

**SECTION 700
ENVIRONMENTAL SYSTEMS**

**STORM DRAINAGE, GRADING, STORM WATER MANAGEMENT, FLOODPLAINS,
EROSION AND SEDIMENT CONTROL AND SOIL TESTING (GEOTECHNICAL)
POLICY**

	<u>Page</u>
701.00 STORM DRAINAGE SYSTEMS - POLICY	
701.01 Adequate Storm Drainage Design in General	700-1
701.02 Discharge Into an Adequate Channel	700-2
701.03 Discharge Into an Inadequate Channel	700-2
701.04 Reference to Manuals and Standards	700-2
702.00 STORM DRAINAGE SYSTEMS - PLANNING AND DESIGN	
702.01 Drainage Areas Up To 200 Acres (81 Hectares)	700-3
702.02 Drainage Areas Greater Than 200 Acres (81 Hectares)	700-3
702.03 Rainfall Frequencies and Duration	700-3
702.04 Storm Drainage Systems in General	700-3
702.05 Storm Drainage Systems for Streets	700-5
702.06 Ditches	700-5
702.07 Headwater and Tailwater Computations	700-6
702.08 Easements in General	700-6
702.09 Easements for Areas of Concentrated Flow	700-7
702.10 Storm Drainage Systems in Relation to Utility Lines	700-7
702.11 Storm Drainage Systems in Relation to Property Lines	700-7
702.12 Storm Drainage Systems in Relation to Slope.	700-7
702.13 Pipe in General	700-8
702.14 Corrugated Metal Pipe	700-8
702.15 High Density Polyethylene Pipe (HDPE)	700-8
702.16 Use of High Density Polyethylene Pipe (HDPE)	700-9
702.17 Easements for Using High Density Polyethylene Pipe (HDPE)	700-9
702.18 Pipe for High Velocity Flow	700-9
702.19 Pipe Cover	700-9
702.20 Major Culverts	700-9
702.21 Storm Drainage Structures in General	700-10
702.22 Headwalls and Endwalls	700-10
702.23 Erosion Protection in General	700-11
702.24 Erosion Protection at Outfalls	700-11

703.00 STORM DRAINAGE SYSTEMS - SUBMISSION REQUIREMENTS

703.01	Schematic Drainage Plan	700-12
703.02	Plan, Plat and Profile Elements	700-12
703.03	Drainage Computation Sheets	700-13
703.04	Headwater and Tailwater Computation Forms	700-13
703.05	Cut Sheets	700-13

704.00 STORM DRAINAGE SYSTEMS - CONSTRUCTION STANDARDS

704.01	Construction in General	700-13
704.02	Line and Grade Stakes	700-14
704.03	Cut Sheets	700-14
704.04	Trenching	700-14
704.05	Bedding	700-14
704.06	Pipe Joining	700-14
704.07	Backfilling	700-14

710.00 GRADING - POLICY

710.01	General Policy for Grading and Clearing	700-15
710.02	Disturbed Area Greater Than 5,000 Square Feet (464.52 Square Meters)	700-15
710.03	Disturbed Areas Less Than 5,000 Square Feet (464.52 Square Meters)	700-16
710.04	Land Disturbance Permit	700-16
710.05	Grading Permit	700-16
710.06	Permit for Retaining Walls	700-16

711.00 GRADING - DESIGN

711.01	Grading Design in General	700-18
711.02	Flood Protection for Residential Development	700-20
711.03	Grading Design for Single-family Attached Development	700-20
711.04	Yard Lighting	700-21

712.00 GRADING - SUBMISSION REQUIREMENTS

712.01	Grading Plans in General	700-21
712.02	Lot Grading Plan Elements	700-22

720.00 STORM WATER MANAGEMENT (SWM) FACILITIES - POLICY

720.01	General Policy for SWM	700-25
720.02	General Policy for BMP and Storm Water Quality	700-26
720.03	Exemptions	700-26
720.04	Waiver of SWM Requirements	700-26
720.05	Waiver of BMP Requirements	700-28
720.06	Pro Rata Share Contribution for SWM in General	700-28
720.07	Pro Rata Share Contribution for a Regional SWM Facility With Allocated Funds	700-29
720.08	Pro Rata Share Contribution for a Regional SWM Facility Without Allocated Funds	700-29
720.09	Pro Rata Share Payments	700-30
720.10	Maintenance Policy for SWM/BMP Facilities in General	700-30
720.11	Residential Properties	700-30
720.12	Nonresidential Properties	700-31
720.13	Apartment Rental Complexes and Mobile Homes	700-31
720.14	Regional Facilities in Residential and Nonresidential Properties	700-31
720.15	Maintenance Agreements for Owner-maintained SWM/BMP Facilities	700-31
720.16	County Maintained SWM/BMP Facilities	700-32

721.00 SWM/BMP FACILITIES - PLANNING AND DESIGN

721.01	Facilities Design in General	700-33
721.02	Design Criteria for SWM/BMP Facilities	700-33
721.03	Location of SWM/BMP Facilities	700-37
721.04	Easements for SWM/BMP Facilities	700-37
721.05	Access to SWM/BMP Facilities	700-38
721.06	Protection of SWM/BMP Facilities	700-38
721.07	Dams	700-39
721.08	Sedimentation and Debris Basins	700-41

722.00 SWM/BMP - SUBMISSION REQUIREMENTS

722.01	General Requirements	700-41
722.02	Plan Elements	700-42
722.03	Modification of Approved Plans	700-43
722.04	Maintenance Notes for Residential Properties (Not Including Apartments and Mobile Home Parks) Where SWM, BMP and Storm Drainage Systems Qualify for County Maintenance	700-43
722.05	Maintenance Notes for Nonresidential Properties (Including Apartment and Mobile Home Parks) Where the SWM, BMP and Storm Drainage Systems Do Not Qualify for County Maintenance	700-43
722.06	Maintenance Notes for Nonresidential Properties (Including Apartments and Mobile Home Parks) Where the SWM and BMP Systems Qualify for County Maintenance but All Other Storm Drainage Systems are Maintained by the Fee Title Owner.	700-44

730.00 FLOODPLAIN MANAGEMENT - POLICY

730.01	General Policy	700-45
730.02	Definitions	700-45
730.03	Floodplain Studies	700-46
730.04	Platting Lots Within the One Hundred (100) Year Floodplain	700-47
730.05	Trees	700-47
730.06	Waivers	700-48
730.07	Nonconforming Use Policy	700-49
730.08	Conflicting Provisions Policy	700-49
730.09	Disclaimer of Liability for Areas Outside Flood Hazard Districts	700-49

731.00 FLOODPLAIN MANAGEMENT - PLANNING AND DESIGN

731.01	Determination of Floodway and Limits of the Regulatory Flood	700-50
731.02	Floodplain Studies	700-50
731.03	Effects of Fills	700-51
731.04	Flood Damage Control	700-52

732.00 FLOODPLAIN MANAGEMENT - SUBMISSION REQUIREMENTS

732.01	General Requirements	700-55
732.02	Floodplain Study Criteria	700-55
732.03	Plan Elements	700-56
732.04	Watercourse Stabilization	700-57
732.05	Flood Damage Control for Structures	700-58

740.00 CHESAPEAKE BAY PRESERVATION AREA - POLICY

740.01	General Policy	700-59
740.02	Definitions	700-59
740.03	Water Quality Impact Assessment in General	700-62
740.04	Interpretation of Resource Protection Area (RPA) Boundaries	700-63
740.05	Waivers in General	700-63
740.06	Nonconforming Use Waivers	700-63
740.07	Exceptions	700-64

741.00 CHESAPEAKE BAY PRESERVATION AREA - PLANNING AND DESIGN

741.01	General Performance Standards	700-65
741.02	RPA Buffers in General	700-66
741.03	RPA Buffers in Intensely Developed Areas (IDA)	700-68
741.04	Minimum Lot Size in Relation to RPA	700-68
741.05	Special Provisions for SWM Facilities	700-69

742.00 CHESAPEAKE BAY PRESERVATION AREA - SUBMISSION REQUIREMENTS

742.01	Certificate of Zoning Approval	700-70
742.02	CBPA Overlay District	700-70
742.03	Preservation Area Site Assessment (PASA)	700-70
742.04	Water Quality Impact Assessment	700-71
742.05	Water Quality Impact Assessment Elements	700-73
742.06	RMA Limits Study	700-74
742.07	Final Site Plans	700-74
742.08	Requests for Exceptions	700-75

750.00 EROSION AND SEDIMENT CONTROL - POLICY

750.01	Definitions	700-75
750.02	General Policy	700-76
750.03	Permits	700-77
750.04	Erosion and Sedimentation Control Management	700-77
750.05	Exceptions.	700-78
750.06	Monitoring, Reports, and Inspections	700-79
750.07	Violations	700-80
750.08	Stop Work Order	700-83
750.09	Injunctions and Other Relief	700-84
750.10	Appeals	700-84
750.11	Escrows	700-84
750.12	Erosion Control Escrow for Building Single-family Detached Dwellings	700-85

751.00 EROSION AND SEDIMENT CONTROL - PLANNING AND DESIGN

751.01	General Requirements	700-85
751.02	Two-layer Perimeter Erosion Control Measures	700-87
751.03	Sedimentation and Debris Basins	700-87

752.00 EROSION AND SEDIMENT CONTROL - SUBMISSION REQUIREMENTS

752.01	General Requirements	700-88
752.02	Phased Plan	700-88

770.00 SOIL TESTING (GEOTECHNICAL) - POLICY

770.01	General Purpose	700-89
770.02	Engineering Soils Categorization	700-89
770.10	Soils Report Requirement	700-90
770.11	Commercial Projects	700-90
770.12	Residential Project	700-91
770.13	Additional Requirements	700-91
770.20	Guidelines for the Preparation of Geotechnical Studies	700-91
770.30	Soils Report Review by Third Party	700-91
770.40	Soils Report Approval	700-92
	Appendix A - Guidelines for Soils (Geotechnical) Studies	Soils-1

780.00 TABLES

Table 7-1	Rational Method	TBL-1
Table 7-2	Pipe Size and Easement Width.	TBL-1
Table 7-2A	Pipe Size and Easement Width for Systems Using High Density Polyethylene Pipe (HDPE)	TBL-2
Table 7-3	Pipe Roughness Coefficient	TBL-2
Table 7-4	Grading Plan Legend	TBL-3
Table 7-5	Waiver Categories for SFD Development	TBL-3
Table 7-6	Pro Rata Cost Sharing Formula	TBL-4

EXHIBITS

- Exhibit 1 Coefficients of Runoff (Rational Formula)
- Exhibit 2 Storm Water Management/BMP Facilities Maintenance Agreement
- Exhibit 3 Overland Flow Time Chart

- Exhibit 4 Rainfall Frequency Relationships (Two [2], Six [6] and Twenty-four [24] Hour Storm)
- Exhibit 5 Rainfall Intensity vs. Duration Curves
- Exhibit 6 Conversion Factors Chart for Pipe Bends Other Than Ninety (90) Degrees
- Exhibit 7 Storm Water Inlet
- Exhibit 8 Culvert Design Form
- Exhibit 9 Storm Sewer Design Form
- Exhibit 10 Storm Water Management Waiver Request Form (Section 706.03.01)
- Exhibit 11 Storm Water Management Waiver Request Form (Section 706.03.02)
- Exhibit 12 Percent Impervious for Various Zoning Classifications
- Exhibit 13 Incremental Unit Hydrograph Values
- Exhibit 14 Floodplain Study Computation Form (Energy Balance)
- Exhibit 15 Storm Water Management Fact Sheet
- Exhibit 16 Roughness Coefficient Computation Chart (Floodplain Studies)
- Exhibit 17 Outlet Protection for Minimum Tailwater Condition
- Exhibit 18 Outlet Protection for Maximum Tailwater Condition
- Exhibit 19 Signage for Dry SWM/BMP Facilities
- Exhibit 20 Signage for Wet SWM/BMP Facilities
- Exhibit 21 Photo Electric Yard Light
- Exhibit 22 Bench Detail

**SECTION 700
ENVIRONMENTAL SYSTEMS**

**STORM DRAINAGE, GRADING, STORM WATER MANAGEMENT, FLOODPLAINS,
EROSION AND SEDIMENT CONTROL**

701.00 STORM DRAINAGE SYSTEMS - POLICY:

701.01 Adequate Storm Drainage Design in General:

A. Adequate drainage must have the hydraulic characteristics to accommodate the expected flow of storm waters from a given watershed, or portion thereof, for a specified duration and intensity of rainfall.

B. The size and capacity of an adequate drainage system shall be determined in accordance with the densities and intensities reflected in the Long Range Future Land Use Plan, the existing zoning, or development in the watershed or affected portions thereof, whichever is greater.

C. Adequate drainage systems shall be designed in accordance with the following:

(1) To accommodate storm water runoff resulting from the ultimate development of the drainage area, unless existing SWM facilities already provided or SWM facilities bonded for construction will provide the required controls. In such cases, the design outflow rates from these facilities shall be considered in the design of the drainage system.

(2) To honor natural drainage divides.

(3) To account for both off-site and on-site peak and base flows.

(4) To convey surface and subsurface (seeps, springs, etc.) waters to a stream, water channel, natural drainageway, or existing facility.

(5) To discharge surface and subsurface waters to a natural drainageway by tying into the drainageway at natural elevations or by discharging the storm water into an existing facility of sufficient capacity to receive the same.

D. Drainage structures shall be constructed in such a manner that they can be maintained at reasonable cost. To facilitate design, construction, and maintenance, said drainage structures shall meet or conform to County or VDOT standards.

E. State law requires that properties and waterways downstream from new development sites be protected from erosion due to increases in the volume, velocity, and peak flow rate of storm water runoff. To satisfy these requirements, the criteria for discharges into adequate or inadequate receiving channels shall apply.

701.02 Discharge Into an Adequate Channel: To satisfy the requirements in Section 701.01 of this manual, the following design criteria options shall apply:

A. Concentrated storm water runoff leaving a development site shall be discharged directly into a well-defined, natural or man-made off-site receiving channel or pipe.

B. Channel must not be subject to erosive velocities for the two-year storm. The designer will check velocity at the point of discharge and at cross sections within three hundred (300) feet (91.44 meters) or upstream of the next control section (culvert, improved channel, storm sewer, etc.), whichever occurs first, that has a steeper slope, or a less stable bed than the point of discharge.

C. If there is not a well-defined off-site receiving channel or pipe, one shall be constructed to convey storm water to the nearest adequate channel. Newly constructed channels shall be designed as adequate channels.

D. A receiving channel may be considered adequate at any point where the total contributing drainage area is at least one hundred (100) times greater than the drainage area of the development site in question or if it can be shown that the peak rate runoff from the site generated by storms up to the applicable designed storm will not be increased after development. The runoff rate and channel adequacy shall be verified with engineering calculations.

701.03 Discharge Into an Inadequate Channel: To satisfy the requirements in Section 701.01 of this manual, the following options shall apply:

A. Improvements to the receiving channel to an adequate condition may be made with permission from downstream property owners. Channel modifications shall comply with applicable laws and regulations.

B. A site plan may be developed that will maintain the predevelopment peak storm water runoff rate. This may be accomplished by enhancing the infiltration capability of the site or by providing on-site storm water detention measures. The predevelopment and postdevelopment peak runoff rates shall be verified by engineering calculations.

C. A combination of channel modifications, storm water detention, or other measures which are satisfactory to the director of Public Works and VDOT may be provided to prevent downstream channel erosion. Easement shall be provided in accordance with Section 702.08 of this manual.

701.04 Reference Manuals and Standards: All manuals and/or standards referenced in this section shall refer to the latest version of such manual or standard.

702.00 STORM DRAINAGE SYSTEMS - PLANNING AND DESIGN

702.01 Drainage Areas Up To 200 Acres (81 Hectares): For drainage areas up to two hundred (200) acres (81 hectares), the rational method, as set forth in the VDOT drainage manual, shall be used for storm drainage design and as outlined in Table 7-1.

702.02 Drainage Areas Greater Than 200 Acres (81 Hectares): The latest editions of Technical Release 55 (TR-55), Urban Hydrology for Small Watersheds, as developed by the Soil Conservation Service (SCS), Technical Release 20 (TR-20) or the U.S. Army Corps of Engineers Flood Hydrograph Package, HEC-1 shall be used for storm drainage design in drainage areas greater than two hundred (200) acres (81 hectares). The SCS methodologies should be used to compute times of concentration and runoff curve numbers. Other methodologies may be used if approved by the director of Public Works prior to the submission of final plans.

702.03 Rainfall Frequencies and Duration:

A. For storm drainage systems that are located within public right-of-ways and/or will be included for maintenance under the state highway system, the rainfall frequencies required by the VDOT drainage manual shall be used, with the exception that no system shall be designed for less than a ten (10) year storm unless allowed elsewhere in the Design and Construction Standards Manual.

B. The two (2) year storm and the actual time of concentration shall be used for the design of curb inlets, catch basins, or yard inlets, unless conditions require a higher frequency curve for design, as determined by the director of Public Works. Grate inlets shall be designed using a fifty percent (50%) clogging factor.

C. For the design of storm drainage systems not to be included in the state highway system, the twenty-five (25) year storm shall be used for drainage areas larger than six hundred (600) acres (243 hectares).

D. The ten (10) year frequency storm shall be used for storm drainage systems in drainage areas equal to or less than six hundred (600) acres (243 hectares).

E. Floodplain studies shall be based on the one hundred (100) year storm.

F. A two (2) hour storm duration shall be used if the rational formula is applied. A twenty-four (24) hour storm duration shall be used for TR-55, TR-20, and HEC-1.

702.04 Storm Drainage Systems in General:

A. At a minimum, storm drainage systems shall be designed to provide overland relief from the one hundred (100) year storm, without damaging or endangering nearby buildings.

B. Closed storm drainage systems, generally, shall be designed to minimize the possibility of interior water surface elevations approaching the level of the inlet throats or manhole covers. The following design characteristics of closed systems shall be avoided or their effect compensated for:

- (1) Numerous bends.
- (2) Shallow systems.
- (3) Junctions with directly opposed laterals.
- (4) Systems which rely on pipes flowing full at high velocities.

C. The design capacity of piped storm drainage systems shall not be computed using headwater pressure in junctions, such as curb inlets, manholes, etc. Piped storm drainage systems shall be acceptable where the hydraulic grade line for the applicable design storm flow is below the elevation of the inlet throats or manhole rim and where, as provided elsewhere in this manual, the capacity of pipes flowing full (by Manning's formula) equals or exceeds the applicable designed storm flow.

D. The location of the hydraulic grade line shall be calculated and submitted with the site plans for systems that are anticipated to contain water surface elevation in junction structures approaching the elevation of the inlet throats or manhole rims.

E. Calculation of the hydraulic grade line shall include consideration of head losses at all junction structures. The hydraulic grade line shall be computed by the method set forth in the VDOT drainage manual. Other established methods may also be used with the approval of the director of Public Works prior to the submission of final plans.

F. The hydraulic grade line may be lowered in a system by the following methods:

- (1) Increasing pipe sizes to reduce the necessary velocities.
- (2) Eliminating bends (but do not, for instance, replace one [1] ninety [90] degree bend with two [2], forty-five [45] degree bends).
- (3) Lowering the elevation of the system to provide deeper structures.
- (4) Eliminating opposing laterals by offsetting their centerline a distance equal to the sum of the diameters.
- (5) Limiting the extent of individual systems.
- (6) Providing effective channelization.
- (7) Providing inlet shaping.

702.05 Storm Drainage Systems for Streets:

A. Storm drainage systems shall be provided when the storm water reaches an eight (8) foot (2.44 meters) spread, measured from the face of curb on public streets with a pavement width up to thirty-six (36) feet (10.97 meters) (see Exhibit 7).

B. Storm drainage systems shall be provided when the storm water reaches a ten (10) foot (3.05 meters) spread on public streets with a pavement width greater than thirty-six feet (36) feet (10.97 meters) (see Exhibit 7).

C. Whenever streets with curb and gutter are proposed, storm water shall not be allowed to cross the surface of the street intersection, except in unusual circumstances where the subsurface conveyance of storm water is deemed impractical by the director of Public Works, such as the distance to the nearest structure. The surface storm water flow shall not exceed one (1) cubic foot per second (fps) (0.0282 cubic meter per second). In such cases, the means of surface conveyance shall be approved by the director of Public Works and VDOT.

D. For curb inlets occurring in sag points of a street, a minimum length of throat of six (6) feet (1.83 meters) shall be required. Spread shall be calculated based on a one-tenth percent (0.1%) grade. For most streets, the vertical curve has sufficient length to result in a gutter section whose effective gradient is one tenth (0.1) of a percent. In cases where special treatment of the gutter gradient is provided, the flattest slope that will actually occur should be used in lieu of the customary one tenth (0.1) of a percent. The spread requirements at the one-tenth (0.1) of a percent grade do not apply to inlets at sump locations within the turnaround of a cul-de-sac, provided that the flow does not overtop the curb or adjacent driveways.

E. Storm drainage systems occurring under curb and gutter shall have a minimum of nine (9) inches (230 millimeters) of clearance from the bottom of the gutter or as may be permitted by the director of Public Works.

F. Whenever streets without curb and gutter are proposed, storm water shall not be allowed to cross a street intersection. The storm water shall be handled by a storm sewer pipe or culvert.

G. Expansion joints in storm drainage structures shall be placed and constructed in accordance with VDOT requirements and standards.

702.06 Ditches:

A. Open drainageways shall be designed in accordance with the current VDOT drainage manual.

B. Open drainageway stabilization shall be required based on velocity as referenced in Chapter 3, Tables 3.17A and 3.17B, of the Virginia Erosion and Sediment Control Handbook, current edition.

C. Graded grass or sod-lined swales and ditches outside of the right-of-way shall be sloped a minimum of two percent (2%).

D. Riprap lined ditches shall be sloped adequately to ensure positive flow. Within the right-of-way, paved ditches shall be required when the ditch centerline grades are in excess of five percent (5%) unless it can be shown through calculations that the velocity of flows is permissible for the alternative lining specified and/or the soil type.

E. Ditch linings of poured concrete are generally acceptable.

F. Permanent ditch linings of part-circle section composed of bituminous or asbestos fiber pipe, or plastic or similar lightweight materials with nonrigid properties, shall not be acceptable.

G. Swales in the back of single-family detached dwelling units shall be designed and located to preclude water from entering the dwellings. The elevation of flow resulting from the ten (10) year storm flow level shall be kept below the nearest opening (doors, windows, etc.) to the dwelling.

702.07 Headwater and Tailwater Computations:

A. The current edition of the VDOT drainage manual shall be used for these computations.

B. The maximum allowable headwater depth is that depth where the water does not exceed a height greater than eighteen (18) inches (450 millimeters) below the edge of the roadway shoulder, or where the depth of the ponded area equals fifteen (15) feet (4.57 meters).

702.08 Easements in General:

A. Easements shall be provided for storm drainage systems and areas of concentrated flow.

B. Easements for natural stream channels shall not be required.

C. Adequate access shall be provided for storm drainage systems. Generally, storm sewer systems shall be constructed to the property line. If a storm drainage system terminates or starts short of a property line, adequate easements shall be dedicated to allow for maintenance and future extension of the system.

D. The drainage easement shall not be less than the widths listed in Table 7-2. Trenches with depths greater than six (6) feet (1.83 meters) shall have five (5) feet (1.52 meters) of additional easement width for each five (5) foot (1.52 meters) increment of additional depth.

E. Storm drainage pipe shall be placed within the middle third of the easement.

F. Permanent structures or unauthorized obstructions such as fences or trees shall not be located within easements.

702.09 Easements for Areas of Concentrated Flow:

A. Easements shall be required for areas of concentrated flow as determined by the director of Public Works. Areas of concentrated flow shall mean modified or constructed swales of ditches concentrating flows from more than one lot and where the drainage area exceeds two (2) acres (0.81 hectare). It shall also mean modified or constructed swales or stabilized existing drainageways leading into and handling the outfall of culverts located within public rights-of-way.

B. For open drainageways (areas of concentrated flow) an easement is required of the same width that is required for a pipe sized to carry the designed flow based on the drainageway slope. Easements for drainage ditches shall be of sufficient width for proper maintenance.

702.10 Storm Drainage Systems in Relation to Utility Lines:

A. The minimum allowable vertical distance between storm drainage pipe and other underground piping, with the exception of waterlines, shall be one (1) foot (300 millimeters). The minimum allowable vertical distance between storm drainage pipes and waterlines shall be 0.5 feet (150 millimeters).

B. Where a storm drainage pipe crosses below a sanitary sewer line within three and one-half (3-1/2) feet (1.07 meters), ductile iron pipe shall be required for the sanitary system. Encasements shall require an increase in the storm drainage excavation at least five (5) feet (1.52 meters) into undisturbed earth.

702.11 Storm Drainage Systems in Relation to Property Lines:

A. Storm drainage pipes or systems, including energy dissipating devices, shall be located to the property line to protect adjacent properties. When a storm drainage system terminates at a property line, above the toe of a fill slope, the system shall be continued to the toe of the slope.

B. When a storm drainage system is proposed to tie-in with an existing drainage system, the developer shall be required to notify the owners of that system and inform them about the proposal in writing. In addition, the developer shall be responsible to inform the owners prior to the start of construction in the vicinity of the existing system.

C. Outfall structures shall be terminated at the property lines.

702.12 Storm Drainage Systems in Relation to Slope:

A. Slopes over twenty percent (20%) for a storm drainage system are generally not acceptable, unless specifically approved by the director of Public Works.

B. When the slope of a storm drainage system exceeds sixteen percent (16%), anchors shall be required to prevent sliding of the pipe. Adequate erosion control shall be installed at the outlet to prevent undermining of the endwall.

C. A cut-off wall shall be required at the outfall of a storm drainage system exceeding sixteen percent (16%) slope (see VDOT Road and Bridge Standards, Detail 101.27).

702.13 Pipe in General:

A. Pipe used for storm drainage systems shall be concrete. Concrete pipe within the right-of-way of a public street or beyond the limits of the right-of-way, shall meet the three (3) edge-bearing strength test requirements for ASTM C76 Class III reinforced concrete pipe, latest revision. Culvert pipe classed as "seconds" by the manufacturer, or pipe which has been rejected from another project, shall not be permitted. The laying length shall not be less than three (3) feet (900 millimeters).

B. Pipe size shall, generally, not be reduced along the direction of flow except for storm water management systems. The director of Public Works may also allow reduction in one pipe size increment when tying into a drainage structure where the outflow pipe is at least thirty-six (36) inches (900 millimeters) in diameter.

C. Storm sewer pipe size shall be determined by using Manning's formula, where:

$$\frac{V}{n} = 1.49 \frac{R^2}{3} S^{1/2} \text{ feet/sec} \qquad \frac{V}{n} = \frac{R^2}{3} S^{1/2} \text{ meters/sec.}$$

(where R is in meters)

D. Pipe shall have a minimum coefficient of roughness in accordance with Table 7-3.

E. The minimum pipe size for a culvert and storm drainage system shall be fifteen (15) inches (375 millimeters) or equivalent, except when used under a driveway entrance on a ditch section street where twelve (12) inch (300 millimeters) or equivalent culverts may be permitted.

F. The maximum distance of piping to be uninterrupted by appurtenances shall be eight hundred (800) feet (243.84 meters) for pipes thirty-six (36) inches (900 millimeters) in diameter or greater and four hundred (400) feet (121.92 meters) for pipes less than thirty-six (36) inches (900 millimeters) in diameter.

G. Pipe shall be straight between manholes, catch basins, or other appurtenances.

702.14 Corrugated Metal Pipe:

A. Corrugated metal pipe, where permitted by the director of Public Works and VDOT, shall meet current VDOT standards.

B. Corrugated metal pipe, when permitted by VDOT east of Interstate 95, shall be fully bituminous coated with a paved invert.

702.15 High Density Polyethylene Pipe (HDPE): High density polyethylene pipe (HDPE) may be used only in sites that do not qualify for County maintenance. Existing storm drainage systems using HDPE will not be accepted for County maintenance.

702.16 Use of High Density Polyethylene Pipe (HDPE): The use of HDPE in storm drainage systems shall be conditioned upon the following:

- A. The system is completely enclosed.
- B. The maximum pipe size is thirty-six (36) inches.
- C. Pipe used shall have a smooth interior.
- D. Installation shall be in accordance with manufacturer's specifications (ASTM D2321).

702.17 Easements for Using High Density Polyethylene Pipe (HDPE): Easements for systems using HDPE shall be provided in accordance with Table 7-2A.

702.18 Pipe for High Velocity Flow: Pipe manufactured with six thousand (6,000) pounds per square inch (41.37 megapascal) concrete, and meeting the strength requirements of ASTM C76 Class III, latest revision shall be used if velocities in storm sewer pipe exceed twenty (20) feet per second (6.10 meters per second), based on the ten (10) year storm. Such velocities shall require approval of the director of Public Works.

702.19 Pipe Cover:

- A. Class of concrete pipe shall be increased above the requirements in Section 702.13 of this manual based on the amount of cover.
- B. The minimum and maximum cover shall conform to VDOT standard PC-1 for drainage pipes within the street right-of-way.
- C. Pipe laid outside of street right-of-way shall have a minimum of one (1) foot (300 millimeters) of cover.
- D. If the minimum cover requirements as set forth in this section cannot be met, then structural modifications may be submitted for approval of the director of Public Works and VDOT.

702.20 Major Culverts:

- A. Major culverts shall be designed in accordance with VDOT standards.
- B. A pipe culvert may be used where drainage requirements call for an opening of thirty-six (36) square feet (3.35 square meters) or less.
- C. A box culvert, a standard span, or a specially designed bridge shall be used where drainage requirements call for an opening over fifty (50) square feet (4.65 square meters).

702.21 Storm Drainage Structures in General:

A. Structures and appurtenances for inlets, curb and gutter, endwalls, junctions, etc., shall conform to the current edition of the road and bridge standards of VDOT unless approved otherwise in writing by the director of Public Works. The use of precast structures from an approved manufacturer shall be in accordance with VDOT standards and specifications.

B. A drainage structure shall be located at every change in line and grade and change in pipe size. Where permitted by the director of Public Works and VDOT, pipes may tie directly into box culverts.

C. Where pick up of additional storm water is required, a yard inlet, curb inlet, or drop inlet shall be constructed.

D. At every structure, a tenth (0.10) of a foot (31 millimeters) drop in invert is required.

E. The ends, entry or exit, of a storm drainage system shall be provided with a standard headwall, endwall, curb inlet, yard inlet, flared end section, or other appurtenance suitable for the intended use of the storm drainage system.

702.22 Headwalls and Endwalls:

A. Standard endwalls or end sections shall be provided on culvert pipe, except twelve (12) inch (300 millimeters) and fifteen (15) inch (375 millimeters) diameter pipe culverts under driveways along streets with open drainage ditches.

B. A standard endwall or end section shall be provided at the outlet of a closed storm drainage system and at the inlet of such a system where no other approved structure is required.

C. The following guidelines shall be used to determine the use of headwalls and endwalls:

(1) On culverts or storm drainage system inlets and outlets from twelve (12) inches (300 millimeters) in diameter to twenty-four (24) inches (600 millimeters) in diameter, a flared end section shall be used unless the height of fill and side slopes exceeds ten (10) feet (3.05 meters) or two-to-one (2:1), respectively, in which case a standard headwall should be used. Generally, if the headwater over diameter (HW/D) ratio is up to one and one-half (1-1/2), then a headwall or approved end treatment shall be required, provided it can be installed safely and not create a potential traffic hazard in the opinion of VDOT and the Department of Public Works.

(2) On a culvert or a storm drainage system inlet and outlets between twenty-four (24) inches (600 millimeters) and thirty-six (36) inches (900) millimeters) in diameter, either a standard flared end section or headwall shall be required depending upon the height of the fill and the quantity of water and its velocity for the designed year storm. Generally, a flared end section can be used in accordance with the following: (1) if the fills are ten (10) feet (3.05 meters) or less, (2) HW/D is less than one and one-half (1-1/2), (3) less than fifty (50) cfs (1.42 cubic meters per second) inflow, or (4) if the installation of a headwall would constitute a safety hazard in the opinion of VDOT and the Department of Public Works.

(3) If the culvert or closed storm drainage inlet and outlet exceeds thirty-six (36) inches (900 millimeters) in diameter, a standard headwall shall be provided, unless this headwall would constitute a safety hazard to the traveling public in the opinion of VDOT and the Department of Public Works. In this case, a flared end section should be considered. Only endwalls are available for oval elliptical concrete culverts.

702.23 Erosion Protection in General: Erosion protection shall be required where curb and gutter terminates on fill sections, or on soil that has eroding characteristics as determined by the director of Public Works.

702.24 Erosion Protection at Outfalls:

A. Erosion protection at the outlets of storm drainage systems shall be provided in accordance with the outlet protection standards contained in the Virginia Erosion and Sediment Control Handbook and the VDOT drainage manual, with the exception that the use of grouted riprap will not be acceptable (See Exhibits 17 and 18).

B. Velocities in excess of eighteen (18) feet (5.49 meters) per second shall require special design energy dissipaters or impact basins. These structures may be designed in accordance with the following publications: Hydraulic Design of Stilling Basins and Energy Dissipaters, Engineering Monograph #24, U.S. Department of the Interior, Bureau of Reclamation; Design of Small Dams, U.S. Department of the Interior, Bureau of Reclamation, or similar text. Appropriate riprap protection should be provided in conjunction with these devices to prevent erosion and scour below the structure.

C. The following guidelines shall be considered in the layout of storm drainage systems to minimize the erosion problems and subsequent construction failures which occur at a storm drainage system outlet:

(1) The outlet of the storm drainage system shall discharge directly into a stabilized existing drainageway.

(2) The outlet of the storm drainage system should be as compatible as possible with the grade, horizontal and vertical alignment, and location of the existing drainageway.

(3) Placing outlet structures of storm drainage systems on fill material should be avoided. If the outlet is on fill, extra erosion protection shall be required, however, placing erosion protection on fill material should be avoided.

(4) If deviations from (1) and (2) of this subsection are necessary, the preferred alternative would be a stabilized ditch of adequate capacity to convey the designed storm flow from the outlet structure to the existing drainageway. Deviation from above stated policy shall be subject to the review and approval of the director of Public Works.

703.00 STORM DRAINAGE SYSTEMS - SUBMISSION REQUIREMENTS

703.01 Schematic Drainage Plan:

- A. A schematic drainage plan shall be submitted with a final plan.
- B. A drainage plan shall include the following:
 - (1) Proposed detention areas.
 - (2) Proposed major drainage systems.
 - (3) Existing drainage divides, and major proposed changes to these divides.
 - (4) Outline of the on-site drainage area.
 - (5) Contours of a two (2) foot (0.50 meter) interval. One meter contours can be used in large areas, eight (8) hectares (20 acres) or greater.
 - (6) Differential areas shown with respect to the point of concentration and the acreage.
 - (7) A minimum scale of one (1) inch equals one hundred (100) feet, unless otherwise approved by the director of Public Works. Metric scale 1:1000.
 - (8) Off-site drainage areas contributing storm water runoff to the system being designed shown on County topographic maps or other acceptable maps.

703.02 Plan, Plat, and Profile Elements:

- A. Storm drainage systems shall be shown in plan and profile on twenty-four (24) inch (600 millimeters) by thirty-six (36) inch (900 millimeters) sheets.
- B. The plans and profiles shall contain the following:
 - (1) Construction information, including invert elevations (in and out), size, type of pipe, gauge, length and percent of slope shown in plan and profile.
 - (2) Storm drainage appurtenances identified by the type and number (i.e., DI-1, DI-3B), including number and length of throats and locations on the profile and/or the plan.
 - (3) The appropriate notes and details for construction of erosion control measures at outlets shown on the plan.
 - (4) Drainage arrows shown on curb and gutter, storm sewers, ditches, site pavement, and drainage divide maps.

C. Easements:

(1) Easements for storm drainage systems and areas of concentrated flow shall be shown on the plan and plats.

(2) Easements for drainage ditches shall be shown on the record plat.

D. Ditches:

(1) All ditches to be utilized for open conveyance of storm water shall be shown in plan and profile with stationing and grade.

(2) Computations used in drainage ditch design shall be submitted with the plans.

(3) A typical ditch section shall be shown on the plan. The transitioning of paved ditches to other appurtenances shall also be shown.

703.03 Drainage Computation Sheets: Drainage computation sheets shall be submitted on forms approved by the Department of Public Works. This shall include consideration of on-site drainage.

703.04 Headwater and Tailwater Computation Forms: Headwater and tailwater computations shall be submitted on standard forms approved by the director of Public Works.

703.05 Cut Sheets: Cut sheets shall be submitted to the Department of Public Works in accordance with Section 704.03 of this manual.

704.00 STORM DRAINAGE SYSTEMS - CONSTRUCTION STANDARDS

704.01 Construction in General:

A. Construction of storm drainage systems shall be in accordance with the approved plans, specifications, and/or the cut sheets submitted to the Department of Public Works.

B. Substantial deviations in location, line, or grade of a storm drain, structure, or accessory from that shown on the approved construction plans shall be submitted to the Department of Public Works for review and approval prior to construction.

C. Drainage ditches shall be constructed in accordance with the current VDOT drainage manual. Ditch stabilization will be required based on velocity as is referenced in Chapter 3 of the Virginia Erosion and Sediment Control Handbook, current edition.

D. Drainage ditches shall be constructed true to the approved cross section and shall be set on a uniform grade and a straight line with the longitudinal axis of the pipe, unless otherwise approved by the director of Public Works. The side slopes shall be free from rocks, stumps, and woody vegetation. After dressing the slopes to the proper cross section, they shall be seeded or sodded with grass to prevent erosion in accordance with the Virginia Erosion and Sediment Control Handbook.

704.02 Line and Grade Stakes: The field layout of storm drainage systems shall be performed by the applicant's engineer or surveyor, who shall place adequate line and grade stakes and furnish elevation for manhole tops in accordance with the approved plans.

704.03 Cut Sheets

A. After setting grade lines and stakes, the applicant's engineer or surveyor shall prepare suitable cut sheets in a clear and legible manner, giving necessary construction data.

B. Two (2) sets of cut sheets, certified by a professional engineer or surveyor shall be submitted to the Department of Public Works. The engineer or surveyor who certifies the cut sheets shall also provide the following statement on both sets: "The professional seal and signature appearing on this document certifies that information shown conforms to the approved plan and/or actual field conditions. Minor deviation from the approved plan shall be performed in a manner comparable to the original design and shall meet applicable standards." The Department of Public Works may perform a cursory review to verify conformance to the approved plans.

704.04 Trenching: Trenching will follow the standards of OSHA and VDOT standards.

704.05 Bedding: VDOT standards shall apply to bedding.

704.06 Pipe Joining:

A. The use of rubber gaskets when joining pipes is permitted, provided that installation is in strict accordance with manufacturer's specifications and the recommended lubricant is used. The type of rubber gasket, lubricant, and pipe shall be subject to approval by the director of Public Works or designated agent.

B. When corrugated metal pipe culvert is used, jointing shall be in strict accordance with the pipe manufacturer's specifications.

C. Jointing shall comply with VDOT standards if roads and streets are to be taken into the state system.

704.07 Backfilling:

A. Backfill in areas subject to vehicular traffic or structural loading shall begin at the top of the standard granular bedding and shall be placed in uncompacted lifts no greater than eight inches thick. These lifts shall be compacted ninety-five percent (95%) of the maximum dry density, as determined by ASTM D698, AASHTO T99, or VTM-1.

B. Backfill material shall be free of organic material, frozen clods, highly plastic silt or clay and other unsuitable material. Rock pieces larger than one inch (25 millimeters) shall not be used in the backfill which is within two feet (600 millimeters) of the pipe. No stone or rock larger than 10 inches (250 millimeters) in any dimension shall be used in backfilling of sewer lines.

C. Backfill in areas not subject to vehicular traffic shall be compacted sufficiently so that any subsidence that may occur shall not be objectionable nor detrimental to normal use.

D. Backfill and replacement work in existing or proposed roads to be accepted into the VDOT system shall be executed in accordance with all applicable VDOT standards. All surplus materials shall be disposed in approved areas.

710.00 GRADING - POLICY

710.01 General Policy for Grading and Clearing:

A. Generally, grading within the following areas should be avoided:

(1) Wooded slopes equal to or greater than twenty-five percent (25%) and having a continuous area of ten thousand (10,000) square feet (929 square meters) or greater.

(2) Wooded one hundred (100) year floodplain.

(3) Wooded slopes equal to or greater than fifteen percent (15%) adjacent to a stream.

B. Slopes steeper than three to one (3:1) are generally not acceptable, unless the existing grades are already in excess of three to one (3:1), or tying out steeper slopes to existing grades is required to preserve woodland areas that are to remain undisturbed. These preserved woodland areas must be in addition to the required minimum tree canopy and landscaping. In this instance, the developer shall be responsible to have a geotechnical engineering report prepared by a professional engineer and shall implement the recommendation in the report for the grading and stabilization of the area.

C. Graded slopes steeper than two to one (2:1) are not permitted.

D. The limits of clearing shall be depicted on the grading plans. They shall be located at the outermost limits of the area to be cleared, which shall include the erosion and sediment controls. The limits of clearing shall not include any unnecessary clearing.

710.02 Disturbed Area Greater Than 5,000 Square Feet (464.52 Square Meters): An approved lot grading plan certified by a land surveyor or professional engineer is required for single-family development and additions to existing single-family development where the generated disturbed area exceeds five thousand (5,000) square feet (464.52 square meters).

710.03 Disturbed Areas Less than 5,000 Square Feet (464.52 Square Meters): A nonengineered plan, showing the land to be disturbed, is required prior to the issuance of any permits for an addition to existing single-family development where the disturbed area is less than five thousand (5,000) square feet (464.52 square meters).

710.04 Land Disturbance Permit: A land disturbance permit, as defined in Section 100.00 of this manual, is required when no other permits are required for land disturbances greater than two thousand five hundred (2,500) square feet (232.26 square meters) but less than five thousand (5,000) square feet (464.52 square meters), or within easements when changes in grade are proposed. The permit shall require compliance with the appropriate erosion control criteria in accordance with Section 750.00 of this manual.

710.05 Grading Permit:

A. An approved grading plan and permit shall be required to be on the job site during construction. The approved grading plan is used to check the final grading prior to the issuance of the occupancy permit. The occupancy permit may be denied if the grading plan and the actual grading of the site do not substantially agree.

B. Substantial deviation from the approved lot grading plan shall require approval of a revised grading plan. The director of Public Works may approve deviations if they are substantially in accordance with the intent of this manual. Those not in substantial accordance shall be denied.

C. Lot grading plans that are part of subdivision plans are valid for the life of the subdivision plans, provided there have not been any approved revisions to the lot grading portions of the subdivision plan in the interim.

D. The validity period for lot grading plans that are not part of the subdivision plans shall be equal to the time specified for final site plans in Section 100 of this manual. If, during that period, a building permit is not issued, then a new lot grading plan conforming with the current requirements of the DCSM must be submitted and approved prior to the issuance of a building permit.

710.06 Permit for Retaining Walls:

A. Retaining walls shall require a structural design certified by a professional engineer to be submitted for plan review approval and issuance of a building permit. Following are two exceptions to this requirement:

(1) A single retaining wall that does not support the surge from any other structure and retains a total elevation difference equal to or less than two (2) feet (600 millimeters) in height shall be exempt from the requirements set forth in subparagraph A above.

(2) The structural design for a single retaining wall or a tiered retaining wall system that retains a total elevation difference equal to or less than forty-two (42) inches (1.07 meters) and is not associated with any other buildings or structures shall not require the certification and signature of a professional engineer, but does require plan review approval and issuance of a building permit.

B. Prior to construction, the developer or builder shall post a bond with the County equal to the cost of constructing the permitted retaining walls.

C. Retaining walls must meet the approval of the zoning administrator.

(1) The design of all wall systems shall show all topographic information for a distance of one and one-half (1.5) times the height of the wall to the high side and at least twice the height in front of the wall; under no circumstances shall the distance shown on either side of the wall be less than twenty (20) feet (6.10 meters).

(2) Walls greater than two (2) feet (600 millimeters) made of timber or other materials subject to decay or rot shall have an easement in accordance with subparagraph (4) below for maintenance, repair, reconstruction and/or restoration. The owner shall record restrictive covenants on the property in accordance with subparagraph (4) below that shall prohibit the installation of other structures, buildings and utility lines which were not designed in conjunction with the wall design.

(3) All nonengineered walls greater than two (2) feet (600 millimeters) and less than or equal to forty-two (42) inches (1.07 meters) shall be subject to restrictive covenants, which are in accordance with the distances set forth in subparagraph (4) below, that prohibit the installation of other structures, buildings and utility lines on, below, or through the retaining wall system.

(4) When required, retaining wall maintenance easements shall be granted to homeowners' associations or other similar organizations. The scope of the retaining wall maintenance easement and/or restrictive covenants shall encompass the entire retaining wall system. This easement and/or restrictive covenants shall extend along the ground above the retaining wall system and along the ground below the retaining wall system a distance of at least two and one-half (2.5) times the total height of the retaining wall system, and the distance of this easement and/or restrictive covenants shall be not less than ten (10) feet (3.05 meters), regardless of the height of the retaining wall system. The retaining wall maintenance easement and/or restrictive covenants shall extend a minimum of ten (10) feet (3.05 meters) from each end of the retaining wall system. The retaining wall maintenance easement and/or restrictive covenants shall be placed to provide an equal amount of clear access space on all sides of the retaining wall system.

(5) The director of Public Works may grant a waiver of the foregoing retaining wall maintenance easement requirement under the following condition:

Where the owner provides an acceptable and safe means for replacing, repairing, restoring or reconstructing the retaining wall system with an identical construction method while providing for and maintaining the safety of proposed buildings, structures or utility lines, which method shall be certified by an engineer licensed to practice in Virginia.

D. When a retaining wall is determined by a County field inspection to have the characteristics or conditions that may be hazardous to public health, safety, and welfare, safety devices such as guardrails, fences or any other measures as required by the County building official shall be installed.

E. In areas prone to graffiti vandalism, the surface of retaining wall shall be treated by a protective coating which can easily be washed and wiped. Instead of a protective surface coating, the retaining wall can be covered or access to the wall blocked with plantings in accordance with Section 804.03 of this manual.

F. No occupancy permit shall be issued until all retaining walls in the general area of the units scheduled for occupancy have been constructed, inspected and approved.

711.00 GRADING - DESIGN

711.01 Grading Design in General:

A. Where permitted, slopes steeper than three to one (3:1) shall be stabilized with pegged sod or other vegetation approved by the director of Public Works.

B. Benches or diversions shall be provided on slopes between two to one (2:1) and three to one (3:1) and steeper, when vertical height of slope exceeds fifteen (15) feet (4.57 meters). Benching shall be in accordance with Exhibit 22 to minimize the flow of stormwater along the face of the slope. The flow shall be directed to and collected by a storm drainage system at each bench. The width of benches may be decreased to four (4) feet, if runoff is diverted away from the top of the bench and into a defined drainage system. For retaining wall applications, refer to Section 710.06 of this manual.

C. Swales shall be sloped a minimum of two percent (2%), but should preferably be three percent (3%). Any swale with steep longitudinal slope shall be properly stabilized in accordance with Section 750.00 of this manual.

D. Grading for the perimeter area immediately adjacent to a proposed building shall be designed in such a manner as to lead water away from the building. In single-family dwellings where the finished yard slopes are steeper than four to one (4:1), a ten (10) foot (3.05 meters) wide slope transition area with slopes not less than two percent (2%) but not greater than ten percent (10%) shall be provided. Dwellings with walk-out basements may not have to comply with this requirement upon approval by the director of Public Works, provided that two percent (2%) cross-slopes away from the building are maintained.

E. Utilizing the side yards between houses as a route for a significant amount of surface water can create problems, i.e., the discharge of significant volumes of water at a single point across a street sidewalk. Where the longitudinal grade of the street exceeds five percent (5%), the water has a tendency to run along the outer edge of the sidewalk, rather than running directly into the street. This can create serious erosion problems around and under sidewalks which may be avoided as follows:

(1) Design overlot grading, to route storm water between several houses and toward the street so that only small amounts of water drain between one (1) pair of adjacent houses. This solution may not always be adequate to prevent storm water from running parallel with a steeper street along the outer edge of the sidewalk.

(2) Install an adequate yard inlet or inlets at intervals in the mid-block drainage swale with the storm water being intercepted by the yard inlet and carried in a storm drainage system between houses to connect with the storm drainage system in the street. If possible, this should be designed when the drainage plan is approved, otherwise the approved drainage plan shall be revised to compensate for this occurrence. If construction of the streets has taken place, the finished construction could be affected.

F. Grading for single-family detached development, where the minimum lot size required is one-half (1/2) acre (0.20 hectare) or less, shall be designed so that the maximum drainage area for a surface swale located within individual lots shall be one (1) acre (0.4047 hectare). A closed storm drainage system shall be required when the drainage area exceeds one (1) acre (0.4047 hectare). Surface swales drainage more than one acre (0.4047 hectare) may be located within common areas. Particular circumstances and other considerations such as sidewalk erosion may require other measures and site plan details.

G. When a structure is proposed in a problem soil or a high ground water area, the builder shall be responsible to have a geotechnical engineering report prepared by a professional engineer. The recommendation in the geotechnical report shall be applied to the proposed dwellings.

H. Driveways for single-family dwelling lots with required minimum areas of less than one (1) acre (0.4047 hectare) shall be paved with a minimum of four (4) inches (100 millimeters) of VDOT 21A stone and two (2) inches (50 millimeters) of asphalt or bituminous concrete, or 5 inches (125 millimeters) of concrete over adequately compacted subgrade. For lots where the

minimum lot area is one (1) acre (0.4047 hectare) or more and the streets are paved, driveways shall be paved from the edge of pavement to the right-of-way line. Driveway apron construction shall be included in the subdivision construction bond. Where allowed, gravel driveways shall have a minimum of six (6) inches (150 millimeters) of VDOT number 21A stone. The 21A stone may be topped with additional clean aggregate.

711.02 Flood Protection for Residential Development:

A. Lot grading, house siting, and house elevation shall provide for protection of the house against flooding from storms exceeding the capacity of the normal designed storm for which the storm drainage system is sized. Consideration of this factor will also provide protection against occasional blockage of pipes.

B. Houses shall be sited outside of depressed grade areas, particularly where overland flow from the depressed area could only take place when ponded water reaches an elevation higher than that of the first floor elevation of the house. Provision of a yard inlet in the depression is required, but not sufficient by itself, since it can be blocked or its capacity exceeded by a storm exceeding the ten (10) year designed storm.

C. County requirements for storm drainage systems in relationship to the one hundred (100) year flood shall be considered. Paths of overland flow should, in conjunction with the pipe system, provide for discharge of similar flows through internal areas of a development without flooding of homes. Where overlot grading and house locations do not appear to meet this requirement, the Department of Public Works shall require that hydraulic calculations be submitted which provide the adequacy of the proposed plan to dispose of the designed flood.

D. Where flood elevations have been established with floodplain studies, the siting of the lots shall be in accordance with Section 730.04 of this manual.

711.03 Grading Design for Single-family Attached Development:

A. Grading plans for single-family attached dwellings shall account for access to the rear of the lots. An owner or builder of a single-family attached dwelling may erect a fence along the rear property lines to enclose the maximum available area of rear yard. If a cut or fill slope begins at the rear yard line, and fences are erected at the line, then pedestrian access is severely restricted. A pathway area five (5) feet (1.52 meters) in width abutting the rear line of lots shall be provided.

B. Storm drainage, sanitary sewer and water line easements shall not be located within ten (10) feet (3.05 meters) of the rear wall of an individual single-family attached dwelling unit.

C. Routing of drainage swales through an individual single-family attached lot shall be avoided. Such swales may be blocked by fences and other improvements and generally restrict the use of the available yard area.

D. Open ditches within single-family attached development should be carefully considered from the viewpoint of maintenance, attracting nuisance, erosion, and the limitations on pedestrian access. Carrying the flow within pipes rather than open ditches eliminates these problems. However, where ditches or swales are used, shallow channels with flat side slopes utilizing partial protective linings should be considered. For major storm drainage channels, where carrying the flow in pipes would be economically impractical, such considerations become even more important. Where major channels intervene between units and important pedestrian destinations (such as a school site), consideration should be given to provide a pedestrian bridge. Where major channels are immediately adjacent to housing, fencing to prevent nuisance shall be considered. All channels should be designed to prevent ponding of water. This should be particularly considered in flat bottom channels with flow-line grades by providing a cross slope to a minor low flow channel in the bottom of the main channel.

E. Utility lines (including sewer, water, gas, telephone, and electric lines), shall be placed to avoid conflicts with the other utilities, and provide accessibility for their maintenance and repair, particularly in off-street areas.

F. A photoelectric entrance light shall be used on an individual single-family attached dwelling unit unless an alternative is approved by the director of Public Works.

711.04 Yard Lighting

A. Subdivision Lighting: On each single-family detached residential building lot within a subdivision, where the minimum required lot area is twenty thousand (20,000) square feet (1,858.06 square meters) or less, the subdivider shall install a yard light on each lot which conforms to the design standards of this manual (See Exhibit 21).

B. A photoelectric yard light (Exhibit 21) must also be installed on single-family attached building lots, unless the owner or builder elects, pursuant to the Uniform Statewide Building Code, to install photoelectric lighting at individual outdoor entrances. Notwithstanding anything in this manual to the contrary, photoelectric cell lights are not required to be placed at dwelling entrances to single-family attached dwelling units, unless the owner or builder so elects, pursuant to this provision and the Uniform Statewide Building Code.

712.00 GRADING - SUBMISSION REQUIREMENTS

712.01 Grading Plans in General:

A. A lot grading plan, certified by a professional engineer or land surveyor, shall be approved prior to the issuance of a building permit.

B. Site development plans for single-family development where the minimum lot size required is less than one acre shall incorporate future grading for all individual lots to provide effective erosion and sediment control measures and reduce future drainage problems.

C. A site plan for single-family attached dwellings shall be included with the final subdivision plan.

D. A grading plan may be submitted for review after approval and release of the final subdivision plan. Building permits shall be issued after the subdivision plat has been recorded.

E. Some revisions to the grading plan may be permitted, should the house type be revised if the owner demonstrates that the change does not materially affect proposed grading adjacent to major drainage systems or preclude erosion control in accordance with Section 750.00 of this manual.

712.02 Lot Grading Plan Elements:

A. The following items shall be provided and indicated on grading plans for residential development:

(1) Scale of one (1) inch equals thirty (30) feet (metric 1:250) or less for lots with areas less than one (1) acre (0.4047 hectare). A scale of up to one (1) inch equals fifty (50) feet (metric 1:500) shall be allowed for lots with areas of one (1) (0.4047 hectare) or greater.

(2) Legend in accordance with Table 7-4.

(3) Contours at two (2) foot (0.5 meter) intervals defining the lot grading. All contours and spot elevations shall be referred to USGS datum and certified by the professional who prepares the plan. The five (5) foot contour topographic maps prepared by the County may be used to prepare individual lot grading plans for lots which were not platted and approved as part of a subdivision, provided that: (1) the lots are greater than two (2) acres, and (2) the limits of clearing and grading are no less than fifty (50) feet from any property line. Any information prepared by others shall be verified to be reasonably accurate at the time the plans are submitted for review.

(4) Only for individual lots, distances from structures to the property lines, building restriction lines, and other proposed changes.

(5) Spot elevations at building entrances, each corner of the buildings, at driveway entrances and at changes in the grade of driveways.

(6) Walkout basements showing the proposed elevations and spot elevations at basement entrances.

(7) Driveways for single-family development, dimensioned at a minimum of ten (10) feet (3.05 meters) in width; sloped a minimum of one percent (1%) and a maximum of fifteen percent (15%).

(8) Parking pads for single-family development not less than three hundred sixty (360) square feet (33.45 square meters), sloped a minimum of one percent (1%) and a maximum of five percent (5%) where there is no garage or carport for two or more vehicles.

(9) Driveway entrances for single-family development aligned with garages and carports. When the driveway length is less than forty (40) feet (12.19 meters) (measured from the garage entrance or carport front wall to the street right-of-way), the driveway entrance and entire driveway length shall be in accordance with Section 650.36 (DE-2) typical section of this manual. An appropriate turnaround shall be provided when the driveway length is fifty (50) feet (15.24 meters) or more.

(10) Lead walks, risers, and the elevations at landings.

(11) Grading of the front of the lots and cuts and fills which define the ditch line and the location of the driveway culvert.

(12) Driveway culvert, computations designed to pass the ten (10) year storm, and culvert invert elevations. A minimum culvert size of twelve (12) inches (300 millimeters) shall be required.

(13) Yard light locations shown on each lot, when required in the development.

(14) Platted storm drainage and sanitary sewer easements.

(15) Areas to remain undisturbed as intended by Section 710.01 of this manual, and indicated by a limit of disturbance line.

(16) An appropriate construction entrance and erosion control measures only for individual lots to be disturbed.

(17) Steep slope stabilization methods when disturbance of steep slopes is permitted.

(18) Retaining walls with proposed elevations.

(19) For a corner lot the driveway entrance for a single-family dwelling shall be provided from the minor road.

(20) Landscaping requirements including size and type of trees.

(21) Signature and seal of a professional licensed to prepare the design by the Commonwealth of Virginia.

B. A grading plan shall include the appropriate notes and/or details for the necessary erosion and sediment control measures. The original erosion controls for a subdivision may be satisfactory for an addition to a subdivision as long as the erosion controls will not be removed until the construction on the lot is completed, the ground stabilized, or the release of the escrow is requested and approved.

C. Storm drainage system plans for pipes, inlets, etc. (which are approved as part of street construction plans) are based upon a storm drainage map showing the areas contributing to flow at various inlets. Overlot grading plans should delineate the drainage divide lines to insure that an approved drainage map is followed, or notation should be made on the plan that it conforms to the approved overall drainage plan.

D. On each residential building lot within a subdivision where the minimum required lot area is twenty thousand (20,000) square feet (1,858.06 square meters) or less, the subdivider shall install a yard light on each lot which conforms to the design standards of this manual (see Exhibit 21).

E. A block for approval with the following minimum information in the same order as it appears for lot grading plans submitted individually:

GPIN: _____
Zoning: _____
Address: _____
Owner: _____
Zoning Approved By: _____
Date: _____
Maximum Height 35'
Approved Lot Grading Only
Department of Public Works
By: _____
Date: _____

F. A block with the following minimum notes for lot grading plans submitted individually:

1. No inspection will be made unless an approved lot grading plan is on the job site.
2. The approval of this lot grading is for building permit application only as shown on the site development plan. Mass grading is not permitted unless building permits are obtained.

3. This lot grading plan is approved for:

Nonmanufactured dwelling(s) _____
Manufactured dwellings(s) _____

4. A note that sidewalks or trails must be in place prior to occupancy permit if the approved subdivision plans show them in the vicinity of this lot.
5. A note that a yard light must be in place prior to occupancy permit if such light is required.
6. A note to indicate if the lot grading plan is a revision of the original approved one.

7. A note to indicate if a proffer contribution is required prior to the issuance of any building permits.

720.00 STORM WATER MANAGEMENT (SWM) - POLICY

720.01 General Policy for SWM:

A. All development occurring within the County shall provide storm water management facilities and best management practices adequate to reduce increased runoff rates and nonpoint source pollution, respective to their predeveloped condition. The design shall include control of stream flow rates, water surface levels, and runoff volumes.

B. The County encourages the construction of regional SWM facilities as opposed to numerous on-site facilities where possible. Regional facilities are generally expected to have drainage areas of one hundred (100) acres (40.47 hectares) or larger and to be located as determined by watershed studies. The Department of Public Works maintains a list of watersheds that have completed watershed management plans. The County will cooperate in the preparation of studies in other watersheds.

Developers are encouraged to discuss with the Department of Public Works the possibility of participating in the construction of a regional SWM facility and to share in the benefits of larger facilities downstream. The Department of Public Works shall provide guidelines for the design, construction, and maintenance of such facilities.

The County's objectives for regional SWM facilities are as follows: (1) To encourage a regional approach to storm water detention, rather than numerous small and marginally effective individual on-site ponds; (2) To facilitate the implementation of the regional SWM ponds through the development process; and (3) To reduce the impact on the environment by encouraging the use of nonstructural BMPs, biofilters and sediment forebays. If a regional facility is under construction or funded and scheduled for construction, the properties within the service area of the facility shall be required to participate in the implementation of the regional pond and pay a pro rata share.

C. The Department of Public Works reserves the right to disapprove certain types of SWM and BMP systems for certain types of development, if there are documented concerns regarding the effectiveness or maintainability of these systems.

D. The Department of Public Works reserves the right to ask for a pro rata share contribution for certain sites, in lieu of providing onsite storm water management facilities, based on watershed conditions, as stated in Section 720.06.A. of this manual.

720.02 General Policy for BMP and Storm Water Quality:

A. All development or redevelopment occurring within the County shall incorporate water quality measures (best management practices). A minimum of twenty percent (20%) phosphorus removal shall be provided for redevelopment sites.

B. The current edition of the Northern Virginia BMP Handbook, prepared by the Northern Virginia Planning District Commission (NVPDC), shall be used in the design and review of BMP facilities.

720.03 Exemptions: Development exemptions from Prince William County SWM plan submission requirements (refer to Section 720.05 of this manual for waiver of BMP) are as follows:

A. Minor land disturbing activity involving less than five hundred (500) cubic yards (382.28 cubic meters) of earthwork and less than two thousand five hundred (2,500) square feet (232.26 square meters) of disturbed area, which is promptly stabilized to prevent erosion and sedimentation, not including creation of paved or other impervious surfaces.

B. Accepted agricultural and management practices permitted by the Zoning Ordinance and/or in accordance with an approved siltation and erosion control plan. Examples of such practices in an agricultural zoning district are plowing, nursery operations, such as the removal or transplanting of cultivated sod, shrubs, trees, and tree cutting at or above existing ground, and logging operations leaving the stump, ground cover and root intact.

C. Individual private septic systems which do not alter the natural terrain.

720.04 Waiver of SWM Requirements:

A. The director of Public Works shall consider granting a waiver of the requirements for on-site SWM in the following development categories:

(1) Detached single-family developments in accordance with Table 7-5.

(2) Multifamily residential development containing two (2) acres (0.81 hectare) or less.

(3) Industrial, institutional, and commercial development containing a total disturbed area of two-thirds (2/3) acre (2,699.28 square meters) or less with one-third (1/3) acre (1,349.64 square meters) or less of impervious area.

B. New development which is an addition, extension, and/or modification to development listed in the above categories which has been granted a prior waiver under this policy, and which exceeds the acreage limitations listed above by the subsequent addition, shall be required to provide SWM for the entire site (with due consideration being given to any monetary contribution).

C. Owners who have projects falling within these categories, who desire not to provide SWM for the site, shall request in writing that the requirements be waived (see Exhibit 10 for the sample form to be used for the written request).

D. The director of Public Works shall also consider granting a waiver for on-site detention facilities for developments not falling within the waiver categories previously listed under the following conditions, provided that the applicant has provided adequate justification for a waiver consideration:

(1) The hydraulic characteristics of the receiving stream or the environmental characteristics of the stream or the site are such that on-site management or detention of flows are contrary to sound engineering practices and detrimental to the environment.

(2) The increased amount or velocity of storm water generated by the development will have a minor detrimental effect on the receiving stream.

(3) An off-site SWM facility has been identified for construction in the capital improvements program, and the applicant agrees to a financial contribution or dedication of an easement or land for the construction thereof.

(4) Two or more developments (including that of the applicant) have provided for the management of storm water, jointly, through reciprocal easements or other means.

(5) Existing off-site SWM facilities provide the required control. In such cases, on-site SWM shall be exempt, provided that the delivery system from the developing site to the off-site SWM facility is adequately protected against erosion.

(6) Inadequate site availability for a suitable structure, or where the only feasible structure would entail unreasonable cost, as determined by the Department of Public Works.

E. The waiver application shall include technical documentation and computations necessary to support any of the above items. The director of Public Works shall consider granting a waiver for on-site detention facilities under the above-mentioned conditions upon submission of a written request. A sample waiver request form is shown in Exhibit 11.

F. Each waiver request shall be considered individually by the director of Public Works.

G. In reviewing the waiver application, storm drainage outfalls, receiving channels, channel capacities, velocities, and other related storm drainage discharge, considerations shall be closely examined to determine the need for additional outfall treatment and/or channel protection measures.

H. The applicant shall furnish the Department of Public Works a declaration of adequacy, prior to granting a waiver, when adequacy of the receiving storm drainage system is in question.

I. A monetary contribution shall be substituted when on-site SWM is waived. This contribution shall be computed in accordance with sections 720.07, 720.08 and 720.09 of this manual.

720.05 Waiver of BMP Requirements:

A. Maintenance, alteration, use, or improvement to an existing structure which does not degrade the quality of surface water discharge, as determined by the director of Public Works, may qualify for a waiver of the requirements of this subsection, provided that it complies with erosion and sediment control requirements of Section 750.00 of this manual.

B. The director of Public Works may also consider granting a waiver of BMP requirements for sites where the SWM requirements have been waived in accordance with Section 720.04 of this manual, provided that it does not result in the degradation of the quality of surface water discharge.

720.06 Pro Rata Share Contribution for SWM in General:

A. The Department of Public Works encourages the use of various methods of on-site storm water detention to minimize the adverse effects of increased runoff on upstream and downstream drainageways. Where the public interest is diminished, however, the director of Public Works reserves the right to deny on-site detention and require a financial contribution from the applicant. Conditions under which the director of Public Works might deny on-site detention could include, but not be limited to, the following:

(1) Proximity of a major waterway to which storm water could be adequately discharged.

(2) Proximity of an existing or proposed off-site facility that has adequate storage capacity for handling storm water flows.

(3) Indication from the hydrology and hydraulic model available to the Department of Public Works that detention will cause more harm than benefit.

B. An applicant may seek permission to either construct or provide the funds for the construction of more than the proportionate share of the downstream off-site drainage improvements in order to proceed with land improvements without damaging other properties.

C. The County shall attempt to collect (on a pro rata basis) excess funds expended beyond the proportionate share from other property owners within the watershed served by drainage improvements. Such properties shall be developed within a period of ten (10) years from the date that the drainage improvements are financed or constructed. These funds shall be released (without interest) to the initial developer or assigns.

720.07 Pro Rata Share Contribution for a Regional SWM Facility With Allocated Funds:

A. In watersheds where a major off-site detention facility is planned, and funds are allocated to the facility design, the applicant shall be required to pay a pro rata share of the cost of the facility, dedicate land, and/or provide easements to be used for the proposed facility, or for other improvements.

B. The Department of Public Works shall study and compute the total estimated cost of the ultimate SWM facilities required to serve a watershed, when and if such watershed is fully developed (in accordance with the adopted Comprehensive Plan). The computation of estimated costs shall include a watershed study and the total cost and design, construction, operation, maintenance, and land or easement acquisition. The total cost shall be updated annually by applying the Engineering News Record cost index factor to the construction costs.

C. The watershed studies and cost estimates mentioned in B above shall constitute the general drainage improvement program for the affected watershed.

D. A list of the watersheds where major off-site facilities are planned, and design funds allocated, shall be published and updated once adopted by the Board of County Supervisors.

E. An applicant may be required to contribute to necessary drainage facilities located outside the land owned or controlled by the applicant, but necessitated or required, at least in part, by the construction or improvement of the applicant's development. If a general drainage improvement program has been established, pro rata share shall be determined based on the total updated cost of the program.

720.08 Pro Rata Share Contribution for a Regional SWM Facility Without Allocated Funds:

A. In watersheds where the total improvement costs for a particular drainage project have not been calculated, and where monetary contribution in addition to (or in lieu of) on-site detention is allowed, the pro rata share shall not be determined by Table 7-6. The pro rata share shall not exceed the calculated cost required to provide full SWM in accordance with the applicable provisions of this manual.

B. The amount calculated from Table 7-6 shall not exceed the estimated construction cost for a SWM facility that will provide the full SWM requirements for a site. Construction quantity estimates, certified by a professional engineer or land surveyor, shall be submitted for the SWM facilities. The current Prince William County bond estimate price list shall be applied to the quantities to arrive at the calculated cost.

C. The required pro rata share contribution shall be paid prior to the issuance of site preparation, site development or early grading permits. Contributions not paid within six (6) months of the waiver approval shall be recalculated using the current ENR construction cost index.

720.09 Pro Rata Share Payments:

A. Payments received pursuant to this section shall be expended for the administrative costs, land acquisition, design, construction, operation, and maintenance of those drainage facilities for which payment was required. This contribution is nonrefundable.

B. The payment of the applicable pro rata share calculated in the manner described in sections 720.07, 720.08 and 720.09 of this manual shall be a condition of the issuance of any permits.

720.10 Maintenance Policy for SWM/BMP Facilities in General: The entity responsibility for the maintenance of storm water management and drainage facilities shall depend on the type of development containing these facilities as outlined in sections 720.11 through 720.14. In addition, the following policies apply:

A. When the storm drainage system is eligible for maintenance by the County, in accordance with this section, it shall be accepted only if it is bonded and inspected by County inspectors during construction.

B. The Department of Public Works shall maintain the SWM/BMP facilities and the storm drainage systems to prevent a potential safety hazard, a significant impediment to flow, danger of severe flooding, or erosion. Drainage facilities located within the public street right-of-way are the responsibility of VDOT.

C. The owner of the property on which there is located an easement for storm drainage or SWM purposes shall be responsible for the following items when applicable:

Grass mowing with reasonable frequency.

Removal of debris and other matter to the best of owner's ability, where such debris or matter has impeded or threatens to impede free flow of storm water.

To notify the Prince William County Department of Public Works of: (1) any defects with the structures, pipes, if applicable, and fencing within the easements; (2) any debris or other matter which is beyond the ability of the owner to remove; and (3) any excessive flooding, sedimentation or soil erosion within the area of the easement.

720.11 Residential Properties:

A. The County is responsible for the maintenance of all SWM/BMP, as well as other drainage facilities within the drainage easements, except wet ponds/lakes, in all residential properties.

B. For drainage facilities under privately owned roads, drives and parking areas, the County shall also be responsible for maintenance. However, the maintenance responsibilities exclude resurfacing, paving, and landscaping.

C. The County shall accept maintenance responsibilities of SWM/BMP and other facilities in existing developments (i.e., single-family attached subdivisions with plans approved prior to 1985), after the fee owner(s) have demonstrated that the facilities are operating according to approved plans and have properly dedicated easements. In cases where the plans are not available, or better technology is available, the property owner(s) have to demonstrate that the facility is properly operating.

D. For wet ponds, the County may accept certain maintenance items, such as inspections of dams and outlet structures, removal of debris, dredging activities, etc. The maintenance responsibility shall, however, be determined on a case-by-case basis. Landscaping and maintenance for aesthetics shall not be part of the County maintenance responsibilities.

720.12 Nonresidential Properties:

A. The County is responsible for maintenance of all (dry) detention ponds in nonresidential properties. However, the fee owner(s) shall demonstrate that the facilities are functioning according to approved plans and that the facility has properly dedicated easements, prior to the County assuming maintenance responsibilities. In cases where the plans are not available, or better technology is available, the property owner(s) have to demonstrate that the facility is properly operating.

B. For wet ponds, the County may accept certain maintenance items, such as inspection of dams and outlet structures, removal of debris, dredging activities, etc. The maintenance responsibility shall, however, be determined on a case-by-case-case basis. Landscaping and maintenance for aesthetics shall not be part of the County maintenance.

C. The County will not accept maintenance of any underground SWM/BMP facilities. Fee owners are responsible for the maintenance of underground SWM/BMP facilities, and all other types of facilities not described above.

720.13 Apartment Rental Complexes and Mobile Homes: Apartment rental complexes and mobile home developments shall be considered as nonresidential properties for maintenance purposes.

720.14 Regional Facilities in Residential and Nonresidential Properties: The County shall be responsible for the maintenance of all public regional BMP/SWM facilities, except for aesthetic items, such as fountains, landscaping, etc.

720.15 Maintenance Agreements for Owner-maintained SWM/BMP Facilities:

A. Prior to the issuance of site development permits, owners of developments with SWM facilities, which will not be maintained by the County, shall be required to execute a SWM maintenance agreement (see Exhibit 2 of this manual). This agreement is designed to give the County authority to maintain or reconstruct any SWM facility, and to assure its long term operational and functional effectiveness. This agreement shall be recorded with the plat for the property. No modifications to this agreement can be made without the approval of the Department of Public Works and the property owner.

B. Owner maintained facilities shall require the landowner, successors and assigns, to provide/arrange annual inspections of the SWM/BMP facilities. This inspection shall be performed by a certified professional engineer familiar with the design and operation of SWM/BMP facilities.

C. The inspecting engineer shall provide a report addressing the maintenance needs of the facility in accordance with this section. The inspection report shall include the observations, measurements, or tests which were performed, and the schedule for repairs when needed.

D. Certified inspection reports shall be forwarded to the Department of Public Works before June 30 of each year. The Department of Public Works shall review reports and comment on the inspector's conclusions, and may perform inspections or maintenance as necessary. The Department of Public Works may require additional maintenance which shall be completed within thirty (30) days of notification. If the Department of Public Works performs maintenance, the owner may be responsible for the costs incurred from the maintenance operation.

E. The repairs and reconstruction of the SWM/BMP facilities should be performed under the direction of registered professionals.

720.16 County Maintained SWM/BMP Facilities:

A. County maintained SWM/BMP facilities shall be inspected and maintained by the Department of Public Works. Easements shall be dedicated to public use during the land development process. Drainage easements are required for the maintenance of storm sewer systems, open channels as defined by the Virginia Erosion and Sediment Control Handbook, improved drainageways of increased concentrated runoff, and for facilities where required by this section.

B. Access easements and driveways are necessary for emergency public access to maintain a drainageway or a storm drainage system located on private property. Furthermore, drainage easements are intended to restrict disturbance of land in the easement which would detrimentally alter the drainageway.

C. Prior to the County performing maintenance or repair on SWM/BMP and drainage facilities, the property owner will be required to enter into an agreement with the County which will hold harmless the County and its agents and employees for any and all damages, accidents, casualties, occurrences or claims which might arise or be asserted against the County for the repair or maintenance of the SWM/BMP or drainage facilities.

721.00 SWM/BMP FACILITIES - PLANNING AND DESIGN

721.01 Facilities Design in General:

A. Storm water management (SWM) addresses the quantity of runoff while best management practices (BMP) addresses the quality of runoff. While there are differences between performance criteria, the two management strategies will often be employed within the same structure or facility. Standards which apply to one set of performance criteria shall not lessen the performance criteria for the other.

B. If both SWM and BMP are provided within the same facility, the final design shall ensure that the performance criteria and maintenance are compatible. Reference to SWM may also imply BMP (but not necessarily).

C. An acceptable SWM plan can be obtained by the following measures:

(1) Providing the necessary facilities within the project area.

(2) Entering into a joint effort with other developers to provide multisite facilities.

(3) Entering into an agreement with the County, subject to prior approval by the Department of Public Works for a financial contribution for off-site SWM. Such contributions shall be held by the County and used only for SWM facilities within the major drainage basin wherein the developer's project is located. The County may choose to construct such facilities, or may use the contributions to reimburse developers who provide SWM facilities in excess of their own needs.

(4) Granting an easement or dedicating land for a larger SWM facility, subject to prior approval by the Department of Public Works, in lieu of the required on-site SWM.

(5) When the County determines that additional storage capacity (beyond that required by the applicant for on-site SWM) is necessary, it may acquire from the applicant or owner, by purchase or dedication, additional land as may be necessary, and/or participate financially in the construction of the SWM facility to the extent that it exceeds the required on-site SWM.

(6) Participation in a regional SWM facility.

721.02 Design Criteria for SWM/BMP Facilities:

A. Peak flows and rainfall frequencies and durations shall be determined using the provisions of this subsection.

B. The ten (10) year storm shall be used in determining predeveloped flow, except in critical watershed areas (see E. below). The twenty-four (24) hour SCS Type II rainfall distribution shall be used. SWM facilities shall be designed to regulate the two (2) and ten (10) year storm such that the postdevelopment peak flows do not exceed predevelopment peak flows.

C. A ten (10) year storm shall be used in determining the developed flow, except in critical watershed areas. If the rational method is used, five (5) or ten (10) minute increments of this storm shall be computed and compared to the predeveloped runoff to determine the amount of storage required (see Exhibit 13). In cases where there is no significant difference between pre and postdevelopment discharges, the designer should determine if a SWM facility is beneficial for the watershed. A pro rata share may be substituted upon approval by the director of Public Works.

D. The control structures of SWM ponds shall be designed and located such that they reduce the ten (10) year postdevelopment flows for the entire watershed at the point of location by at least twenty percent (20%).

E. SWM facilities located upstream of existing or future (in accordance with the Comprehensive Plan) residential areas with required minimum lot sizes less than one (1) acre (0.4047 hectare) shall be designed to regulate the peak discharge from the two (2) and ten (10) year storm.

F. SWM facilities shall be designed to regulate the peak discharge from the two (2), ten (10), and one hundred (100) year storms, if located upstream of existing residential developments with required minimum lot sizes less than one (1) acre (0.4047 hectare) and located adjacent to special flood hazard areas, as delineated in the County's FIRM.

G. In critical watershed areas, in addition to the two (2) year and ten (10) year storms, SWM facilities must also be designed to regulate postdevelopment flows to the predevelopment levels for the twenty-five (25) year storm events. A list of critical watersheds shall be maintained by the Department of Public Works. Monetary contribution, in addition to providing storage for the ten (10) year storm, may be allowed by the director of Public Works, in lieu of regulating the twenty-five (25) year storm. Requests for such substitutions must be made in writing.

H. The effect of the one hundred (100) year storm must be considered in the design of all SWM facilities unless, due to the height of the dam and the capacity of the impoundment, smaller frequency storms have to be considered during the design. Emergency spillways and ponds shall be designed to pass the one hundred (100) year storm, with the assumption that the principal outlet structure is inoperative. Dam design shall be performed in conformance with Section 708.04 of this manual.

I. The use of anti-vortex devices and trash racks shall be included in the design of the principal spillway. Possible flotation of the outlet devices and structures shall also be considered.

J. Pollution loads shall be determined by calculation methods set forth in the Northern Virginia BMP Handbook. Where required, BMP facilities shall be designed to reduce projected phosphorus runoff resulting from site development by at least fifty percent (50%). Phosphorus removal efficiencies for the different types of BMP systems are included in the Northern Virginia BMP Handbook. Where a method or facility without an efficiency rating is proposed, the designer shall be required to adequately substantiate the ratings before the design is approved.

K. Concrete trickle ditches shall not be allowed in SWM facilities, unless a continuous low flow exists.

L. The following methods are considered acceptable to achieve the pollution load objectives of this section:

(1) Structural measures that store storm water and rely upon solid settling processes to remove pollutants. Minor modifications could practically convert a storm water detention facility to a multipurpose facility, satisfying both water quality and quantity needs. Extended detention ponds and wet ponds are examples of acceptable structural measures.

(2) Volume control BMP, such as porous pavement, sand filters, modular pavement, and infiltration pits or trenches (when the soil permeability allows) or nonstructural BMPs such as bioretention practices, vegetated swales, etc.

(3) Entering into a joint agreement with other developers to provide appropriate multisite facilities.

(4) Entering into an agreement with the County, subject to prior approval by the director of Public Works, which provides for a financial contribution for off-site SWM and BMP. Such contributions shall be held by the County and used only for SWM and BMP facilities within the major drainage basin where the developer's project is located. The County may construct such facilities, or use the contributions to reimburse developers who provide SWM facilities in excess of their own needs.

(5) Restoring a minimum of twenty percent (20%) of the site to vegetated open space on a redevelopment site that is completely impervious as currently developed.

(6) Preservation of existing or woodland vegetation in conjunction with minimizing impervious cover.

(a) In accordance with the CBPA designation and management regulations (VR-173-02-01), the one hundred (100) foot (30.48 meters) buffer area achieves a seventy-five percent (75%) reduction of sediments and a forty percent (40%) reduction of nutrients. To achieve this effectiveness, the method of flow over and through the buffer shall be generally sheet flow that promotes sedimentation and nutrient uptake. A large drainage area resulting in high volumes or velocities flowing through a concentrated swale cannot have this effectiveness as research has indicated that concentrated flows are not treated effectively in natural open spaces.

(b) Large lot residential subdivisions with five (5) acre (2.02 hectare) lots are considered to meet this criteria.

M. For redevelopment incorporating an existing BMP, an engineer shall certify that the facility is in good working order and performing at the necessary level of service. Maintenance records may be necessary to verify that the facility has been operating correctly.

N. Underground structures detaining flows and not providing inground percolation or not documented to reduce pollution loads shall not be allowed.

O. Concrete shall be used for outlet pipes and structures. Outflows from a BMP facility shall be regulated by either a bolted-on plate or a lockable gate valve. Outlet structures shall be designed so that the downstream side of the BMP orifices are accessible when ponds are at the flooding stage. BMP plates shall have only one hole unless holes are three (3) inches (75 millimeters) in diameter or greater and shall be made of rustproof material or rendered rustproof.

P. Storm water outfalls should be located at a distance equal to or greater than two-thirds (2/3) the maximum dimension of the pond (length or width) from the outlet structure. The two (2) year and ten (10) year storm should be used in determining the pond's dimensions. Baffles may be used to increase the effective distance between inlets and outlets.

Q. Wet pond designs shall include specific provisions to permit dredging of sediment. Possible provisions would include gates to permit complete dewatering, sediment forebays (with sediment dewatering within easy reach of drag line or other designated equipment), and sediment dewatering beds, designed to permit hydraulic dredging. Sediment dewatering areas should be adjacent to the facility, drain into the facility, and be protected by an easement.

R. For infiltration trenches/pits that receive surface flow, sheet flow across a grass filter strip shall be used. This grass filter strip shall be fifteen (15) feet (4.57 meters) wide and included within the easement.

S. For infiltration trenches that receive runoff through a pipe, pretreatment devices for the removal of oil, sand and gravel shall be approved. The use of oil and grit separators as primary BMPs or pretreatment facilities is not acceptable.

T. Infiltration trenches shall have monitoring wells or other equally accurate means to measure the need for renewal of the stone. Such devices shall be provided at the rate of one (1) per each two hundred (200) cubic yards (152.91 cubic meters) of stone. The design computation shall identify specific measurements which indicate when renewal of the stone is required, and these measurements shall be included in the maintenance agreement.

U. Institutional developments shall be defined as: churches, cemeteries, rescue squads, fire departments, hospitals, libraries, schools, day care centers, nursing convalescence homes, and recreational facilities and their related building and parking lots.

V. All parking lots, as conventionally constructed, shall be considered impervious and therefore included in the impervious area considerations. Specially designed treatments with proven results and accompanying supportive documentation may be considered.

W. Resurfacing a previously approved or legally nonconforming impervious area shall not require SWM or BMP, nor shall it be included in the impervious area calculation.

X. Impervious area calculations for buildings shall include overhanging projections such as eaves, canopies, and porticos.

721.03 Location of SWM/BMP Facilities:

- A. Above ground SWM and BMP facilities shall be located in conformance with the applicable sections of the Zoning Ordinance.
- B. In general, SWM and BMP facilities shall be set back at least fifty (50) feet (15.24 meters) from a dwelling unit. Likewise, a dwelling unit shall be set back at least fifty (50) feet (15.24 meters) from a SWM and BMP facility.
- C. Unless authorized by the Zoning Ordinance, SWM and BMP facilities shall not be located in required buffer areas. They shall be set back from property lines a distance equal to the minimum width of the applicable required buffer yard established in Section 800.00 of this manual or setback established in the applicable zoning district or ten (10) feet (3.05 meters), whichever distance is greater.
- D. Notwithstanding the provisions of the preceding paragraph, a SWM and BMP facility in nonresidential districts shall not be located within thirty (30) feet (9.14 meters) of a property line along which a buffer zone is required.
- E. In agricultural districts and in single-family and single-family attached developments, SWM and BMP facilities shall be located within easements in lots which will be conveyed to and maintained by a homeowners' association. In the absence of a homeowners' association, SWM and BMP facilities may be located in individual lots, provided that the minimum lot area required is met outside the area devoted to the SWM and BMP facilities and floodplains. The area devoted to storm drainage systems (including SWM and BMP) shall not exceed twenty percent (20%) of the total area of the lot.
- F. SWM and BMP facilities shall not be located within individual single-family attached lots.
- G. Nonregional SWM facilities shall not be located within identified special flood hazard areas delineated in the County's FIRM.
- H. SWM and BMP setback areas shall be stabilized and landscaped, provided access easements remain clear in accordance with Section 800 of this manual. All measured distances of setbacks mentioned above shall be to the one hundred (100) year floodplain.

721.04 Easements for SWM/BMP Facilities:

- A. An easement around the SWM/BMP facility shall be required.
- B. SWM and BMP facility easements shall be provided to adequately contain the one hundred (100) year ponding level (plus required freeboard), embankment, outlet structures, and an appropriate width of maintenance area around the one hundred (100) year ponding area that permits access to the dam, outlet structures, and embankment.

C. For infiltration trenches and other underground systems, the easement shall include a ten (10) foot (3.05 meters) wide strip outside the edges of the structure. This width will be increased one (1) foot (300 millimeters) for each foot that the depth of structure exceeds six (6) feet (1.83 meters).

D. The easement shall include a space to stockpile material which would be excavated during reconstruction or maintenance of the facility. If the stockpile area cannot be accommodated within the SWM easement, then an equally accessible area outside of the easement shall be provided.

E. Easement for pipes used as SWM and BMP facilities shall be provided in a manner similar to that described in Section 702.10 of this manual.

721.05 Access to SWM/BMP Facilities:

A. Access to a SWM/BMP facilities shall be within an easement of not less than twenty (20) feet (6.10 meters) in width and shall not exceed a grade of twenty percent (20%). If the grade exceeds ten percent (10%), the travelway shall be built in accordance with Category I pavement design. A curb cut from the road shall be provided.

B. The access easement and a minimum ten (10) foot (3.05 meters) travelway shall not have obstacles, vegetation, cross slopes, or grades which would prevent easy access by a four-wheel drive light truck onto the embankment and to the BMP or other outlet structures within the impoundment areas. The travelway shall have a minimum of six (6) inch (150 millimeters) VDOT 21A stone. A turnaround at the end of the travelway shall be provided if the length exceeds one hundred fifty (150) feet (45.72 meters).

C. The access travelways to SWM facilities shall be built prior to the issuance of building permits for residential lots abutting the access easements.

D. The site development plans should consider the provision of adequate access to open space areas surrounding watercourses to allow equipment to maintain the area and watercourse, and any sanitary sewer or utility lines therein. The access should also relate to prospective recreational and park uses. Pedestrian crossings of streams may also be desirable in some instances.

721.06 Protection of SWM/BMP Facilities:

A. The Department of Public Works shall require protective devices and warning signs in conjunction with SWM and BMP facilities. Protective devices shall be in the form of one of the following:

(1) Four (4) foot (1.22 meters) high chain link fence or approved equivalent with gate, in accordance with VDOT road and bridge standards.

(2) Gradual slopes no steeper than ten to one (10:1) in the inner perimeter of the facility and a shallow water depth for a minimum horizontal distance of twenty (20) feet (6.10 meters) measured from the ten (10) year ponding elevation.

(3) Alternate means of protection as approved by the director of Public Works.

B. Permanent fencing, when required, shall be installed with a fifteen (15) foot (4.57 meters) wide gate where the access road enters the facility. Fencing shall be installed around the easement in such a manner to minimize obstruction of the emergency spillway. Adequate access must be provided within the facility for maintenance. Wet ponds shall not require fencing.

C. Ponds in industrial or business parks remotely located from residential development and the public, shall not require fencing. Wet ponds must have aquatic benches along the entire shoreline, except portions having slopes of ten to one (10:1) or flatter to a two (2) foot (600 millimeters) depth of water.

D. Warning signs shall be posted at SWM and BMP facilities within residential developments and commercial or industrial developments which are close to residential communities. These signs shall be in accordance with Exhibit 19 and 20 of this manual and are available from the sign shop.

721.07 Dams:

A. Items to be considered in the design of dams should include, but not necessarily be limited to, the following:

(1) Embankment: Type of material, placement of material, compaction, permeability of material, settlement vegetative cover, cross-section shape, stability, site geology, deformation and foundation contact conditions. Any design and stabilization recommended by the geotechnical engineer shall be shown on the plans. No other utilities shall be located within the SWM facilities and embankment areas. In addition, no trees shall be planted within the embankment area.

(2) Seepage Considerations: Placement of impervious material or zoning of embankment materials, foundation material, cut-off trench, drains and anti-seep collars, drainage blankets, and internal drains, differential settlement, local ground water condition and foundation underseepage.

(3) Riser and Culvert: Materials, joint connections, trash control, clogging, anti-vortex device, structural strength and stability, flotation, lake drawdown device, and differential settlement. Trash racks shall extend a minimum of one (1) foot (0.3048 meters) beyond all sides of the riser structure.

(4) Hydrology and Hydraulics: Ultimate upstream land use, freeboard, erosive velocities, water surface fluctuation, storage capacity, spillway capacity, staff gage, and storm durations and distributions.

(5) Downstream Area: Existing development, existing zoning, ultimate land use, dam failure and analysis, and determination of inundated area with and without dam.

(6) Maintenance: Vehicular access, safety of dam and appurtenances.

B. Any proposals for the construction of dams to form dry and wet ponds or lakes shall be fully supported by detailed engineering plans and calculations and shall generally include the following:

(1) Inflow and outflow hydrographs for the two (2) year, ten (10) year, and one hundred (100) year floods, and principal spillway hydrograph, emergency spillway, and freeboard hydrograph.

(2) Design calculations and details for the principal spillway, emergency spillway, and outlet works. Outlet analysis shall be provided in accordance with Section 701.02 of this manual.

(3) Depth (elevation) versus volume of storage curve and depth (elevation) versus outflow curve. All formulas and assumptions used to develop these curves shall be included.

(4) Emergency spillway design calculations for ponds with storage in excess of two (2) acre-feet (2,467 cubic meters) shall include a free board safety factor in accordance with practices set forth in the National Engineering Handbook, Chapter 4, of the SCS. When the riser is used as the emergency spillway, the two (2) and ten (10) year flows must be controlled with a separate orifice or weir. A minimum of one (1) foot (0.31 meters) of freeboard from the one hundred (100) year ponding limits to the top of embankment shall be provided.

(5) Embankment design computations, including seepage control, slope protection, freeboard calculations, and stability analysis.

(6) Calculations or effects (if any) on established floodplain boundaries.

(7) Description of the operation and maintenance plan for the facility, including an inspection schedule. The maintenance plan shall also include sediment deposition computations.

C. A dam break analysis shall be required for wet ponds with a dam height of fifteen (15) feet (4.57 meters) or greater and an impoundment capacity of twenty-five (25) acre-feet (30,860 cubic meters) or greater.

D. Water quality impact assessment as may be required by Section 742.04 of this manual. For any impoundment, the design procedures, manuals, and criteria used by the United States Army Corps of Engineers, SCS, the Water and Power Resources Services (formerly the Bureau of Reclamation), the National Weather Service, and the Virginia Department of Conservation and Historic Resources may be used. In addition, other recognized design methods may be used with approval of the Department of Public Works.

E. Soil structures and characteristics shall be investigated. Plans, data and subsurface investigations conducted by a professional engineer, qualified as an expert in geotechnical engineering, shall be submitted with the plans. These submissions should consider and offer design solutions for frost heave potential, shrink-swell potential, soil bearing strength, water infiltration, soil settling characteristics, fill and backfilling procedures, and soil treatment techniques as required to protect the improvements or structures.

721.08 Sedimentation and Debris Basins:

A. In some locations, as may be allowed by Section 740.00 of this manual, sedimentation basins or debris barriers may be situated in the watercourses for the control of silt or debris while upstream construction is taking place.

B. The planning of these basins should include consideration of the necessity to remove these basins, and the trapped materials, when the construction process is completed. The effects of these facilities on the surrounding environment shall also be considered (i.e., the deposition of silt over root systems, the preservation of existing woodland, etc.).

C. Sedimentation basins are not normally acceptable as permanent facilities due to maintenance problems and the long term desirability of eliminating erosion, rather than merely trapping a percentage of the eroded material.

D. The installation of permanent debris barriers (designs may be found in BPR publication, Hydraulic Engineering Circular No. 9) may be desirable in particular instances. The desirability of permanent debris barriers shall be assessed on an individual basis.

E. Permanent debris barriers, if approved, should be in a location accessible to heavy equipment and trucks and would primarily be for the purpose of trapping large debris such as dead tree limbs before such material could float downstream to block a culvert system. Location of such debris barriers should include consideration of flood water levels that could occur if the barrier had trapped a considerable amount of such debris.

F. A final step in the construction process should include the removal of any debris, rubbish, trash and waste construction material in a similar manner to that done for other portions of the development.

722.00 SWM/BMP - SUBMISSION REQUIREMENTS

722.01 General Requirements:

A. An application for a final plan of subdivision shall not be approved unless it includes the manner in which erosion, sediment, pollutant loading, and storm water resulting from the development will be controlled, managed, or waived. This plan shall indicate whether storm water or BMP shall be managed on-site or off-site, the location design criteria of facilities, and type of management proposed.

B. A building permit shall not be issued for a parcel or lot until a SWM and BMP plan, or waiver thereof (for the plat or parcel), shall have been approved by the Department of Public Works as meeting applicable requirements.

C. A SWM and BMP plan shall be provided as a part of every site development plan submission, unless a waiver of the requirements of the policy is approved by the director of Public Works, in accordance with provisions of sections 720.04 and 720.05 of this manual.

D. Final SWM and BMP plans shall be submitted with final site development plans. They shall be subject to the applicable review and notification procedures and time schedules presented in the Administrative Procedures Manual.

722.02 Plan Elements: The following information shall be included in the final SWM and BMP plans:

A. Information provided in the preliminary plan with required changes. This usually includes a description of the approach proposed to manage storm water in the site.

B. Calculations, assumptions, and criteria used in the design of the storm drainage system and SWM facilities. This includes, but is not limited to, time of concentration, time of concentration flow paths, runoff curve numbers, soil types, runoff coefficients, etc.

C. Plans and profiles of proposed storm drainage systems and open channels, including horizontal and vertical controls, elevations, sizes, slopes, and materials.

D. Locations, dimensions, and design details required for the construction of facilities, including details for installation of trash rack and antivortex devices on riser pipes.

E. Drainage area maps, soil maps, and land use maps.

F. Inflow and outflow hydrographs generated by the design storms for pre and postdeveloped conditions.

G. Depth (elevation) versus volume of storage curve and depth (elevation) versus outflow curve, including formulas and assumptions used to develop these curves.

H. Contours that adequately describe the final topography.

I. Project specifications for erosion and sedimentation control (refer to Section 750.00).

J. Deed restrictions, easements, and rights-of-way.

K. Description of the operation and maintenance needs for SWM and BMP facilities, including a schedule of sediment removal and/or control. A maintenance agreement, as described in sections 722.04 and 722.05 of this manual, stating the ownership and maintenance responsibilities for SWM and BMP control structures, both during and after development. The identity of the responsible individual, corporation, association, or other specific entity, including the specific maintenance outlined on the plan and plat.

L. SWM fact sheet (See Exhibit 15).

M. Depth to severest high water table or peaked water table. Percolation tests and calculations for gravel trenches or pits proposed to incorporate infiltration into soil. The Department of Public Works reserves the right to require additional calculations or information which may be necessary to evaluate the design of the facility.

722.03 Modification of Approved Plans: Modification of an approved SWM/BMP plan involving a change in control methods or techniques, the relocation or redesign of control measures, or where soil or other conditions are not as stated on the approved application, shall be approved under the procedures contained in the Administrative Procedures Manual. The Department of Public Works shall notify the applicant when such plan modification is required.

722.04 Maintenance Notes for Residential Properties (Not Including Apartments and Mobile Home Parks) Where SWM, BMP and Storm Drainage Systems Qualify for County Maintenance:

The record plats and plans shall contain the following notes for facilities and systems that are eligible for County maintenance:

"The County shall maintain drainage, storm water management, and best management practices facilities and systems to ensure that they function properly. The County shall not be responsible for repaving or resurfacing paved areas or maintaining landscaping within easements. The fee title owner shall be responsible for grass mowing with reasonable frequency, if applicable, and for the removal of debris and other matter that has impeded or threatens to impede the free flow of storm water.

The fee title owner shall notify the Department of Public Works of any defects with the structures, pipes and fencing within the easement, of any debris or other matter which is beyond the ability of the owner to remove, and of any excessive flooding, sedimentation or soil erosion within the area of easement."

722.05 Maintenance Notes for Nonresidential Properties (Including Apartments and Mobile Home Parks) Where the SWM, BMP and Storm Drainage Systems Do Not Qualify for County Maintenance:

The record plats and plans shall contain the following notes for facilities and systems that are not eligible for County maintenance:

"The fee title owner shall be responsible for the maintenance of all drainage, storm water management, and best management practices facilities and systems in accordance with the maintenance agreement to ensure that they function properly.

Subject to other limitations, the fee title owner may landscape the easement to include vegetation, signs and fences, provided that drainage and the County's or the owner's ability to access the easement is not compromised and that the County is not in any way responsible for the repairs of these landscape items even if damaged by County forces."

722.06 Maintenance Notes for Nonresidential Properties (Including Apartments and Mobile Home Parks) Where the SWM and BMP Systems Qualify for County Maintenance but All Other Storm Drainage Systems are Maintained by the Fee Title Owner:

"The fee title owner shall be responsible for the maintenance of all storm drainage systems, except the storm water management and best management practices pond(s) to ensure that they function properly.

The County shall maintain storm water management and best management practices pond(s) to ensure that they function properly. The County shall not be responsible for repaving or resurfacing paved areas or for maintaining landscaping within easements.

The fee title owner shall be responsible for grass mowing with reasonable frequency, if applicable, and for the removal of debris and other matter that has impeded or threatens to impede the free flow of storm water. The fee title owner shall notify the Department of Public Works of any defects with the structures, pipes, and fencing within the easement, of any debris or other matter which is beyond the ability of the owner to remove, and of any excessive flooding sedimentation or soil erosion within the area of easement.

Subject to other limitations, the fee title owner may landscape the easements to include vegetation, signs, and fences, provided that drainage and the County's or the owner's ability to access the easement is not compromised and that the County is not in any way responsible for the repairs to these landscape items, even if damaged by County forces."

730.00 FLOODPLAIN MANAGEMENT - POLICY

730.01 General Policy:

A. Whenever the balance established by nature between a watershed and its naturally stabilized drainageways is disturbed by development, some corrective measures shall be taken to restore the balance and to avoid downstream flooding and damage. The need for corrective measures does not preempt any requirements established in Section 740.00 or elsewhere in this manual.

B. Persons wishing to construct or repair bridges, culverts, embankments, channelizations, dams, reservoirs, and small ponds must obtain any necessary permits or certificates from the federal or state agencies regulating these types of activities in the County's waterways.

C. Permits or certificates obtained from federal or state agencies do not obviate the need to submit the required information and plans to the Office of Planning for distribution to other County agencies, and for review and approval of this information and plans. The agencies that are often involved with or regulate construction on waterways are the U.S. Army Corps of Engineers, the Federal Emergency Management Agency, the Virginia Marine Resources Commission, the Division of Soil and Water Conservation of the Virginia Department of Conservation and Recreation, and the Department of Environmental Quality (DEQ). It is the responsibility of the property owner to initiate and obtain the necessary Federal Emergency Management Agency flood insurance map revisions or amendments if floodplain modifications occur in areas identified as special flood hazard areas (A and AE) in the FIRM. Copies of correspondence with these agencies regarding the project shall be provided.

D. All provisions of this subsection shall apply unless waived by the director of Public Works. Waivers shall be evaluated in accordance with Section 730.06.

730.02 Definitions: The following words and terms used in this subsection of the manual have the following meanings, unless the context clearly indicates otherwise:

A. Base Flood One Hundred Year Flood/Regulatory Flood - A flood that, on the average, is likely to occur once every one hundred (100) years (i.e., that has a one percent (1%) chance of occurring each year, although the flood may occur in any year).

B. Base Flood Elevation (BFE) - The Federal Emergency Management Agency designated one hundred (100) year water surface elevation.

C. Basement - Any area of the building having its floor subgrade (below ground level) on all sides.

D. Development - Any man-made change to improved or unimproved real estate including, but not limited to, buildings or other structures, mining, dredging, filling, grading, paving, excavation or drilling operations or storage of equipment or materials.

E. Floodplain - Any land area that would be inundated by floodwater as a result of the regulatory flood.

F. Floodway - The channel of a river or other watercourse and the adjacent land areas that must be reserved in order to discharge the base or regulatory flood without cumulatively increasing the water surface elevation more than a designated height.

G. Freeboard - A factor of safety, usually expressed in feet or meters, above a flood level for purposes of floodplain management.

H. Lowest Floor - The lowest floor of the lowest enclosed area (including basement).

I. Recreational Vehicle - A vehicle which is (a) built on a single chassis; (b) four hundred (400) square feet (37.2 square meters) or less when measured at the largest horizontal projection; (c) designated to be self-propelled or permanently towable by a light duty truck; and (d) designed primarily not for use as a permanent dwelling but as temporary living quarters for recreational camping, travel, or seasonal use.

J. Substantial Damage - Damage of any origin sustained by a structure whereby the cost of restoring the structure to its before-damaged condition would equal or exceed fifty percent (50%) of the market value of the structure before the damage occurred.

K. Substantial Improvement - Any reconstruction, rehabilitation, addition, or other improvement of a structure, the cost of which equals or exceeds fifty percent (50%) of the market value of the structure before the start of construction of the improvement. This term includes structures which have incurred substantial damage, regardless of the actual repair work performed. The term does not, however, include either (1) any project for improvement of a structure to correct existing violations of state or local health, sanitary, or safety code specifications which have been identified by the local code enforcement official and which are the minimum necessary to assure safe living conditions, or (2) any alteration of a historic structure, provided that the alteration will not preclude the structure's continued designation as a historic structure.

730.03 Floodplain Studies:

A. Floodplain studies shall be required whenever the drainage area is greater than one hundred (100) acres (40.47 hectares).

B. Drainage studies may be required with a drainage area greater than forty (40) acres (16.19 hectares), but less than one hundred (100) acres (40.47 hectares), if there are building lots proposed adjacent to the stream, and the development is located in a high density area.

C. Minor drainage studies may only be required with a drainage area less than forty (40) acres (16.19 hectares) if there are lots proposed adjacent to the stream on which the proposed building site is less than ten (10) feet (3.05 meters) above flow line of the stream. In lieu of a drainage study, a flood hazard area may be shown on the plan, coinciding as a minimum, with the contour which is ten (10) feet (3.05 meters) above the flow line of the stream. No permanent construction shall be permitted within this flood hazard area.

D. In addition to determining the one hundred (100) year floodplain, the Department of Public Works may require calculation of a floodway for drainage areas of one square mile (259 hectare) or larger.

E. The areas as established by the floodplain studies above shall be identified with boundary lines with bearings and distances and identified as a flood hazard area.

730.04 Platting Lots Within the One Hundred (100) Year Floodplain:

A. In planned residential districts, other zoning districts where the required lot area is ten thousand (10,000) square feet (930 square meters) or less and cluster developments, no individual lot or part thereof shall be platted within the one hundred (100) year floodplain.

B. In all residential zones (other than those listed in A. above), lots may be platted within the one hundred (100) year floodplain provided that:

(1) For lots where the minimum required area is up to five (5) acres (2.02 hectares), the minimum lot area required by the particular zone, or one acre, whichever is less, shall be located outside the limits of the one hundred (100) year floodplain; or

(2) For lots where the minimum required area is greater than five (5) acres (2.02 hectares), a minimum of two (2) acres (0.81 hectare) shall be located outside the limits of the one hundred (100) year floodplain.

Additional lot restrictions may be imposed by Section 740.00 of this manual.

730.05 Trees:

A. Consistent with Section 740.00 of this manual, trees within floodplain areas which are dead or obviously dying may be selectively removed during the construction phase.

B. Any trees which would be adversely affected by construction activities, so that they would die later, may be considered for selective removal and replacement.

C. Some selective removal of undergrowth vegetation may be allowed for the development of recreational trails, sanitary sewer construction, etc.

D. Clearing for a sanitary sewer line or other utilities to provide for future access for maintenance or for a walking trail shall be properly stabilized.

730.06 Waivers:

A. In reviewing waivers for activities in the flood hazard overlay district, the director of Public Works shall consider the following factors:

(1) The relative danger to life and property due to increased flood heights or velocities caused by encroachments.

(2) The relative danger that materials may be swept onto other lands or downstream to the injury of others.

(3) The degree to which the proposed water supply and sanitation systems are able to prevent disease, contamination and unsanitary conditions.

(4) The degree to which the proposed facility and its contents is susceptible to flood damage and the effect of such damage on the individual owners.

(5) The degree to which the proposed facility provides public service.

(6) The need that facility has for a waterfront location.

(7) The availability of alternative locations within the flood hazard area for the proposed use.

(8) The extent to which the proposed use is compatible with development and development anticipated in the foreseeable future.

(9) The extent to which the proposed use is compatible with the Comprehensive Plan.

(10) The extent to which the property is safely accessible in time of flood.

(11) The expected height, velocity, duration, rate of rise and sediment transport of the flood waters expected at the site.

(12) The repair or rehabilitation of historic structures upon determination that the proposed repair or rehabilitation will not preclude the structure's continued designation as a historic structure and the waiver is the minimum necessary to preserve the historic character and design of the structure.

(13) Such other factors which are relevant to the purpose of this section of the manual.

B. Waivers shall be issued only after the director of Public Works has determined that the granting of such will not result in (a) unacceptable or prohibited increases in flood height, as identified in Section 731.01(A), (B) and 731.04(B); (b) additional threats to public safety; (c) extraordinary public expense; (d) and will not create nuisances; (e) cause fraud or victimization of the public; or (f) conflict with local laws or ordinances. Waivers will be issued only after the director of Public Works has determined that variances will be the minimum required to provide

relief from any hardship to the applicant. The director shall notify the applicant for a waiver, in writing, that the issuance of a waiver to construct a structure below the one hundred (100) year flood elevation (a) increases the risks to life and property, and (b) will result in increased premium rates for flood insurance.

C. A record shall be maintained of the above notification as well as all waiver actions, including justification for the issuance of the waivers. Any waivers which are issued shall be noted in the annual or biennial report submitted to the federal insurance administrator.

730.07 Nonconforming Use Policy: A structure or the use of a structure or premises which was lawful before September 23, 1975, or the date of adoption of an applicant amendment to this article, but which is not in conformity with the provisions of this article, may be continued subject to the following conditions:

A. No structural alterations, additions, or repairs of any nonconforming structure shall exceed fifty percent (50%) of its value at the time of its becoming a nonconforming use, unless the structure is permanently changed to a conforming use.

B. If a nonconforming use is discontinued for twelve (12) consecutive months, any future use of the building/premises shall conform to this article.

C. If any nonconforming use or structure is destroyed by any means, including floods, to an extent of fifty percent (50%) or more of its value, it shall not be reconstructed, except in conformity with the provisions of this article. The Department of Public Works may permit reconstruction, if the use of the structure(s) is located outside the floodway, and upon reconstruction, is adequately and safely flood proofed, elevated, or otherwise protected.

730.08 Conflicting Provisions Policy:

A. Whenever any provisions of this section impose a greater requirement or a higher standard than is required in a state or federal regulation or other provision of this manual, or other County ordinances or regulations, the provisions of this section shall govern.

B. Whenever any provisions of any state or federal statute or other provision of this manual or other County ordinances or regulations impose a greater requirement or a higher standard than is required by this section, the provisions of the state or federal status or other provisions of this manual or other County ordinances or regulations shall govern.

730.09 Disclaimer of Liability for Areas Outside Flood Hazard Districts:

A. The degree of flood protection required by this article is considered reasonable for regulatory purposes. Larger floods may occur on rare occasions, or flood heights may be increased by man-made or natural causes, such as bridge openings restricted by debris. This article does not imply that areas outside the one hundred (100) year floodplain or land uses permitted within such districts will be free from flooding or flood damages.

B. The granting of a permit or approval of a site development plan in an identified flood hazard area shall not constitute a representation, guarantee, or warranty of any kind by any official or employee of the County of the practicability or safety of the proposed use and shall create no liability upon the County, its officials, or employees.

731.00 FLOODPLAIN MANAGEMENT - PLANNING AND DESIGN

731.01 Determination of Floodway and Limits of the Regulatory Flood:

A. In the floodway district no encroachments, including fill, new construction, substantial improvements, or other development shall be permitted unless it has been demonstrated through hydrologic and hydraulic analyses, performed in accordance with standard engineering practice that the proposed encroachment would not result in any increase in the one hundred (100) year flood elevation.

B. In unstudied (areas outside of the AE zones) or approximate floodplain areas, computation of the floodway shall be based on the area required to convey the regulatory flood without increasing flood heights more than one-half (1/2) foot (150 millimeters) at any point. Computation of increases in flood heights caused by an encroachment shall be based upon equal conveyance reduction on both sides of the watercourse within that reach. The Department of Public Works may allow use of the floodway delineation for streams studied in detail (Zone AE) in the flood insurance study, if determined to be an accurate representation of current conditions, and no floodplain disturbance is proposed.

C. For any floodplain disturbance or modification, the water surface elevations shall be established in accordance with Section 732.02 of this manual.

731.02 Floodplain Studies: The following procedure shall be used by the Department of Public Works in reviewing the computations for establishment of water surface elevations and balance of energy of flowing streams and their floodplains.

A. Examination of the topography of the floodplain area for the location of major constrictions, sharp changes of slope, or where the cross-section becomes narrow relative to the width of the channel.

B. Review of the plotted cross-sections of the stream.

C. Review of the water surface profiles for the one hundred (100) year discharges using the U.S. Army Corps of Engineers' HEC-2 water surface profiles program and SCS's WSP2, water surface profiles program.

D. Comparisons of determined values with available gauge data, USGS regional equations, or any existing reports by federal, state, or local agencies.

- E. Check of the hydrologic models in the following areas:
- (1) Model representation of the watershed (schematic);
 - (2) Tabular data for cross-sections and structures;
 - (3) Precipitation data;
 - (4) Drainage areas;
 - (5) Runoff curve numbers;
 - (6) Times of concentration;
 - (7) Reservoir and channel routing parameters;
 - (8) Miscellaneous items (assumptions, back-up data, other input parameters etc.); and
- F. Check of the hydraulic models in the following areas:
- (1) Length of study and relationship with other cases.
 - (2) Discharges check.
 - (3) Starting water surface elevations.
 - (4) Manning's "n" values and contraction and expansion coefficients.
 - (5) Cross-section spacing and accuracy.
 - (6) Bridge modeling.
 - (7) Floodway computations, if applicable.
 - (8) Miscellaneous items (assumptions, critical depths, etc.).
- G. Check of the representation of the hydrologic and hydraulic analyses on the plans and profiles.

731.03 Effects of Fills:

A. Filling within the one hundred (100) year floodplain of the original stream will frequently create an obstruction that will cause higher water levels upstream during flood flows. Such filling in floodplains is not usually allowed, except for road crossings, SWM facilities, or as allowed by Section 740.00 of this manual.

B. When filling of floodplain is allowed, hydrologic analyses shall be prepared and backwater curves should be carefully calculated based on the presence of the fill or other obstructions. Included shall be a comparison of the flood level at the upstream and downstream property line for existing and modified channel cross conditions.

731.04 Flood Damage Control: All development permitted in the flood hazard overlay district shall, at a minimum, comply with the following standards, except that the Department of Public Works may impose more restrictive standards as warranted:

A. Nonresidential structures, or parts thereof, may be constructed below the one hundred (100) year flood water surface elevation for developed conditions, provided these structures are designed to preclude or withstand inundation to an elevation of at least eighteen (18) inches (450 millimeters) above the one hundred (100) year flood water surface elevation for developed conditions.

B. Uses shall not be permitted in flood fringes and approximated floodplains, including fills and landfills, unless the applicant has demonstrated through the delineation of a floodway that the proposed uses, in combination with all other existing and reasonably anticipated uses, will not raise the water level of the predeveloped one hundred (100) year flood more than one-half (1/2) foot (150 millimeters) at any point, unless additional flood hazard areas are reserved to accommodate increases over one-half (1/2) foot (150 millimeters).

C. When located within floodplains, new utilities shall be located and constructed to minimize or eliminate flood damage.

D. Fill shall comply with the following:

(1) The fill shall be sloped to provide positive drainage away from any building or structure and shall extend fifteen (15) feet (4.57 meters) beyond the limits of such building or structure to a point which is no lower than the regulatory flood elevation for the particular area.

(2) All fill shall consist of soil or small rock materials only. Sanitary and/or debris landfills shall be prohibited. The fill materials shall be compacted to provide the necessary permeability and resistance to erosion or scouring.

(3) Fill slopes shall be no steeper than one (1) vertical unit to three (3) horizontal units, unless substantiating data justifying steeper slopes are submitted to and approved by the Department of Public Works.

(4) The toe of fill shall not be within the designated floodway.

(5) Compensatory excavation shall normally be required for fills in the floodplain, unless waived for environmental reasons.

E. Placement of buildings and structures shall comply with the following:

(1) All buildings and structures shall be designed, constructed and placed on the lot so as to offer the minimum obstruction to the flow of water.

(2) Fences, except two-wire fences, and other structures or matter which may impede, retard or change the direction of the flow of water, or may catch or collect debris carried by such water, or that could be carried downstream by the natural flow of the stream, shall not be placed in the floodway.

F. Anchoring shall comply with the following:

(1) Buildings or structures shall be firmly anchored to prevent movement or collapse from the action of the regulatory flood.

(2) Air ducts, large pipes, and storage tanks located at or below the regulatory flood elevation shall be firmly anchored to prevent floatation.

(3) Minor structures which may be allowed within areas subject to major flooding (e.g., possible park structures, picnic tables, etc.) should be considered from the viewpoint of what will happen when a major flood occurs. Anchoring such structures will prevent them from being floated downstream to block a major culvert.

G. Wood flooring used below an elevation of eighteen (18) inches (450 millimeters) above the one hundred (100) year flood elevation shall be installed to accommodate a lateral expansion of the flooring, perpendicular to the flooring grain, without incurring structural damage to the building.

H. Electrical systems shall comply with the following:

(1) All electrical water heaters, electric furnaces and other critical electrical installations shall be prohibited below an elevation of eighteen (18) inches (450 millimeters) above the regulatory flood elevation.

(2) Electrical distribution panels shall be placed at least three (3) feet (900 millimeters) above the regulatory flood elevation. Separate electrical circuits serving areas below the regulatory flood elevation shall be dropped from above.

I. Plumbing and other mechanical installations shall comply with the following:

(1) Water heaters, furnaces, and other critical mechanical installations shall be prohibited below an elevation of eighteen (18) inches (450 millimeters) above the regulatory flood elevation except for nonresidential structures which are floodproofed.

(2) Gas and oil supply systems shall be designed to preclude the infiltration of flood waters into the systems and discharges from the systems into flood waters. Additional provisions shall be made for the drainage of these systems in the event that flood water infiltration occurs.

(3) No part of an on-site disposal system, including drainfields, shall be allowed with the one hundred (100) year floodplain.

J. Paints and adhesives shall comply with the following:

(1) Adhesives used below an elevation of eighteen (18) inches (450 millimeters) above the regulatory flood elevation shall have a bonding strength that is unaffected by inundation.

(2) Doors and wood trim used below an elevation of eighteen (18) inches (450 millimeters) above the regulatory flood elevation shall be sealed with a waterproof paint or similar product.

(3) Paints or other finishes used below an elevation of eighteen (18) inches (450 millimeters) above the regulatory flood elevation shall be capable of surviving inundation.

K. Materials that are buoyant, flammable, explosive, or in times of flooding could be injurious to human, animal, or plant life, shall not be stored in the one hundred (100) year floodplain, unless they are properly anchored or flood proofed to preclude their causing damage to life or property.

L. Sanitary sewers designed for flooding conditions shall comply with the following:

(1) Sanitary sewers through areas which are frequently subject to flooding should be designed to prevent flood water infiltration into the system as would occur through ordinary vented manhole covers when placed at elevations below the flood surface.

(2) Aerial sewers crossing a stream on supports should be designed with consideration of possible erosive scour around pier footings and for the prevention of access by children to such utility installations.

(3) Design consideration should also be given to preventing a "picket fence" effect caused by using very closely placed piers which would act as a natural trap for debris.

M. Recreational vehicles placed within flood hazard areas shall either be on the site for fewer than one hundred eighty (180) consecutive days, be fully licensed and ready for highway use, or meet the permit requirements for placement and the elevation and anchoring requirements for manufactured homes as contained in the Virginia Uniform Statewide Building Code. A recreational vehicle is ready for highway use if it is on its wheels or jacking system, is attached to the site only by quick disconnect type utilities and security devices, and has no permanently attached additions.

732.00 FLOODPLAIN MANAGEMENT - SUBMISSION REQUIREMENTS

732.01 General Requirements:

A. The data required under this section and sections 730.00 through 732.00 of this manual shall be submitted to the Department of Public Works for technical evaluation and approval before development in the flood hazard overlay district. The issuance of a conditional letter of map amendment (CLOMA) or revision (CLOMR) from FEMA is required, prior to the approval of site development or construction plans, and prior to issuance of any building or flood hazard use permits. An escrow or bond equal to the cost of processing a final letter of map amendment (LOMA) or revision (LOMR) shall be posted with the construction plans. The occupancy of any structures built within the flood overlay district will be contingent upon the submission of a certified FEMA elevation certificate. The issuance of a LOMA or a LOMR shall be required prior to the release of the escrow or construction bonds.

B. Plans drawn to scale, showing the elevation of the one hundred (100) year flood, topographic information showing existing and proposed ground elevations, the nature, location, dimensions and elevation of the lots, existing or proposed structures, fill, storage of materials, streets, water supply, sanitary facilities, flood proofing measures, and the relationship of the above to the location of the channel. For structures to be elevated, the elevation of the lowest floor (including basement) must be shown. For nonresidential structures to be floodproofed, show the elevation to which the structure will be floodproofed.

C. If required, a floodplain study as described in Section 731.02 of this manual, or the file number of the approved floodplain study shall be submitted to the Office of Planning.

732.02 Floodplain Study Criteria: The following items provide general criteria to be used in the preparation of floodplain studies.

A. Friction coefficient, "n" factor, both on-site and off-site shall be computed using the approved form (see Exhibit 16). Photographs of the stream, taken at appropriate cross-sections shall be submitted with the computations. The "n" factor must be approved prior to the submission of the floodplain study.

B. The discharge (Q) and the time of concentration shall be determined in accordance with Section 702.00 of this manual. Runoff curve numbers or coefficient of runoff shall be established based on ultimate development of the watershed in accordance with the current Comprehensive Land Use Plan and consultation with the Department of Public Works.

C. Field or certified aerial run topography of the stream through the site, extending three hundred (300) feet (91.44 meters) up and downstream from the property lines or to a control section, if deemed necessary. Field run or certified aerial topography shall extend to cover the limits of the floodplain freeboard, except in cases of abrupt change in the characteristics of the terrain. Additional topography may be required.

D. The cross-sections shall be perpendicular to the stream channel and/or floodplain and taken at all constrictions and other areas of change in the channel and/or floodplain.

E. For streams not identified as special flood hazard areas (Zone A and AE) in the Flood insurance study of Prince William County, the one hundred (100) year discharge for predeveloped and developed conditions shall be provided. The discharges shall be determined using the methodology stated in Section 702.00 of this manual. The water surface elevations shall be computed using the methodology stated in Section 731.02 of this manual. For minor floodplain studies, normal depth calculations, using Manning's equation, shall be accepted.

F. For streams identified in the flood insurance study of Prince William County, the hydrologic and hydraulic analysis shall be prepared in conformance with the National Flood Insurance Program Regulations as stated in Parts 60, 65, 70 and 72 (Title 44) of the Code of Federal Regulations (CFR) as applicable. In addition, one hundred (100) year discharges and water-surface elevations for developed conditions shall be submitted to the Department of Public Works for review.

G. All hydrologic and hydraulic computations shall be submitted in hard copy and digital format.

732.03 Plan Elements: The following information shall be provided on the plans:

A. Drainage divides of contributing areas and their relation to the site in question at a maximum scale of one (1) inch equals one thousand (1,000) feet, using the County topographic maps as a base (metric map ratio 1:10,000).

B. Cross-sections every one hundred (100) feet (30.48 meters) shall be plotted at a scale of one (1) inch equals ten (10) feet (metric ratio 1:100) vertically, and one (1) inch equals fifty (50) feet (metric ratio 1:500) horizontally. In cases of extremely flat terrain, a scale of one (1) inch equals five (5) feet (metric ratio 1:50) vertically, and one (1) inch equals fifty (50) feet (metric ratio 1:500) horizontally, shall be used. The cross-sections shall show existing and developed water surface elevations for the one hundred (100) year storms.

C. A profile of the floodplain and stream bed indicating the elevation of the water surface and invert of the stream every fifty (50) feet (15.24 meters) for the full length of the floodplain study area shall be submitted with the cross-sections. The scale of the profile shall be one (1) inch equals five (5) feet (metric ratio 1:50) vertically, and one (1) inch equals fifty (50) feet (metric ratio 1:500), horizontally. The profile shall show the one hundred (100) year water surface elevations for developed conditions.

D. A written description of the methodology used to determine hydrologic and/or hydraulic parameters.

E. Delineation of the one hundred (100) year flood boundaries, predeveloped and developed conditions and floodway, if required, and the location and alignment of cross-sections used in the hydraulic model.

(1) This information should be shown on maps of suitable scale and topographic definition to provide reasonable accuracy.

(2) All items should be labeled for easy cross-referencing to the hydrologic and hydraulic models and summary tables.

(3) All lots and structures adjacent to the floodplain should be shown.

F. Source data, engineering documentation, and back-up data, for the previously mentioned items, as well as a reference list of other sources of information used.

G. The flood hazard areas shall be placed on all plats and plans for the site. Flood hazard areas shall coincide with the one hundred (100) year flood boundaries for developed conditions. The mathematical ties between the flood hazard area and the lot lines shall be required on the plats. The plats shall also describe flood hazard area with metes and bounds. The following notes shall be clearly shown: "No use shall be made of, nor shall any improvements be made in the flood hazard area, without specific authorization from the Department of Public Works."

H. Once the floodplain modifications are completed, the floodplain study shall be resubmitted and shall include construction plans for as-built conditions, if applicable. This as-built package is required as per part 65.6 (C), Title 44, CFR, and will be submitted to FEMA to obtain a revision of the flood maps.

732.04 Watercourse Stabilization:

A. Once the adequate capacity of the watercourse has been established, the engineer should provide details of the work required to maintain a stable channel and floodplain, and to prevent erosion or other adverse effects which could place an extreme maintenance burden on future users of the area.

B. All watercourse improvements and maintenance shall be in accordance with Section 740.00 of this manual.

C. Every plan submitted for areas containing a watercourse shall, in addition to the floodplain studies, be accompanied by a written report, signed by a professional engineer, setting forth his or her study, conclusions, and recommendations regarding the following factors and any others that may be pertinent to particular conditions:

(1) Predeveloped watercourse conditions: The original condition of the watercourse and floodplain area, including such matters as probable velocities for the two (2) and ten (10) year storm under present watershed conditions (prior to development), particularly where no continuous channel improvements are proposed, the presence or absence of a meander pattern that may be shifting, areas of existing erosion processes, or where sedimentation is taking place, whether the watercourse appears to be perennial or merely wet weather, the material forming the bed of the natural channel (rock, cobbles, sediment and soil materials, etc.), the state of natural stability of banks and adjacent slopes, whether they are present within the floodplain, abandoned or cut off former courses of the stream, natural levees, etc.

(2) Effect of developed conditions on the existing watercourse: For comparison, the velocity of the two (2) and ten (10) year flows, if the stream is left in an entirely natural condition, but after all of the watershed area has been completely developed according to the Comprehensive Land Use Plan, or in lieu of same, according to reasonable estimates of future development (where no continuous channel improvements are planned). These comparative calculations are to serve as a guide in assessing the probable effect on the stream of increased water discharges.

(3) Proposed modifications: If the foregoing comparison, and other investigations made by the engineer, indicate that watershed environmental changes due to development will adversely affect the stream and probably create a heavy maintenance burden (unless modifications are made to the channel), then a thorough discussion of proposed modifications necessary to eliminate undue maintenance shall be included. Factors involved in such modifications include the use of concrete lining, rubble riprap lining, etc. Possible needed improvements could involve natural levees or abandoned portions of the old meander pattern. In certain areas, these may be for depressions with imperfect natural drainage, which are swampy in times of heavy rainfall, which may be valuable as a natural water quality element to remain.

(4) Other uses as affected: Other proposed uses should also be covered in this report such as utility lines, road crossings, park and recreation areas and trails, etc.

(5) Detailed hydraulic considerations: Adequate measures shall be proposed to prevent erosion from any entering flows, i.e., pipes or streams. Channel changes or partial linings should take into consideration increased erosive forces at bends. Wave action in supercritical flow should be allowed in linings. Riprap should be designed to withstand anticipated velocities. The effects of increased velocity on immediate downstream areas should be considered. Proposed channel changes which decrease velocity should be considered to determine if silt deposition will occur.

(6) Effects on downstream and upstream lands: The engineer's report shall include a discussion of the effects of increased runoff on developed downstream and upstream properties.

732.05 Flood Damage Control for Structures:

A. The applicant shall provide the following factual information as certified by a registered professional engineer, surveyor or architect:

(1) Proposed structure or substantial modifications to the floodplain that will not adversely affect the predeveloped one hundred (100) year flood level;

(2) The lowest floor elevation (including basement) of the proposed structure located at least eighteen (18) inches (450 millimeters) above the one hundred (100) year water surface elevation for developed conditions;

(3) The minimum horizontal distance of fifteen (15) feet (4.57 meters) provided between the one hundred (100) year water surface and the structure proper (the fifteen [15] foot [4.57 meters] setback requirement may be waived for specially designed commercial structures);

(4) Adequate emergency access available to the structure during periods of maximum flooding.

B. The applicant shall specify the one hundred (100) year flood water surface elevation(s) on the plan.

740.00 CHESAPEAKE BAY PRESERVATION AREA – POLICY

740.01 General Policy:

A. The performance standards of this section implement the requirements of Part 504 of Chapter 32 of the Prince William County Code. These performance standards establish the means to minimize erosion and sedimentation potential, reduce land application of nutrients and toxicants, and maximize rainwater infiltration. Natural ground cover, especially indigenous woody vegetation, is most effective in holding soil in place and preventing site erosion. Indigenous woody vegetation, with its adaptability to local conditions without the use of harmful fertilizers or pesticides, filters storm water runoff. Minimizing impervious cover enhances rainwater infiltration and effectively reduces storm water runoff potential.

B. In addition to the objectives in part A of this subsection, the purpose and intent of the requirements of this section are also to implement the following objectives:

(1) Prevent a net increase in nonpoint source pollution from new development.

(2) Achieve a ten percent (10%) reduction in nonpoint source pollution from redevelopment.

C. Any development or redevelopment exceeding two thousand five hundred (2,500) square feet of land disturbance shall be permitted only upon compliance with the requirements of this section, in addition to any other requirements imposed by this manual prior to any clearing or grading of the site or the issuance of any building permit.

740.02 Definitions: The following words and terms used in this part have the following meanings, unless the context clearly indicates otherwise:

A. Agricultural land uses – Activities such as the tilling of the soil, planting and harvesting of crops or plant growth of any kind in the open, pasture, horticulture, dairying, floriculture, or raising of poultry or livestock. This does not include noncommercial ancillary agricultural activities on lands within existing platted residential subdivisions.

B. Applicant - A person seeking any determination under this part or permit required by this ordinance.

C. Best Management Practices (BMPs) - Practices, or combination of practices, that are determined by the County to be the most effective, practical means of preventing or reducing pollution inputs from nonpoint sources to water bodies.

D. Chesapeake Bay Preservation Area - Any land so designated by the Board of County Supervisors pursuant to Part III of the Chesapeake Bay Preservation Area Designation and Management Regulations, 9 VAC 10-20-070, et seq. and Section 10.1-2107 of the Code of Virginia. Chesapeake Bay Preservation Areas shall consist of Resource Protection Areas (RPAs) and Resource Management Areas (RMAs).

E. Chesapeake Bay Preservation Area Review Board – Board of County Supervisors appointed body which reviews exception requests for encroachment into RPA and takes action following a public hearing.

F. Development - The subdivision of land or construction, or substantial alteration of residential, commercial, industrial, institutional, recreation, transportation, or utility facilities or structures.

G. Dripline - A vertical projection to the ground surface from the lateral extent of a tree's leaf canopy.

H. Floodplain - All lands that would be inundated by flood water as a result of a storm event of a one hundred (100) year return interval. The limits of the floodplain shall be established in accordance with Section 731.00 of this manual.

I. Highly Erodible Soils - Soils (excluding vegetation) with an erodibility index (EI) from sheet and rill erosion equal to or greater than eight (8). The erodibility index for any soil is defined as the product of the formula $RKLS/T$, where K is the soil susceptibility to water erosion in the surface layer; R is the rainfall and runoff; LS is the combined effects of slope length and steepness; and T is the soil loss tolerance.

J. Highly Permeable Soils - Soils with a given potential to transmit water through the soil profile. Highly permeable soils are identified as any soil having a permeability equal to or greater than six (6) inches of water movement per hour in any part of the soil profile to a depth of seventy-two (72) inches (“permeability groups rapid and very rapid”) as found in the National Soil Survey Handbook of November 1996, in the Field Office Technical Guide of the U.S. Department of Agriculture Soil Conservation Service.

K. Impervious Cover - A surface composed of any material that significantly impedes or prevents natural infiltration of water into the soil. Impervious surfaces include, but are not limited to roofs, buildings, streets, parking areas, and any concrete, asphalt, or compacted gravel.

L. Infill IDA- Utilization of vacant land in previously developed areas.

M. Intensely Developed Area (IDA) – means those areas designated by the Board of County Supervisors to meet the criteria for designation as an Intensely Developed Area, as

provided in Section 32-504.07 of the County Code and pursuant to 9 VAC 10-20-60 of the Chesapeake Bay Preservation Area Designation and Management Regulations.

N. Nonpoint Source Pollution - Pollution consisting of constituents such as sediment, nutrients, and organic and toxic substances from diffuse sources, such as runoff from agricultural and urban land development and use.

O. Nontidal Wetlands - Those wetlands other than tidal wetlands that are inundated or saturated by surface or ground water at a frequency and duration sufficient to support and that, under normal circumstances, do support a prevalence of vegetation typically adapted for life in saturated soil conditions, as defined by the U.S. Environmental Protection Agency, pursuant to Section 404 of the Federal Clean Water Act, in 33 C.F.R. 328.3b.

P. Noxious Weeds - Weeds that are difficult to control effectively, such as Johnson Grass, Kudzu, thistle and multiflora rose.

Q. Perennial water body – All water bodies identified as perennial when using a scientifically valid system of in-field indicators. Water bodies shall include all areas of natural inflow, including but not limited to: streams, impoundments, lakes and all areas of concentrated flow.

R. Plan of Development - The process for site plan or subdivision plat review to ensure compliance with Part 504 of Chapter 32 of the Prince William County Code, prior to any clearing or grading of a site or the issuance of a building permit.

S. Private road – a privately owned and maintained road designed and constructed in accordance with DCSM standards.

T. Public road – a publicly maintained road designed and constructed in accordance with DCSM or the Virginia Department of Transportation standards.

U. Redevelopment - The process of developing land that is or has been previously developed lawfully under then existing regulations.

V. Resource Management Area (RMA) - That component of the Chesapeake Bay Preservation Area that is not classified as Resource Protection Area and includes land types that, if improperly used or developed, have a potential for causing significant water quality degradation or for diminishing the functional value of the Resource Protection Areas. The following land categories have been considered by the Board of County Supervisors in establishing the resource management areas: floodplains; highly erodible soils including steep slopes; highly permeable soils nontidal wetlands not included in the resource protection area.

W. Resource Protection Area (RPA) - That component of the Chesapeake Bay Preservation Area comprised of lands adjacent to water bodies with perennial flow that have an intrinsic water quality value due to the ecological and biological processes they perform, or are sensitive to impacts which may result in significant degradation to the quality of state waters.

X. Silvicultural Activities – Forest management activities, including but not limited to the harvesting of timber, the construction of roads and trails for forest management purposes, and the preparation of property for reforestation that are conducted in accordance with the silvicultural best management practices developed and enforced by the State Forester pursuant to Section 10.1-1105 of the Code of Virginia and are located on property defined as real estate devoted to forest use under Section 58.1-3230 of the Code of Virginia for the purposes of this Act only.

Y. Substantial Alteration - Expansion or modification of a building or development that would result in a disturbance of land exceeding an area of two thousand five hundred (2,500) square feet in the Resource Management Area only.

Z. Tidal Shore or Shore - Land contiguous to a tidal body of water between the mean low water level and the mean high water level.

AA. Tidal Wetlands - Vegetated and nonvegetated wetlands as defined in Section 28.2-1300 of the Code of Virginia.

BB. Water-Dependent Facility - A development of land that cannot exist outside of a resource protection area and must be located on the shoreline by reason of the intrinsic nature of its operation. As provided in Part 504 of Chapter 32 of the Prince William County Code, these facilities include, but are not limited to, (i) ports; (ii) the intake and outfall structures of power plants, of water treatment plants, of sewage treatment plants, and of storm sewers; (iii) marinas and other boat docking structures; (iv) beaches and other public water-oriented recreation areas; and (v) fisheries or other marine resources facilities.

CC. Wetlands – Tidal and nontidal wetlands.

740.03 Resource Protection Area (RPA) Boundaries:

A. Resource Protection Areas (RPAs) consist of lands adjacent to water bodies with perennial flow that have an intrinsic water quality value due to the biological and ecological processes they perform and are sensitive to impacts which may cause significant degradation to the quality of state waters. In their natural condition these lands provide for the removal, reduction or assimilation of sediments, nutrients, and potentially harmful or toxic substances in runoff entering the Bay and its tributaries and minimize the adverse effects of human activities on state waters and aquatic resources.

B. The Resource Protection Area shall consist of lands that would include:

(1) Tidal wetlands.

(2) Nontidal wetlands connected by surface flow and contiguous to tidal wetlands or water bodies with perennial flow.

(3) Tidal shores.

(4) Perennial water bodies.

(5) An area of 100 feet in width shall be located adjacent to and landward of the components listed in subsections 1 thru 4 listed above and along both sides of a water body with perennial flow. Such area shall be designated as the landward component of RPA, notwithstanding the presence of permitted uses, encroachments, permitted vegetation clearing in compliance with Part IV (9 VAC 10-20-130 et seq.) of the Chesapeake Bay Preservation Area Designation and Management Regulations.

(6) Other lands with sensitive environmental features that have the potential of significantly affecting water quality, as determined by the Director of Public Works.

C. The designation of the components listed under section B. 1-4 above shall be determined based on reliable, site-specific information as detailed in section 742 of this manual.

740.04 Exemptions in Resource Protection Areas: Land disturbances in RPA may be commenced for the following uses or purposes without the submissions and approvals otherwise required under section 740:

A. Water wells, passive recreation facilities such as boardwalks, trails, and pathways and historic preservation and archaeological activities.

B. Construction, installation, operation and maintenance of electric, natural gas, fiber optic and telephone transmission lines, railroads, public roads and their appurtenant structures so long as they comply with Erosion & Sediment Control regulations and the Stormwater Management (SWM) Act of the Code of Virginia. The exemption of public roads is further conditioned on the road alignment and design being such as to minimize encroachment into the RPA and adverse effects on water quality is minimized.

C. Construction, installation and maintenance of water and sanitary sewer lines and storm sewer system outfalls as permitted by Prince William County provided that:

(1) To the degree possible, the location of such utilities should be outside RPA.

(2) No more land shall be disturbed than is necessary to provide the necessary utility installation.

(3) The construction shall be in compliance with applicable state and federal permits.

(4) Any disturbance exceeding 2,500 feet shall comply with Erosion & Sediment requirements.

740.05 Permitted Uses in Resource Protection Areas: The following uses will be allowed in the RPA with the submission of a Water Quality Impact Assessment (WQIA):

- A. Water dependent facilities, new or expanded. Access to the water dependent facility will be provided with the minimum necessary disturbance to the RPA.
- B. Development or redevelopment within the designated Intensely Developed Area (IDA)
- C. Regional SWM facility as defined in section 741.03.

740.06 Exceptions for Encroachments into the RPA: Any proposed encroachment into the RPA area which is not exempt under section 740.04 or permitted under section 740.05 of this manual shall submit a request for an exception in writing to the Director of Public Works. This request shall identify the impacts of the proposed exception on water quality and on lands within the RPA through the performance of a Water Quality Impact Assessment (WQIA) which complies with the provisions of section 742.05.

An exception may be granted with such conditions and safeguards as deemed necessary to further the purpose and intent of Part 504 of Chapter 32 of the Prince William County Code and this section, provided that it is found that:

- (1) Granting the exception will not confer upon the applicant any special privileges that are denied to other property owners in the CBPA overlay district.
- (2) The exception request is not based on conditions or circumstance that are self-created or self-imposed, nor does the request arise from conditions or circumstances either permitted or nonconforming that are related to adjacent parcels.
- (3) The exception requested is the minimum necessary to afford relief.
- (4) The exception request will be consistent with the purpose and intent of the overlay district, and not injurious to the neighborhood or otherwise detrimental to the public welfare.
- (5) Reasonable and appropriate conditions are imposed which will prevent the exception request from causing a degradation of water quality.

A. Administrative exception: The Director of Public Works shall review the request for an exception and associated WQIA and may grant an administrative exception with such conditions and safeguards as deemed necessary to further the purpose of this section of the manual. An administrative exception will be considered in the following situations:

- (1) Lots lawfully recorded prior to November 27, 1990 when the application of the RPA would result in the loss of buildable area, provided that:

(a) Encroachments into the RPA shall be the minimum necessary to achieve a reasonable buildable area for a principal structure and necessary utilities; accessory structures shall not be allowed if their construction will further reduce the RPA width.

(b) Where possible, an area equal to the area encroaching the RPA shall be established elsewhere on the lot or parcel in a way to maximize water quality protection.

(c) In no case shall the encroachment into the RPA area be greater than fifty (50) feet in width.

(d) Where the necessary encroachment in the RPA is greater than 50 feet, such exception may be granted only following a public hearing conducted by the Chesapeake Preservation Area Review Board.

(2) Lots lawfully recorded between November 27, 1990 and March 1, 2002 which meet conditions 740.06A1a through 740.06A1c as listed above and the additional following conditions:

(a) Conditions or mitigation measures imposed through a previously approved exception shall be met.

(b) If the use of a best management practice was previously required, the BMP shall be evaluated to determine if it continues to function effectively and if necessary, the BMP shall be reestablished or repaired and maintained as required.

(3) A private road or driveway crossing provided it satisfies specific conditions imposed by the Department of Public Works.

(4) Lots for which encroachment into RPA is necessary to install septic drainfields and where no alternate percolation sites are available as verified by the Health Department.

(5) Expansion of a non-conforming structure for minor alteration in conformance with Section 601.33 of the Zoning Ordinance.

B. If the administrative exception request is denied, the Director of Public Works shall provide the rationale for the decision to the applicant. The applicant may then appeal the decision to the Chesapeake Bay Preservation Area Review Board, within 30 days of denial.

C. Exceptions requiring a Public Hearing - The Director of Public Works shall review and forward its recommendation on all other exception requests, with accompanying WQIA, to the Chesapeake Bay Preservation Area Review Board for consideration and action following a public hearing.

D. The Chesapeake Bay Preservation Area Review Board shall conduct a public hearing to review the request for an exception and the WQIA and may grant the exception with such

conditions and safeguards as deemed necessary to further the purpose and intent of Part 504 of Chapter 32 of the Prince William County Code and this section.

E. If the exception request is denied, the Chesapeake Bay Preservation Area Review Board shall provide its written findings and rationale for the decision to the applicant. The decision of the Board is final and can be appealed by the applicant to the Circuit Court within 30 days of the denial.

741.00 CHESAPEAKE BAY PRESERVATION AREA – PLANNING AND DESIGN

741.01 General Performance Standards:

A. Land disturbance shall be limited to the area necessary to provide for the proposed use or development and shall comply with the following:

(1) The proposed limits of disturbance shall be clearly shown on all plans. The limits shown on the approved plans shall be physically marked and protected on the development site.

(2) No construction access should be permitted through an RPA unless specifically approved by the Director of Public Works.

B. Indigenous vegetation shall be preserved to the maximum extent possible, consistent with the use and development proposed and in accordance with the Virginia Erosion and Sediment Control Handbook. All development or redevelopment shall conform to the requirements of Section 800.00 of this manual. Site design shall preserve existing tree cover to the greatest extent feasible. Diseased trees or trees weakened by age, storm, fire, or other injury may be selectively removed in accordance with the requirements of Section 800.00 of this manual.

C. Land development shall minimize impervious cover to promote infiltration of storm water into the ground consistent with the proposed use or development, in accordance with Section 721.00 of this manual.

D. Any land disturbing activity cumulatively exceeding two thousand five hundred (2,500) square feet, including construction of single-family houses, shall comply with the requirements of Section 751.00 of this manual.

E. All on-site sewage disposal systems not requiring an NPDES permit shall be pumped out at least once every five (5) years, in accordance with the provisions of Chapter 23 of the Prince William County Code.

F. A reserve sewage disposal site with a capacity at least equal to that of the primary sewage disposal site shall be provided in accordance with the requirement of Section 500.00 of this manual.

G. For any use or development, including redevelopment, storm water runoff shall be controlled by the use of best management practices in accordance with Section 721.00 of this manual.

H. Prior to initiating grading or other on-site activities on any portion of a lot or parcel, all wetland permits required by federal, state, and local laws and regulations shall have been obtained and evidence of such submitted to the Director of Public Works.

741.02 Additional Performance Criteria for RPA:

A. To minimize the adverse effects of human activities on the other components of RPA, state waters, and aquatic life, a one hundred (100) foot buffer area of vegetation that is effective in retarding runoff, preventing erosion, and filtering nonpoint source pollution from runoff shall be retained if present and established where it does not exist adjacent to water bodies with perennial flow.

B. In accordance with the regulations of this section, the one hundred (100) foot RPA buffer area of natural or established vegetation is deemed to achieve a forty percent (40%) reduction of nutrients provided that runoff is conveyed by sheet flow through the buffer area.

C. In order to maintain the functional value of the RPA buffer area, indigenous vegetation may be removed subject to written approval by the Director of Public Works or approval of a plan to provide reasonable access paths, sight lines, general woodlot management, and best management practices, including those that prevent upland erosion and concentrated storm water flows, as follows:

(1) Trees may be pruned or removed as necessary to provide for sight lines and vistas provided that where removed, they shall be replaced with other vegetation that is equally effective in retarding runoff, preventing erosion and filtering nonpoint source pollution from runoff.

(2) Where indigenous vegetation is removed to create passive recreation trails, the path shall be constructed and surfaced so as to effectively control erosion.

(3) Dead, diseased, or dying trees or shrubbery and noxious weeds may be removed and thinning of trees may be conducted based upon the best available technical information in conformance with section 802.33 of this manual and pursuant to sound horticultural practice as determined by the Director of Public Works.

(4) Where areas to be preserved in RPA, as designated on an approved site, subdivision or lot grading plan, are encroached upon, replacement of existing trees and other vegetation will be achieved in accordance with a site specific RPA restoration plan approved by the Director of Public Works.

(5) For shoreline erosion control projects, trees, and woody vegetation may be removed, necessary control techniques employed, and appropriate vegetation established to protect or stabilize the shoreline in accordance with the best available technical advice and applicable permit conditions or requirements.

D. Where land uses such as agriculture or silviculture within the area of the buffer cease, and the land is proposed to be converted to other uses, the full 100-foot buffer area shall be reestablished. In reestablishing the buffer, management measures shall be undertaken to provide woody vegetation that assures the buffer functions as set forth in the Chesapeake Bay Regulations. (9VAC10-20-130)

741.03 RPA Buffers in Intensely Developed Areas (IDA): Development and redevelopment within intensely developed areas (IDA) and IDA infill shall be exempt from the provisions of Section 741.02, but only in accordance with the following:

A. The proposed development or redevelopment is permitted under the provisions of Part 601 of Chapter 32 of the Prince William County Code and Section 740.07 of this manual, as applicable.

B. Any proposed development or redevelopment shall not increase the areas of disturbed RPA, exclusive of RPA buffers, unless such disturbance is otherwise permitted by and consistent with the requirements of Part 504 of Chapter 32 of the Prince William County Code and all applicable requirements of this manual.

C. Development or redevelopment shall meet all RPA buffer standards established in Section 741.02, except that encroachment due to redevelopment may occur within the full width of the buffer.

D. Notwithstanding the provisions of subparagraphs A, B, and C above, the RPA buffer shall be established to the extent feasible consistent with the proposed development of redevelopment of the site.

E. All other requirements of this manual, the Prince William County Code and other applicable laws are met.

741.04 Minimum Lot Size in Relation to RPA:

A. All residential lots, of 20,000 square feet or less, shall not be platted incorporating land within an RPA, irrespective of zoning designation.

B. For all other residential lots, RPA land may be incorporated within the lots when the following criteria are met:

(1) Lots must have 20,000 square feet or more outside of the RPA.

(2) All minimum required yard, setbacks and other applicable development standards have been met and shown on the plats.

(3) A minimum distance of fifty (50) feet shall be between the principal structure, and any attachments thereto, and the RPA.

C. For lots two (2) acres or greater in size, RPA acreage may be used to calculate minimum lot size, provided that sufficient acreage lies outside that portion of the lot zoned RPA to permit reasonable use and enjoyment of any proposed use not permitted in the RPA.

741.05 Special Provisions for SWM Facilities:

A. Regional storm water management facilities, part of an approved watershed plan or as hereafter provided, may be located in the RPA, provided that the following criteria are met:

(1) They are part of a watershed storm water management plan which considers environmentally sensitive features and minimizes negative impacts on them. Where possible, plans must locate facilities outside of RPAs.

(2) A water quality impact assessment is required for each SWM facility in RPA.

(3) All performance criteria must be met, including wetlands permits, locating nonwater-dependent elements outside of RPAs, and minimum vegetative removal and access disturbances.

B. Until such time as the watershed in which the development is located is the subject of an approved watershed plan, the Director of Public Works may permit on-site storm water management facilities to be located in the RPA that, in general, serve drainage areas that exceed one hundred (100) acres in size and otherwise conform to the criteria set out in this section.

742.00 CHESAPEAKE BAY PRESERVATION AREA - SUBMISSION REQUIREMENTS

742.01 CBPA Overlay District: In addition to the requirements of chapters 25 and 32 of the Prince William County Code, the applicant shall submit the following prior to any development or redevelopment of lands within Chesapeake Bay preservation areas:

A. Perennial Flow Determination in accordance with section 742.02 of this manual.

B. Preservation Area Site Assessment (PASA), in accordance with Section 742.03 of this manual, as applicable.

C. Water Quality Impact Assessment (WQIA) study, in accordance with sections 742.04 and 742.05 of this manual, as applicable.

D. RMA limits study, if desired, in accordance with the provisions of Section 742.06 of this manual, as applicable.

E. Studies or plans as required by all applicable sections of this Design and Construction Manual. (Landscaping plan, Stormwater Management plan, E&S control plan, etc.)

742.02 Perennial Flow Determinations: A reliable, site-specific determination shall be conducted to determine whether water bodies within the development site have perennial flow. Such determination will be made using a scientifically valid system of in-field indicators acceptable to the Director of Public Works.

A. If water bodies exist on the development site and have a drainage area greater than 100 acres, a perennial flow determination shall be required in conjunction with a rezoning or special use permit application, preliminary subdivision plan or site plan submission. This determination shall identify all perennial streams located on the proposed development site using a method approved by the Director of Public Works.

B. If water bodies exist on the development site and have a drainage area less than 100 acres, a perennial flow determination can be limited to a modified flow determination study of less detail which is acceptable to the Director of Public Works. This simplified perennial stream documentation can be in the form of field notes, observed flow conditions, photos with short narrative or survey or other relevant observations. The dated pictures taken during field visit shall be submitted to the County.

C. The Director of Public Works may require a detailed perennial flow determination for water bodies on the development site with a drainage area less than 100 acres under unique circumstances where field data is available from the Department of Public Works.

D. For development sites containing Resource Protection Areas (RPAs) as mapped on the County's Chesapeake Bay Preservation Area Overlay map, the Director of Public Works may allow the applicant to use the map delineation as a representation of perennial flow for all water bodies mapped as RPA. However, the applicant is still required to establish whether all other water bodies within the development site not mapped as RPA exhibit perennial flow through site-specific determination.

742.03 Preservation Area Site Assessment (PASA):

A. A Preservation Area Site Assessment (PASA) shall be submitted for any proposed development site where RPA is located on the site based on Chesapeake Bay Preservation Area Overlay maps or on Perennial Flow Determination. This PASA shall be submitted to delineate the extent of wetlands on the site and to define RPA boundaries. The PASA shall be submitted in conjunction with a rezoning or special use permit application, preliminary subdivision plan or first plan submission and once approved, shall be considered valid for 5 years from approval date, or as long as the final site plan remains valid.

B. A PASA study submission shall include a narrative report and associated plans which detail the field investigation done at the site to determine the extent of wetlands on the site at the time of investigation.

C. Wetland delineation shall be performed during field investigation of PASA and shall be in accordance with the United States Army Corps of Engineers "Wetlands Delineation Manual, Technical Report Y-87-1, January 1987, Final Report (Federal Manual) or latest effective edition.

D. The PASA shall clearly delineate RPA boundaries as defined in section 740.03 of this manual.

E. The PASA shall be drawn at the same scale as the preliminary site plan or subdivision plan, and plans shall be certified as complete and accurate by a licensed professional engineer, or a licensed land surveyor.

F. Upon the submission by an applicant of the Preservation Area Site Assessment, the Department of Public Works shall verify the accuracy of and may render adjustments to the boundary delineation shown therein.

742.04 Water Quality Impact Assessment: A Water Quality Impact Assessment (WQIA) is required for any proposed development in RPA or as determined by the Director of Public Works, based on the unique characteristics of the site or intensity of the proposed use or development.

A. The purpose of the WQIA is as follows:

(1) Identify the impacts of proposed development on water quality and lands within RPAs and other environmentally sensitive lands that have the potential to significantly affect water quality.

(2) Ensure that, where development does take place within RPAs and other sensitive lands, it will be located on those portions of a site and in a manner that will be least disruptive to the natural functions of RPAs and other sensitive lands important to the natural functioning of RPA lands, consistent with the goals and objectives of the Chesapeake Bay Preservation Act, the regulations of Part 504 of Chapter 32 of the Prince William County Code, and this section of the manual.

B. The submission of a modified WQIA may be accepted by the Director of Public Works in conjunction with the processing of exceptions as identified in section 740.06A.

C. All information required for a WQIA in this section shall be certified as complete and accurate by a licensed professional engineer or a licensed land surveyor.

D. Upon the completed review of a water quality impact assessment, the Department of Public Works will determine if the proposed development is consistent with the purpose and

intent of Part 504 of Chapter 32 of the Prince William County Code and this section and make a finding based upon the following criteria:

- (1) The proposed development within any RPA is permitted pursuant to Section 32-504.06 of the Prince William County Code.
- (2) The disturbance of wetlands will be minimized.
- (3) The development will not result in significant disruption of the hydrology of the site.
- (4) The development will not result in significant degradation to aquatic vegetation or life.
- (5) The development will not result in unnecessary destruction of plant materials on-site.
- (6) Development is consistent with all applicable standards of the DCSM, including stormwater, erosion and sediment control, drainfields, etc. and the intent of the Chesapeake Bay Preservation Act.
- (7) The cumulative impact of the proposed development, when considered in relation to other development of the vicinity, both existing and proposed, will not result in a significant degradation of water quality.

E. The Director of Public Works shall require additional mitigation where potential impacts have not been adequately addressed. Evaluation of mitigation measures will be made by the Department of Public Works based on the criteria listed in this section.

F. The Director of Public Works shall find the proposal to be inconsistent with the purpose and intent of this article when the impacts created by the proposal cannot be mitigated. Evaluation of the impacts will be made by the Department of Public Works, based on the criteria listed in this section.

G. Approval of the water quality impact assessment shall be conditioned upon review and approval of final design calculations which validate the design provisions of the plan.

742.05 Water Quality Impact Assessment Elements: A water quality impact assessment shall include a site drawing to scale which shows the following:

- A. Location of the components of the RPA, including the one hundred (100) foot RPA buffer area.
- B. Location and nature of the proposed encroachment into the RPA buffer.

C. Type and location of proposed best management practices to mitigate the proposed encroachment. Estimation of pre and post development pollutant loads in runoff (refer to Exhibit 23 - Buffer Equivalency Bulletin.).

D. A hydrogeological element that provides the following:

- (1) Existing topography, soils, hydrology and geology of the site and adjacent lands.
- (2) Description of the impacts of the proposed development on topography, soils, hydrology and geology on the site and adjacent lands.
- (3) Anticipated duration and phasing schedule of the construction.
- (4) Estimation of pre and post development pollutant loads in runoff. (refer to Exhibit 23 - Buffer Equivalency Bulletin.)
- (5) Listing of all requisite permits from all application agencies necessary to develop the project.
- (6) Proposed mitigation measures for the potential hydrogeological impacts shown on the site plan or plat. Potential mitigation measures include:
 - (a) Proposed erosion and sediment control concepts, which may include minimizing the extent of the cleared area, perimeter controls, reduction of runoff velocities, measures to stabilize disturbed areas, schedule and personnel for site inspection.
 - (b) Proposed storm water management and BMP systems.
 - (c) Creation of wetlands to replace those lost.
 - (d) Minimizing cut and fill and land disturbance.

E. A wastewater element, where applicable, that provides the following:

- (1) Size and locations of anticipated drainfield or wastewater irrigation areas.
- (2) Justification for sewer line locations in environmentally sensitive areas, where applicable, and of construction techniques and standards.
- (3) Proposed on-site collection and treatment systems, their treatment levels, and impacts on receiving watercourses.

742.06 RMA Limits Study:

A. An applicant electing to establish the limits of RMA on the subject property shall submit an RMA limits study establishing concentrations of the following:

- (1) Floodplain.
- (2) Highly erodible soils, including steep slopes greater than twenty-five percent (25%).
- (3) Highly permeable soils.
- (4) Nontidal wetlands not included in the RPA.

B. Upon review of the RMA limits study, if the Department of Public Works is satisfied the applicant has established the absence of concentrations of land types protected as RMA on the entire property, the Director of Public Works shall approve the exemption of such property area from the application of these provisions. The applicant shall cause a plat depicting the areas approved for exemption to be recorded among the land records of the County.

742.07 Final Site Plans: In addition to all other requirements applicable to site development plans such as a landscaping plan, a storm water management plan, and an erosion and sediment control plan, all projects within Chesapeake Bay preservation areas shall include the following additional information:

A. The delineation of the RPA boundary by metes and bounds description with the following note: "No use shall be made of, nor shall any improvements or modifications be made in the resource protection area without specific authorization from Prince William County." This shall also be shown on the record plat.

B. Plat notation or stamp containing notification of 5-year septic pump out and 100% reserve drainfield requirements for onsite sewage treatment systems.

C. Wetlands permit submissions.

D. A maintenance agreement, as deemed necessary and appropriate by the Director of Public Works to ensure proper maintenance of best management practices in order to continue their functions in accordance with the provisions of Section 722.00 and 100.00 of this manual.

E. If the Director of Public Works has approved an RMA limits study, pursuant to Section 742.06, a delineation of the RMA by metes and bounds description.

743.00 CHESAPEAKE BAY PRESERVATION AREA – VIOLATIONS

743.01 Disturbance of RPA: Where areas designated as RPA are encroached upon without prior approval in accordance with Sections 740.04, 740.05 and 740.06, they shall be restored in accordance with a plan approved by the Director of Public Works. Restoration of the disturbed areas shall be performed as necessary to meet the intent of the regulations and shall be in accordance with a site specific restoration plan detailing both any existing vegetation and all

supplemental plantings to adequately reestablish the natural vegetative condition which existed previously on the site, including trees, shrubs and groundcover.

743.02 Violation of Chesapeake Bay Regulations: Any construction, vegetation removal or land disturbing activity in the Resource Protection Area contrary to permitted provisions of this Section shall be declared to be a violation and shall be enforced in accordance with Section 100.

750.00 EROSION AND SEDIMENT CONTROL - POLICY

750.01 Definitions: For the purpose of this section, the following words and phrases shall have meanings respectively ascribed to them as follows:

A. Applicant - A person or persons required herein and hereby to accept legal responsibility for the land disturbing activity for which a permit is requested, namely the owner of the property on which such land disturbing activity is proposed to be accomplished as well as any contractor, agent, or other person who, by virtue of contractual employment or other relationship to the owner of the property of which such land disturbing activity is proposed to be accomplished, is or will be in actual or effective control of all or a substantial portion of the land disturbing activity for which the application is or has been made.

B. Conservation Plan, Erosion and Sediment Control Plan - A document containing material for the conservation of soil and water resources of a parcel or parcels of land. It may include appropriate maps, an appropriate soil and water plan inventory and management information with needed interpretations, and a record of decisions contributing to conservation treatment. The plan shall contain all major conservation decisions to assure that the entire parcel or parcels of land will be so treated to achieve the conservation objectives.

C. Soil and Water Conservation District - A political subdivision of the commonwealth organized in accordance with the provision of Section 10.1-506 of the Code of Virginia, 1950, as amended.

D. Erosion Impact Area - An area of land not associated with current land disturbing activity but subject to persistent soil erosion resulting in the delivery of sediment onto neighboring properties or into drainageways. This definition shall not apply to any lot or parcel of land of two thousand five hundred (2,500) square feet (232.26 square meters) or less used for residential purposes.

E. Land Disturbing Activity - Any land change which may result in soil erosion from water or wind and the movement of sediments into drainageways or state waters, or onto lands in the commonwealth, including but not limited to, clearing, grading, excavating, transporting, and filling of land. The term shall not include those activities identified in Section 750.04 of this manual.

F. Local Erosion and Sediment Control Program - An outline of the various methods employed by a program authority to regulate land disturbing activities and thereby minimize erosion and sedimentation in compliance with the state program, and may include such items as local ordinances, policies and guidelines, technical materials, inspection, enforcement, and evaluation.

G. Owner - The owner or owners of the freehold of the premises or lesser estate therein, a mortgagee, or vendee in possession, assignee of rents, receiver, executor, trustee, lessee, or other person, firm, or corporation in control of a property.

H. Permittee - The person to whom the permit authorizing land disturbing activities is issued or the person who certifies the approved erosion and sediment control plan will be followed.

I. Person - Any individual, partnership, firm, association, joint venture, public or private institution, utility, cooperative, county, city, town, or other political subdivision of the commonwealth, any interstate body, or other legal entity.

J. Plan Approving Authority - The director of Planning of Prince William County.

K. State Erosion and Sediment Control Program - The program administered by the Virginia Soil and Water Conservation Board, pursuant to Article 4, Chapter 5, Title 10.1 of the Code of Virginia, 1950, as amended, including regulations designed to minimize erosion and sedimentation.

L. Program Authority - The director of Public Works of Prince William County.

M. Certified Inspector - An employee or agent of the program authority who holds a certificate of competence from the Virginia Soil and Water Conservation Board in the area of project inspection.

N. Certified Plan Reviewer - An employee or agent of the program authority who holds a certificate of competence from the Virginia Soil and Water Conservation Board in the area of plan review or is licensed as a professional engineer or land surveyor pursuant to Article 1 of Chapter 4 of Title 54.1 of the Code of Virginia.

O. Certified Program Administrator - An employee or agent of the program authority who holds a certificate of competence from the Virginia Soil and Water Conservation Board in the area of program administration.

750.02 General Policy:

A. The purpose of this section is to protect the soil and water resources of Prince William County through a coordinated program to limit soil erosion and sediment deposits caused by land disturbance activities related to urban development.

B. The County accepts and shall enforce all provisions of the Virginia Erosion and Sediment Control Law (Title 10.1 of the Code of Virginia). In addition, the County shall enforce the state's current erosion and sediment control regulations. Additional County requirements are described in sections 751.00 and 752.00 of this manual.

C. Whenever a land disturbing activity is proposed to be conducted by a contractor performing construction work pursuant to a construction contract, the preparation, submission, and approval of the required erosion and sediment control plan shall be the responsibility of the owner of the land.

D. Any erosion and sedimentation plan submitted under the provisions of this section will be acted on within forty-five (45) days from receipt by either approving or disapproving in writing and, if disapproved, giving specific reasons for such disapproval. If no formal action has been taken within forty-five (45) days after receipt of a plan, the plan shall be deemed approved. An erosion and sediment control plan submitted as part of a final subdivision or site plan will be reviewed within the time specified in the Administrative Procedures Manual. Where land disturbing activities involve lands under the jurisdiction of more than one local program, an erosion and sediment control plan may, at the option of the applicant, be submitted to the Board for review and approval, rather than to each jurisdiction. However, the applicant shall still be required to obtain appropriate permits from the County.

750.03 Permits:

A. No person shall engage in land disturbing activity of more than two thousand five hundred (2,500) square feet (232.26 square meters) until the appropriate type of permits have been acquired.

B. An approved erosion and sediment control plan and certification that this plan will be carried out is required for issuance of site development, grading, building, or other permits.

C. Erosion and sediment control measures shall be installed, inspected, and approved prior to the initiation of construction.

750.04 Erosion and Sedimentation Control Management:

A. An agreement shall be required on all projects which will obligate the developer to construct and maintain required erosion and sediment control devices, as specified on approved site development plans.

B. The agreement shall be between the developer and the Board of County Supervisors. It shall ensure that measures could be taken by the Department of Public Works, at the applicant's expense, should erosion and sediment control devices fail. Such action shall occur after proper notice and within the time specified to initiate or maintain appropriate conservation action, which may be required by the approved plan as a result of land disturbing activity.

C. The agreement document shall provide for a right-of-entry by representatives of the County, for purposes of inspection, reinstallation, maintenance, or any conservation practices as may be necessary.

D. If the Department of Public Works takes conservation action, upon failure of the erosion and sediment control devices from the applicant, it may collect the difference between the amount of the reasonable cost of such action which exceeds the amount of the security held.

750.05 Exceptions:

A. The following activities shall not be required to provide erosion and sediment control unless subject to the requirements of the Chesapeake Bay regulations:

(1) Minor land disturbing activities, such as home gardens, individual home landscaping, repairs, and maintenance.

(2) Individual service connections of telephone, cable, and electricity.

(3) Installation, maintenance or repair of any underground public utility lines when such activity occurs on an existing hard surface road, street, or sidewalk, provided the land disturbing activity is confined to the area of the road, street, or sidewalk, which is hard surfaced.

(4) Septic tank lines or drainage fields, unless included in an overall plan for land disturbing activity relating to construction of the building to be served by a septic system.

(5) Surface or deep mining.

(6) Exploration or drilling for oil and gas including well site, feeder lines, and off-site disposal areas.

(7) Tilling, planting, harvesting of agricultural, horticultural or forest crops, or livestock feedlot operations, including engineering, operating as follows: Construction of terraces, terrace outlets, check dams, desilting basins, dikes, ponds, ditches, strip cropping, lister furrowing, contour cultivating, contour furrowing, land drainage, and land irrigation.

(8) Repair or rebuilding of the tracks, right-of-way, bridges, communication facilities, and other related structures and facilities of a railroad company.

(9) Agricultural engineering operations including, but not limited to, the construction of terraces, terrace outlets, check dams, desilting basins, dikes, ponds not required to comply with the provisions of the Dam Safety Act (Section 10.1-604 et seq. of the Code of Virginia, as amended), ditches, strip cropping, lister furrowing, contour cultivating, contour furrowing, land drainage, and land irrigation.

(10) Preparation for single-family residences separately built and with land disturbance less than two thousand five hundred (2,500) square feet (232.26 square meters) in size.

(11) Disturbed land areas of less than two thousand five hundred (2,500) square feet (232.26 square meters) in size.

(12) Installation of fence and sign posts or telephone and electric poles and other kinds of posts or poles.

(13) Shore erosion control projects on tidal waters when the projects are approved by the local wetlands board, the Marine Resources Commission or the United States Corps of Engineers.

(14) Emergency work to protect life on property and emergency repairs. However, if the land disturbing activity would have required an approved erosion and sediment control plan, had there not been an emergency, then the land disturbed shall be stabilized in accordance with this section.

750.06 Monitoring, Reports, and Inspections:

A. The Department of Public Works shall provide for periodic inspections of the land disturbing activity and may require monitoring and reports from the person responsible for carrying out the plan. The purpose of the periodic inspections is to ensure compliance with the approved plan and to determine whether the measures required in the plan are effective in controlling erosion and sediment. The owner, permittee, or person responsible for carrying out the plan shall be given notice of the inspection.

B. If a County inspector determines that there is a failure to comply with the plan, a notice to comply shall be served upon the permittee or person responsible for carrying out the plan by registered or certified mail to the address specified in the permit application, or by delivery at the site of the land disturbing activity to the agent or employee supervising such activities. The notice shall specify the measures needed to comply with the plan and shall specify the time within which such measures shall be completed. Upon failure to comply within the time specified, the permit may be revoked and the applicant shall be deemed in violation of this section. Upon conviction, the applicant shall be subject to the penalties provided in sections 750.07, 750.08, and 750.09 of this manual.

C. After land clearing operations have begun, no area shall be denuded for more than fourteen (14) days, except that portion of the site in which work will be continued beyond fourteen (14) days. All trenches for storm, sewer, water, and gas lines are to be backfilled, compacted, seeded, and mulched within seven (7) days of backfill.

D. A County inspector may ask the person responsible for carrying out the approved plan to change it in accordance with the following:

(1) Where inspection has revealed that the plan is inadequate to satisfy applicable regulations.

(2) Where the person responsible for carrying out the approved plan finds that the approved plan cannot be effectively carried out, and proposed amendments to the plan, consistent with the requirements of this section, are agreed to by the director of Public Works.

750.07 Violations:

A. If, after written notification, in accordance with sections 10.1-566 and 10.1-569 of the Code of Virginia, erosion and sediment control compliance is not obtained, appropriate administrative/legal action will be initiated which shall include authorizing the Department of Public Works to take erosion control escrow funds to correct the deficiencies listed on the violation in the event the suspense date is not met.

B. In the event that a violation of sections 10.1-563 or 10.1-566 of the Virginia Code is observed, a stop work order may be sought, pursuant to Section 10.1-566 C of the Code of Virginia, to prevent the unreasonable degradation of properties, stream channels, waters, and other natural resources.

C. The director of Public Works shall not begin any legal action to enforce the provisions of this section, unless notice has been given to the applicant of a violation of this section. Such notice shall give the applicant a reasonable opportunity under particular circumstances to correct the situation before enforcement action.

D. Violators of sections 10.15-563 and 10.1-566 of the Code of Virginia shall be guilty of a Class I misdemeanor.

E. Any person who violates this section may be liable to the County in a civil action for damages, as appropriate.

F. Any person violating or failing, neglecting, or refusing to obey any injunction, mandamus, or other remedy obtained pursuant to this section shall be subject, in the discretion of the court, to a civil penalty not to exceed two thousand dollars (\$2,000) for each violation. A civil action for such violation or failure may be brought by the Board of County Supervisors. Any civil penalties assessed by the court shall be paid to the County.

G. Violation of any regulation or provision of the erosion and sediment control program and condition of a permit shall be subject to the following:

(1) The civil penalty for commencement of land-disturbing activities without an approved plan, as provided in Section 750.03 of this manual, shall be one thousand dollars (\$1,000).

(2) Violation of any of the following minimum standards, which are set forth in subsections 4 (1) through 4 (17) of the erosion and sediment control regulation, as codified at VR 625-02-00, and which are incorporated herein by reference, shall be subject to a civil penalty of one hundred dollars (\$100).

(a) Permanent or temporary soil stabilization shall be applied to denuded areas within seven days after final grade is reached on any portion of the site. Temporary soil stabilization shall be applied within seven (7) days to denuded areas that may not be at final grade but will remain dormant for longer than thirty (30) days. Permanent stabilization shall be applied to areas that are to be left dormant for more than one (1) year.

(b) During construction of the project, soil stockpiles and borrow areas shall be stabilized or protected with sediment trapping measures. The applicant is responsible for the temporary protection and permanent stabilization of all soil stockpiles on site as well as borrow areas and soil intentionally transported from the project site.

(c) A permanent vegetative cover shall be established on denuded areas not otherwise permanently stabilized. Permanent vegetation shall not be considered established until ground cover is achieved that is uniform, mature enough to survive, and will inhibit erosion.

(d) Sediment basins and traps, perimeter dikes, sediment barriers and other measures intended to trap sediment shall be constructed as a first step in any land-disturbing activity and shall be made functional before upslope land disturbance takes place.

(e) Stabilization measures shall be applied to earthen structures such as dams, dikes and diversions immediately after installation.

(f) Sediment traps and sediment basins shall be designed and constructed, based upon the total area to be served by the trap or basin.

(i) The minimum storage capacity of a sediment trap shall be one hundred thirty-four (134) cubic yards per acre of drainage area and the trap shall only control drainage areas less than three (3) acres (1.21 hectares).

(ii) Surface runoff from disturbed areas that is comprised of flow from drainage areas greater than or equal to three acres (1.21 hectares) shall be controlled by a sediment basin. The minimum storage capacity of a sediment basin shall be one hundred thirty-four (134) cubic yards per acre of drainage area. The outfall system shall, at a minimum, maintain the structural integrity of the basin during a twenty-five (25) year storm of twenty-four (24) hour duration. Runoff coefficients used in runoff calculations shall correspond to a bare earth condition or those conditions expected to exist while the sediment basin is utilized.

(g) Cut and fill slopes shall be designed and constructed in a manner that will minimize erosion. Slopes that are found to be eroding excessively within one year of permanent stabilization shall be provided with additional slope stabilization measures until the problem is corrected.

(h) Concentrated runoff shall not flow down cut or fill slopes, unless contained within an adequate temporary or permanent channel, flume or slope drain structure.

(i) Whenever water seeps from a slope face, adequate drainage or other protection shall be provided.

(j) All storm sewer inlets that are made operable during construction shall be protected so that sediment-laden water cannot enter the conveyance system without first being filtered or otherwise treated to remove sediment.

(k) Before newly constructed stormwater conveyance channels or pipes are made operational, adequate outlet protection and any required temporary or permanent channel lining shall be installed in both the conveyance channel and receiving channel.

(l) When work in a live watercourse is performed, precautions shall be taken to minimize encroachment, control sediment transport and stabilize the work area to the greatest extent possible during construction. Nonerodible material shall be used for the construction of causeways and cofferdams. Earthen fill may be used for these structures, if armored by nonerodible cover materials.

(m) When a live watercourse must be crossed by construction vehicles more than twice in any six-month period, a temporary vehicular stream crossing constructed of nonerodible material shall be provided.

(n) All applicable federal, state and local regulations pertaining to working in or crossing live watercourses shall be met.

(o) The bed and banks of a watercourse shall be stabilized immediately after work in the watercourse is completed.

(p) Underground utility lines shall be installed in accordance with the following standards, in addition to other applicable criteria:

(i) No more than five hundred (500) linear feet (152.5 meters) of trench may be opened at one time.

(ii) Excavated material shall be placed on the uphill side of trenches.

(iii) Effluent from dewatering operations shall be filtered or passed through an approved sediment trapping device, or both, and discharged in a manner that does not adversely affect flowing streams or off-site property.

(iv) Materials used for backfilling trenches shall be properly compacted in order to minimize erosion and promote stabilization.

(v) Restabilization shall be accomplished in accordance with these regulations.

(vi) Applicable safety regulations shall be complied with.

(q) Where construction vehicle access routes intersect paved or public roads, provisions shall be made to minimize the transport of sediment by vehicular tracking onto the paved surface. Where sediment is transported onto a paved or public road surface, the road surface shall be cleaned thoroughly at the end of each day. Sediment shall be removed from the roads by shoveling or sweeping and transported to a sediment control disposal area. Street washing shall be allowed only after sediment is removed in this manner. This provision shall apply to individual development lots, as well as to larger land disturbing activities.

(r) Each day, during which any violation above is found to have existed, shall constitute a separate offense. In no event shall a series of specified violations arising from the same operative set of facts result in civil penalties which exceed a total of three thousand dollars (\$3,000), except that a series of violations arising from the commencement of land-disturbing activities without an approved plan for any site shall not result in civil penalties which exceed a total of ten thousand dollars (\$10,000). The specification of civil penalties for the civil violations set forth in this subsection 750.07.G. shall be in lieu of criminal sanctions and shall preclude the prosecution of the violations specified in this subsection as a misdemeanor. However, violations not specified in this civil summons violation still are subject to prosecution as a misdemeanor under Section 10.1-569(A), Virginia Code Ann.

750.08 Stop Work Order:

A. Upon receipt of a sworn complaint of a violation of this section from a County inspector, the director of Public Works may, in conjunction with or subsequent to a notice to comply, issue an order requiring that all or part of the land disturbing activities permitted on the site be stopped until the specified corrective measures have been taken or, if the land disturbing activities have commenced without an approved plan, requiring that all of the land disturbing activities be stopped until an approved plan or any required permits are obtained.

If the alleged violator has not obtained an approved plan and the required permits within seven (7) days from the date the order was served, the director of Public Works may issue an order to the owner requiring that all construction and other work on the site, other than corrective measures, be stopped until an approved plan and the required permits have been obtained.

B. Where the alleged violation is causing or is in imminent danger of causing harmful erosion of lands or sediment deposition on waters within the watersheds of the commonwealth, an order may be issued whether or not the alleged violator has been issued a notice to comply under this section. Otherwise, such an order may be issued only after the alleged violator has failed to comply with a notice to comply under this section.

C. The order shall be served in the same manner as a notice to comply and shall remain in effect for up to seven (7) days. Upon the determination that appropriate corrective measures have been undertaken, the order shall be lifted immediately.

750.09 Injunctions and Other Relief:

A. Notwithstanding any other relief or remedy available under this section, the director of Public Works may apply to the Circuit Court of Prince William County for injunctive or such other equitable relief as may be appropriate in the case of a violation or threatened violation of any of the provisions of this section, without the necessity of showing that there does not exist an adequate remedy at law.

B. The remedies provided for in this section shall be cumulative in the sense that the imposition of, or attempt to, impose one remedy shall not act as a restriction of any right to impose, or attempt to impose, any other remedy authorized by this section.

C. With the consent of any person who has violated, failed, neglected, or refused to obey any regulation or order of the director of Public Works of a permit or any provision of this section, the director of Public Works may provide, in an order issued by the BOCS against such person, for payment of civil charges for violations in specific sums, not to exceed two thousand (\$2,000.00) dollars for each violation. Such civil charges shall be instead of any appropriate civil penalties which could be imposed as outlined in Section 750.07F of this manual.

750.10 Appeals: Final County decisions are subject to review by the Prince William Circuit Court, provided an appeal is filed within thirty (30) days of the date of written decision.

750.11 Escrows:

A. Prior to issuance of a soil erosion control permit, an escrow shall be required to be posted in one of the following forms:

(1) Deposited with the Prince William County director of Finance.

(2) Deposited in an appropriate financial institution. The agent shall be a permanent resident of, and shall be bonded in, the state of Virginia, for an amount in excess of the aforementioned amount of deposit.

(3) Letter of Credit. The institution must be FDIC or FSLIC insured.

B. The minimum acceptable amount for the erosion control escrow shall be one thousand (\$1,000.00) dollars. It shall include an amount sufficient for the County, should the applicant fail to perform in accordance with the agreement required in Section 750.03 of this manual, to implement and maintain the following:

(1) Conservation measures.

(2) Stabilization of all denuded areas through seeding, landscaping, and/or ground cover.

(3) Cleaning of sediment from sediment basins, traps and SWM ponds which function as sediment traps.

(4) The total amount of the escrow shall be inclusive of fifteen percent (15%) of the above costs for supervision, administration, and inflation.

C. The escrow shall be released when the site is adequately stabilized and all requirements have been completed, inspected and accepted, to include compliance with County administrative release requirements.

D. A one-time reduction of a maximum of fifty percent (50%) of the escrow amount may be approved when work has satisfactorily progressed to the stage where sufficient escrow monies would remain to ensure the installation, maintenance, and performance of erosion and sediment control measures.

750.12 Erosion Control Escrow for Building Single-family Detached Dwellings:

A. Amount of Guarantee. The escrow amount required for erosion control for each disturbed lot will be one thousand dollars (\$1,000.00), but will not exceed twenty-five thousand dollars (\$25,000.00) per builder per section of project.

B. Form or Guarantee. Same as in Section 750.11A of this manual.

751.00 EROSION AND SEDIMENT CONTROL - PLANNING AND DESIGN

751.01 General Requirements: Conservation standards shall be the state minimum criteria, standards and specifications as contained in the current Virginia Erosion and Sediment Control Handbook, with modifications as follows:

A. Standard and Specification #3.02, Temporary Gravel Construction Entrance. The minimum length for the temporary gravel construction entrance shall be seventy (70) feet (21.34 meters). Wash racks shall be required with an appropriate water source to wash the mud off the tires before entering the public road. The source of the water shall be stated on the plans. The wash water must be carried away from the entrance to a settling area to remove sediment. In addition, a construction entrance pad shall be provided for each detached single-family dwelling unit. The construction entrance shall be a minimum of thirty (30) feet (9.14 meters) long, twelve (12) feet (3.66 meters) wide, and a minimum of four (4) inches (102 millimeters) thick. VDOT #1 coarse aggregate (2 to 3 inch / 50 to 80 millimeter) stone shall be used. The pads shall be located at the proposed location of the individual driveways so that the coarse aggregate could be used as subgrade for the driveways.

B. Standard and Specification #3.04, Straw Bale Barriers. Straw bales shall be used only for sheet flow application; they shall not be used for any drainageway or channel flow applications or as perimeter controls for the site to be developed.

C. Standard and Specification #3.05, Silt Fence. Manufacturer's certification shall be required to meet the physical properties given for synthetic filter fabric per the construction specifications as noted in the current Virginia Erosion and Sediment Handbook. Prince William County shall maintain a list of acceptable materials.

D. Standard and Specification #3.06, Brush Barrier. This practice shall not be used without the specific authorization of the director of Public Works.

E. Standard and Specification #3.07, Storm Drain Inlet Protection. Any storm drain inlet protection measure which completely blocks the drain throat or entrance shall not be used. Straw bales and cinder block wrapped with filter fabric shall not be used for curb inlet protection. Block and gravel sediment filters are to be used for curb or drop inlet protection. Inlet protection devices are for drainage areas of less than one acre (0.4047 hectare). Runoff from larger disturbed areas should be routed through a temporary sediment trap (Standard and Specification #3.13).

F. Standard and Specification #3.09, Temporary Diversion Dike. The maximum allowable drainage area is five (5) acres (2.02 hectares). The dike should be located to minimize damage by construction operations and traffic. It should be adequately compacted to prevent failure and stabilized with temporary or permanent seeding and mulch immediately after construction. Dikes shall not be used to break up drainage divides to support the use of sediment traps in place of sediment basins where it will inhibit the constructability of the site. Construction of the dikes shall be in accordance with Standard and Specification #3.09 of the Virginia Erosion and Sediment Control Handbook.

G. Standard and Specification #3.13, Temporary Sediment Trap: One hundred thirty-four (134) cubic yards per acre (253.15 cubic meters per 0.4047 hectare) of the total contributing drainage area shall be required for the storage volume. One half of the design volume shall be in the form of permanent pool or wet storage and the remaining half in the form of drawdown or dry storage. Construction of the sediment trap shall be in accordance with Standard and Specification #3.13 of the Virginia Erosion and Sediment Control Handbook. The dimensions (length, width, and depth) for each trap shall be clearly labeled on the erosion and sediment control plans.

H. Standard and Specification #3.14, Temporary Sediment Basin. A designed basin shall be provided where the total contributing drainage area exceeds three (3) acres (1.21 hectare). One hundred thirty-four (134) cubic yards per acre (253.15 cubic meters per 0.4047 hectare) of total contributing drainage area shall be required for the storage volume. The design of the sediment basin shall be in accordance with Standard and Specification #3.14 of the Virginia Erosion and Sediment Control Handbook. One half of the design volume shall be in the form of permanent pool or wet storage and the remaining half in the form of drawdown or dry storage. Construction of the sediment trap shall be in accordance with Standard and Specification #3.14 of the Virginia Erosion and Sediment Control Handbook. The dimensions (length, width and depth) for each basin shall be clearly labeled on the erosion and sediment control plans.

I. Permanent or temporary soil stabilization shall be applied to denuded areas within seven (7) days after final grading is reached on any portion of the site. Temporary soil stabilization shall be applied within seven (7) days to denuded areas that may not be at final grade but will remain dormant for longer than fourteen (14) days, except for that portion of the site on which work will be continuous beyond fourteen (14) days. Permanent soil stabilization shall be applied to areas that are to be left dormant for more than six (6) months. For winter stabilization, any area denuded for more than fourteen (14) days after November 1 and before March 1 shall be mulched and seeded appropriate to the season and site conditions. Preparation of areas for permanent stabilization shall be performed in accordance with standard specification #3.32 of the Virginia Erosion and Sediment Control Handbook.

751.02 Two-Layer Perimeter Erosion Control Measures

A. To protect adjacent properties and to limit erosion and to control sediments, two layered erosion control measures shall be installed under the following conditions:

(1) Slopes of fifteen percent (15%) or greater with soils showing severe erodibility as per Prince William County soils classifications.

(2) Tidal and nontidal wetlands.

(3) Expected detrimental impact on adjacent properties, waterways, or water courses.

B. Depending on on-site conditions, two-layered erosion control measures may consist of diversion dikes (Standard and Specification #3.09) with adequate gravel outlet structures, silt fence (Standard and Specification #3.05), and/or straw bale barrier (Standard and Specification #3.04). The measures shall be placed approximately parallel to each other and no closer than ten (10) feet (3.05 meters). The outer layer shall be placed within the limits of the disturbance area identified on the approved plans. Both layers shall remain in place and functional until all disturbed areas which contribute runoff towards these measures are properly stabilized.

751.03 Sedimentation and Debris Basins:

A. In some locations, as may be allowed by Section 740.00 of this manual, sedimentation basins or debris barriers may be situated in the watercourses for the control of silt or debris while upstream construction is taking place.

B. The planning of these basins should include consideration of the necessity to remove these basins and the trapped materials when the construction process is completed. The effects of these facilities on the surrounding environment shall also be considered (i.e., the deposition of silt over root systems, the preservation of existing woodland, etc.).

C. Sedimentation basins are not normally acceptable as permanent facilities due to maintenance problems and the long term desirability of eliminating erosion rather than merely trapping a percentage of the eroded material.

D. The installation of permanent debris barriers may be desirable in particular instances. The desirability of permanent debris barriers shall be assessed on an individual basis.

E. Permanent debris barriers, if approved, should be in a location accessible to heavy equipment and trucks and would primarily be for the purpose of trapping large debris such as dead tree limbs before such material could float downstream to block a culvert system. Location of such debris barriers should include consideration of flood water levels that could occur if the barrier had trapped a considerable amount of such debris.

F. A final step in the construction process should include the removal of any debris, rubbish, trash and waste construction material in a similar manner to that done for other portions of the development.

752.00 EROSION AND SEDIMENT CONTROL - SUBMISSION REQUIREMENTS

752.01 General Requirements:

A. An erosion and sediment control plan shall be required for all land disturbing activity that exceeds two thousand five hundred (2,500) square feet (232.26 square meters). The erosion and sediment control plan shall detail those methods and techniques to be utilized in the control of the erosion and sedimentation.

B. The erosion and sediment control plan shall follow the format as set forth in the Virginia Erosion and Sediment Control Handbook, which is adopted as part of this section.

C. The checklist contained in Chapter 6 of the Virginia Erosion and Sediment Control Handbook shall be used by site planners to determine if all of the major items are included in the erosion and sediment control plan.

D. In order to prevent further erosion, the Department of Public Works may require the submission and approval of a conservation plan for any land identified by the Department as an erosion impact area.

752.02 Phased Plan:

A. A two-phased plan for the control of erosion and sedimentation, with a detailed narrative explaining each phase, is required to be submitted to address the topographical and site drainage features of a development site.

B. The narrative portion of the phased plan shall indicate at which stage of construction the transition is to be made from the initial plan to the secondary plan. This two-phased plan is designed to ensure adequate erosion and sediment control protection from the beginning of a project until its completion.

C. The phased plan shall consist of two (2) independent plans. The first plan shall describe the conservation measures required during the initial land clearing and rough grading phase. The second plan shall specify the conservation measures required once the storm sewer system is installed and operational and the roads are near completion. The plans must clearly state when a storm water management facility is to be constructed, if it is not a sediment basin.

770.00 SOIL TESTING (GEOTECHNICAL) POLICY

770.01 General Purpose: The purpose of this policy is to promote safety and protect property through a coordinated program of adequate soil testing and approval in the early stages of site development. This policy is required by the Uniform Statewide Building Code.

770.02 Engineering Soils Categorization:

A. The only comprehensive source of information about soils in the County is the Soil Survey of Prince William County, Virginia, 1989, published by the Soil Conservation Service of the United States Department of Agriculture. This survey is useful for agricultural, planning, engineering and environment enhancements.

(1) The survey referenced above describes fifty-six (56) different kinds of soils, numbered one (1) through fifty-six (56). Each of these soils carry a suffix of A through E, representing the class of slope, and a final number indicating the degree of erodibility. This results in a total of ninety-one (91) soil units.

(2) The survey has some limitations, e.g., the depth of exploration does not exceed seventy-two (72) inches, and the areas already developed at the time of survey have not been studied.

B. For the purpose of implementation of this policy, the engineering information contained in the above soil survey has been utilized for expedient and dependable engineering evaluation. Based on the engineering characteristics of the type of soil, the ninety-one (91) units are divided into three (3) categories:

(1) Category I Soils: Good soils. (No engineering difficulties anticipated.)

(2) Category II Soils: Potential problem soils. (Some engineering difficulties anticipated which may require special engineering solutions.)

(3) Category III Soils: Problem soils. (Significant engineering difficulties anticipated which may require special engineering solutions.)

C. The following criteria was utilized to determine the soil categories:

(1) Category I Soils: Soils that are not anticipated to represent any engineering problems that are associated with category II and III soils are listed below.

(2) Category II Soils: Any of the following conditions will cause an area to be designated as Category II soil:

- (a) High groundwater table (seasonal or perched).
- (b) Shallow rock.
- (c) Natural asbestos formations.
- (d) Areas located in the western coastal plain (soil unit Neabsco-Quantico-Dumfries).

(3) Category III Soils: Any of the following conditions will cause an area to be designated as a Category III soil:

- (a) High shrink/swell potential.
- (b) Compressible soils.
- (c) Existing uncontrolled or undocumented fills.
- (d) Flood plain and perennial high groundwater table.
- (e) Eastern coastal plain/marine clay soils (soil unit Dumfries-Lunt-Marr).

D. Based on the above criteria, all ninety-one (91) soils in PWC have been categorized and the results presented in a table and a digitized map available at the Department of Public Works.

770.10 Soils Report Requirement:

A. A soils report shall be prepared and submitted for approval at the time of first site plan submission. The report shall be prepared, sealed and signed by a professional engineer, registered in the Commonwealth of Virginia, qualified and experienced in geotechnical engineering and approved by the County, known as the geotechnical engineer of record (GER). The geotechnical recommendations made in the report shall be transposed in the form of specifications onto the project site/subdivision plan. The GER shall review, sign and seal these plans.

B. A soils report shall be required to be submitted, depending on the type of project and the types of soils encountered within the project, in accordance with Section 770.11 to 770.13 below.

770.11 Commercial Projects: All commercial projects will be governed by the provisions of the latest revision of the BOCA code adopted by the uniform statewide building code and special inspection program of Prince William County.

770.12 Residential Project:

A. Limited Geotechnical Study: Any of the following conditions will warrant a limited geotechnical study to be conducted, followed by the submission of a geotechnical report. However, based on reconnaissance of the site and literature review, performed for the limited geotechnical report, the GER may decide that a detailed geotechnical investigation and report is required.

- (1) Category II soils.
- (2) Unmapped areas outside eastern coastal plain (soil unit Dumfries-Lunt-Marr).
- (3) Disturbed areas, defined as those areas that have been altered by mankind without the availability of compaction or other disturbance record.

B. Detailed Geotechnical Study: Any of the following conditions will warrant a detailed geotechnical study to be conducted, followed by the submission of a detailed geotechnical report:

- (1) Category III soils.
- (2) Specialty engineering solutions expected (reinforced slope/deep foundations/ground improvement, etc.).
- (3) Retaining walls - Refer to Section 710.06 of the DCSM and special inspection program.
- (4) Ponds/dams higher than ten (10) feet (3.05 meters).

770.13 Additional Requirements: If necessary, the director of Public Works may require a geotechnical study for special situations not foreseen by this policy. Likewise, if the director of Public Works determines that problem soils are not located adjacent to or within the construction areas and that the proposed construction on a site with problem soils will not adversely impact either the subject property or adjoining properties, the director of Public Works may exempt the project from the requirement of a soils report upon submission of a letter of exception by the developer.

770.20 Guidelines for the Preparation of Geotechnical Studies: The required soils report and associated plans, specifications and other documentation must be prepared in accordance with the Prince William County Guidelines for Soils (Geotechnical) Studies (Appendix A).

770.30 Soils Report Review by Third Party:

A. After a soils report on the proposed work has been submitted, the director of Public Works may refer the report to a third party for review, analysis, advice and recommendations. Referral to a third party could be to supplement the County staff technical expertise, or when the recommendations of the GER are not satisfactory to the County.

B. The recommendations of the third party shall not be binding to the director of Public Works. However, if the director makes a finding contrary to the third party recommendations, the director shall file a written statement of reasons for such finding.

770.40 Soils Report Approval:

A. No work shall be commenced until approved by the County. Approval as to soil conditions shall not relieve any person from obtaining all other approvals and permits necessary for the proposed work.

B. The review and approval plans, specifications and reports by the County, with or without the recommendations of a third party, shall in no way relieve the developer of the responsibility for the design, construction and performance of the structures, pavement and slopes on the project and any damage to surrounding properties.

780.00 TABLES







TABLE 7-1 RATIONAL METHOD									
$q = C_f C_i A /$	$(Q = KCiA \text{ (Metric)})$								
<p>Q = peak discharge in C.F.S. / Q = flow cubic meters per second.</p> <p>C = runoff coefficient (Exhibit 1) based on the ultimate densities and intensities of the drainage area as shown on the Long Range Future Land Use Plan Map of the Comprehensive Plan.</p> <p>C_f = Correction Factor for ground saturation</p> <p>I = Rainfall intensity (Exhibit 4A)</p> <p>A = Drainage area, acres</p> <p>C_f vs. Frequency (Recommended Values)</p> <table style="margin-left: 20px;"> <tr> <td>1.0</td> <td>10 yr. or less</td> </tr> <tr> <td>1.1</td> <td>25 yr.</td> </tr> <tr> <td>1.2</td> <td>50 yr.</td> </tr> <tr> <td>1.25</td> <td>100 yr.</td> </tr> </table>	1.0	10 yr. or less	1.1	25 yr.	1.2	50 yr.	1.25	100 yr.	<p>C = Runoff Coefficient</p> <p>I = Rainfall Intensity, millimeters</p> <p>A = Drainage Area, hectares</p> <p>K = 1/360</p>
1.0	10 yr. or less								
1.1	25 yr.								
1.2	50 yr.								
1.25	100 yr.								

TABLE 7-2 PIPE SIZE AND EASEMENT WIDTH	
Pipe Size in inches/millimeters	Width of Easement in feet /meters
up to 18 / up to 450	15 / 4.57
21 to 33 / 525 to 825	20 / 6.10
36 to 48 / 900 to 1,200	25 / 7.62
54 to 72 / 1,350 to 1,800	30 / 9.14

TABLE 7-2A		
PIPE SIZE AND EASEMENT WIDTH FOR SYSTEMS USING HIGH DENSITY POLYETHYLENE PIPE (HDPE)		
Pipe Size in inches / millimeters		Width of Easement in feet / meters
up to 18"	450 mm	20 / 6.10
21" to 33"	525 to 825 mm	25 / 7.62
36"	900 mm	30 / 9.14

TABLE 7-3	
PIPE ROUGHNESS COEFFICIENT	
Pipe Material	Coefficient
Concrete	0.013
Corrugated Metal with Paved Invert	0.021
Plain Corrugated Metal	0.024
Field Bolted Arch	0.030

**TABLE 7-4
GRADING PLAN LEGEND**

Existing contour:	
Proposed contour:	
Existing spot elevation:	90.5
Proposed spot elevation:	+ 90.5
Proposed clearing limit:	
Silt fence:	
Temporary diversion dike:	
Yard Light:	 YL-1

**TABLE 7-5
WAIVER CATEGORIES FOR SFD DEVELOPMENT**

Minimum Lot Size in acres/hectares	Maximum Development Size in acres/hectares
2 / .81	n/a / n/a
1 / .4047	10 / 4.05
1/2 / .20	5 / 2.02

TABLE 7-6
PRO RATA COST SHARING FORMULA

LESS THAN OR EQUAL TO FORTY PERCENT (40%) IMPERVIOUS

$$\$/\text{Acre} = A \times I$$

$$\$/\text{hectare} = \$/\text{Acre} \times 2.47$$

GREATER THAN FORTY PERCENT (40%) IMPERVIOUS

$$\$/\text{Acre} = B + I^2 \times C$$

$$\$/\text{hectare} = \$/\text{Acre} \times 2.47$$

I = Impervious represented as a fraction, based on current zoning (see Exhibit 12)

$$A = 3,400 \times D$$

$$B = 400 \times D$$

$$C = 6,000 \times D$$

$$D = \text{Current ENR Construction Cost Index} \div 3,726$$

ENR Construction Cost Index for Jan. 1982 = 3,726

APPENDIX A

GUIDELINES FOR SOILS (GEOTECHNICAL) STUDIES

1.00 Purpose: The purpose of any geotechnical investigation is to determine the character and physical properties of soil deposits for use as foundation support or material for earthwork construction purposes. The type of structure to be built and anticipated geologic and field conditions have a major bearing on the extent of investigation to be conducted.

The investigation must, therefore, be planned with knowledge of the intended project size, land utilization and a broad knowledge of the geologic history of the area. The geotechnical report will be submitted for review with the site plan.

2:00 Scope: Experience has shown that in many areas of the County, there are potential problems including ground slippage and instability of Cretaceous Age deltaic clays, often called marine clays, shrinking and swelling of certain clays, high water table, shallow rock, etc. The extent of such soils has been approximately delineated on the County soils map.

These guidelines present minimum requirements, and every effort should be made to meet these requirements. However, depending on the site conditions, the geotechnical engineer of record (GER) may propose an alternate program for the approval of the director of Public Works. The final responsibility for adequate planning of exploration, sampling and testing programs and close supervision of the work, shall be vested in a competent professional engineer, registered in the Commonwealth of Virginia, qualified and experienced in geotechnical engineering, and approved by the County.

3.00 General Guideline:

3.01 Limited and Detailed Geotechnical Studies: The Design and Construction Standards Manual (DCSM) envisions two levels of geotechnical studies; namely, limited geotechnical study and detailed geotechnical study. The DCSM also discusses the conditions that will warrant each type of study. Related to those conditions is attached Table I, titled Prince William County Soils Categories. The extent of the two studies is described below.

The limited geotechnical study shall include, but may not be limited to, a site visit and literature search. The detailed geotechnical study shall include field exploration and laboratory testing, in addition to the requirements for the limited geotechnical study. The reports for both limited and detailed geotechnical studies shall address all pertinent geotechnical issues concerning the project, as discussed later. However, as the name implies, the limited report may not be as detailed and most often a letter report will be acceptable.

3.02 Site Investigation: The site and soil investigation should include, but not be limited to, the following factual information, analysis and recommendations:

A. Identification of surface features should include, but not be limited to, old construction, rock outcrops, water course, swamps, ditches, ponds, wooded areas, and filled-in areas. Particular emphasis must be given to identification of possible old slide areas. This should include a thorough surface reconnaissance of the site being developed and the surrounding area. Consideration should be given to reviewing aerial photographs of the area.

B. Field exploration methods shall follow the applicable standards and recognized procedures of geotechnical engineering, as set forth by ASTM, ASCE, AASHTO, AEG and other recognized standards.

C. The spacing and depth of borings must be based on the site conditions and the proposed construction. Borings shall extend sufficiently into an underlying material of adequate bearing capacity and below the depth of a possible slope failure.

D. The interval of soil sampling shall be determined on the basis of soils encountered, the type of structure and other conditions. Continuous sampling may be required. Test procedures utilized shall be identified.

E. Information on the degree of compactness of granular soils and on the consistency of cohesive soils should be obtained.

F. The presence of seepage zones, depth to groundwater and the possible fluctuations with seasons should be investigated. Water tables should be determined at least twenty-four (24) hours after completing the boring. Perforated casings or piezometers may be required in selected bore holes, satisfactory to the director of Public Works, to obtain long-term water level readings. The bore holes must be plugged after completion and after taking twenty-four (24) hour water level readings.

Direct observation of soil samples from various depths and locations shall be required for correlation with the known geology of the area. Classification and description of soils shall be done by the USCS (ASTM specification D2487), and by the visual manual identification procedure (ASTM D2488). All terms and nomenclatures used for textural description of the soils must be clearly defined. Complete soil descriptions must also include in-place conditions, geologic names, local names and any other information that is pertinent to the interpretations of the subsoil characteristics.

3.03 Laboratory Testing: The nature and extent of laboratory testing deemed necessary shall depend upon, but not be limited to, the characteristics of the soils, the type and size of the proposed structure, and the anticipated geotechnical problems. The following are the minimum items to be considered:

A. Gradation tests and water content determinations on representative samples of granular soils are often adequate.

B. Testing of cohesive soil samples may include, but not be limited to, determination of water content, Atterberg limits, dry density and unconfined compressive strength.

C. In stiff, fissured clays such as the Cretaceous marine clays, the results of unconfined compression tests alone cannot be used to assess the structural strength of the soil in-situ. Atterberg limit and hydrometer analysis tests aid in classification and also in predicting certain properties.

D. Consolidation tests should be performed on samples from relatively soft soils which may underlie the foundations. Expansive pressure of the clays should also be determined for foundation design.

E. For the deltaic clays, which have undergone relatively large strains in the past, the important properties for predicting long-term behavior are the residual effective friction angle and the residual cohesion intercept (the absolute minimum strength of clay material). These parameters should be determined by appropriate laboratory tests (drained direct shear tests using sufficient stress reversals to obtain large strains). Many reversals are required to reach residual strengths. Some references suggest using a pre-split sample (Ref. Engineering Properties of Clay Shales Report No. 1, by W. Haley and B. N. MacIver). For less complex situations, subject to approval of the director of Public Works, the required parameters may be estimated by comparison of other index properties (particularly the Atterberg limits) with those of similar soils for which test results are reported in the published literature and on the basis of past experience. Documentation shall be furnished when shear strength parameters are based on results other than laboratory tests. Such documentation must set forth the reasoning by which parameters were determined.

3.04 Geotechnical Report: All the information and data obtained from literature search, site surface observations, explorations and laboratory testing must be recorded properly in the soils report. Where applicable, the following information should be provided:

A. A plotted record of the stratification of the soil deposits, both horizontal and vertical, shall be included in the soils report. This record should indicate, in the soil profile, the surface elevation of all borings and test pits, and should also indicate the thickness and character of the soils encountered. The profiles should reach to such a depth as may be required, and are to include twenty-four (24) hour water level readings.

B. Information on groundwater elevations must be provided, including depth of permanent and perched water tables.

C. The report of the soil studies shall include sufficient analytical foundation and slope stability studies to allow a reviewer to follow the logic and assumptions on which the analysis was based and conclusions reached. Recommendations and advice concerning pavement design, foundation design, earthwork, site grading, drainage, slope stabilization and construction

procedures must be included in the report. The report shall include a complete record of the field and laboratory findings, information concerning structures to be built (types and elevations of basements), the conclusions reached from the study, and the recommendations for use by the designer and the owner. Probable total and differential settlement of foundations, special basement problems and retaining wall design must be discussed and recommendations set forth.

D. In areas that are susceptible to high water table (permanent, perched and/or seasonal) the engineer shall provide pavement design and measures to assure dry basements and to preclude wet yards, etc.

E. Where marine clays are found, an engineering analysis of the short- and long-term stability of existing and planned slopes must be made, including a careful evaluation of potential adverse effects on nearby properties. The stability analysis shall be made by acceptable methods of analysis. The long-term stability shall be based on the residual shear strength parameters for the marine clays.

F. The report shall include a discussion on the problems of expansive soils. High shrink/swell soils have been found in a wide variety of locations in Prince William County and are concentrated in the north and west of Manassas and in the eastern coastal plain (generally west of I-95). It is suggested that the design recommendations in such soils be based on expansive properties of the clay, unless it is shown otherwise by X-ray defraction studies or other appropriate laboratory tests.

4.00 Specific Guidelines

4.01 The site and soil exploration should be tailored to gather reliable information for making design and construction recommendations concerning the following structures and conditions, where applicable:

- A. Foundations/slabs.
- B. Proposed slopes or existing slopes affected by construction.
- C. Ponds/dams.
- D. Retaining walls.
- E. Pavements.
- F. Existing fills.
- G. Shrink/swell soils.
- H. Marine clays.
- I. Soil types within limits of disturbance.

- J. Asbestos formations.
- K. Groundwater.
- L. Presence of rock.
- M. Special conditions.

4.02 Frequency and Depth of Exploration:

The number and depth of borings shall be based on the following criteria:

A. Dwelling units: The GER shall decide on the number and location of borings such as to develop adequate characterization of the site subsurface conditions.

Borings shall be extended below the ground surface to the most stringent of the following:

(1) Two times the footing width, or five (5) feet below bottom of footing elevation, whichever is greater, unless refusal is encountered earlier.

(2) A minimum of five (5) feet into competent virgin soils.

(3) A minimum of five (5) feet below the bottom of undocumented fill soils into competent virgin soils.

B. Slopes: All of the slopes that are located in the coastal plain and are steeper than six-to-one (6:1), and have an elevation difference of five (5) feet, shall be explored with a minimum of one cross-section per slope and two borings per cross-section.

The GER will decide on the number of borings needed for slopes located in other areas of the County.

Borings shall extend below the bottom elevation of the slope to a minimum depth of half times the height of slope and shall provide a continuous vertical soil profile from the top of slope to the termination depth of exploration. Where deep-seated failures are anticipated, such as the eastern coastal plain, consideration should be given to drill to an elevation of the full height of the slope below the level of the bottom of the slope.

C. Ponds/dams: When the dam exceeds ten (10) feet height, a minimum of three (3) borings shall be drilled; one boring in the pond basin, one (1) boring in the embankment, and one (1) boring in the principal spillway area. If necessary, the GER may choose to drill additional borings.

The GER shall decide on the depth of boring for adequate evaluation of seepage and embankment stability.

D. Retaining Walls: Up to eight (8) feet exposed height, the GER shall decide on the number of borings from eight (8) feet to sixteen (16) feet exposed height, one (1) boring per two hundred (200) feet length of wall, higher than sixteen (16) feet exposed height, one (1) boring per one hundred (100) feet length of wall.

The depths of boring to be drilled shall be decided by the GER, based on the soil conditions and type of retaining structure.

4.03 Accuracy of Boring Placement/Elevation: The elevation of all explorations shall be determined and noted on their respective logs to within \pm one (1) foot accuracy, relative to a known datum. Similarly, the location of all explorations shall be determined and shown on a plan to within \pm five (5) feet laterally. Depending on the purpose for which the boring is being drilled, the County may agree to relax these limits, upon submission of reasonable grounds by the GER.

TABLE I
PRINCE WILLIAM COUNTY SOIL
CATEGORIES

SYMBOL	SOIL NAME	SOIL CATEGORY
1A	Aden	III
2B	Airmont-Weverton Cx	II
2C	Airmont-Weverton Cx	II
2D	Airmont-Weverton Cx	II
2E	Airmont-Weverton Cx	II
3A	Albano	III
4B	Arcola	II
5C	Arcola Nestoria Cx	II
5D	Arcola Nestoria Cx	II
6A	Baile	III
7A	Bermudian	III
8C	Braddock	I
9B	Brentsville	II
9C	Brentsville	II
10B	Buckhall	I*
10C	Buckhall	I*
11B	Calverton	II
12D	Catlett	I
13B	Catlett-Sycoline Cx	II
13C	Catlett-Sycoline Cx	II
14A	Codorus	III
15A	Comus	III
16A	Delanco	III
17A	Dulles	III
18C	Dumfries	I*
18D	Dumfries	I*
18E	Dumfries	I*
19B	Elloak	I
19C	Elloak	I
20B	Elsinboro	III
21B	Fairfax	I
21C	Fairfax	I
22A	Featherstone	III
23C	Gaila	I
23D	Gaila	I
23E	Gaila	I
24B	Glenelg-Buckhall Cx	I
24C	Glenelg-Buckhall Cx	I
24D	Glenelg-Buckhall Cx	I

25A	Glenville	II
26A	Halboro	III
27A	Halboro-Codorus Cx	III
28B	Haymarket	III
28C	Haymarket	III
29B	Hoadly	II
30B	Jackland	III
31B	Jackland-Haymarket Cx	III
31C	Jackland-Haymarket Cx	III
32A	Kelly	III
33B	Legore-Oakhill Cx	II
33C	Legore-Oakhill Cx	II
33D	Legore-Oakhill Cx	II
34B	Lunt	III
34C	Lunt	III
34D	Lunt	III
35B	Manassas	III
36D	Marr	I*
36E	Marr	I*
37A	Marumsco	III
38B	Meadowville	III
39B3	Minnieville	I
39C3	Minnieville	I
40B	Montalto	III
40C	Montalto	III
41B	Neabsco	II*
41C	Neabsco	II*
42B	Neabsco-Quantico Cx	II
43D	Nestoria	II
43E	Nestoria	II
44D	Occoquan	II
44E	Occoquan	II
45C	Orenda	I
46B	Panorama	II
46C	Panorama	II
47B	Quantico	I*
47C	Quantico	I*
47D	Quantico	I*
48A	Reaville	III
49A	Howland	III
50D	Spriggs	II
50E	Spriggs	II
51D	Stumptown	II
51E	Stumptown	II
52B	Sudley-Oatlands Cx	II
52C	Sudley-Oatlands Cx	II

53B	Sycoline-Kelly Cx	III
53C	Sycoline-Kelly Cx	III
54B	Urban Land/Udorthents	II*
55D	Watt	II*
55E	Watt	II*
56A	Waxpool	III

*When these soils are located in the eastern and western coastal plains, they will be considered as category III and II soils, resp. and II soil, resp.