
	BUILDING DEVELOPMENT POLICIES AND PROCEDURES RESIDENTIAL INSPECTIONS ELECTRICAL	Effective Date: October 10, 2003
		Supersedes Policy Dated: N/A
	4.3.1 Electrical Service Inspection	Issued by: Eric M. Mays, P.E.  Building Official

The requirements for Residential Electrical Service Inspections for services up to 400 amps, will require the service inspection to be scheduled along with the combination close-in inspection. Failure to schedule these inspections together will constitute a “Not Ready for Inspection” rejection. The field inspectors will not field generate the service inspection. With pre-approval of the Chief Electrical Inspector, the service inspection may, under special circumstances, be done *before* the close-in. Services greater than 400 amps may be called as separate inspections.