



Wade Hugh  
Acting Director

**COUNTY OF PRINCE WILLIAM**  
5 County Complex Court, Prince William, Virginia 22192-9201  
(703) 792-6930 Metro (703) 631-1703 FAX: (703) 792-7054

DEPARTMENT OF  
DEVELOPMENT SERVICES  
Division of  
Building Development

**Product Approval 06-01**  
**August 14, 2008**


<b><u>Division 7:</u></b>	<b><u>Thermal And Moisture Protection</u></b>	<b><u>Section 07210:</u></b>	<b><u>Building Insulation</u></b>
<b><u>Product:</u></b>	<b><u>Icynene Inc. Spray Foam Insulation System</u></b>	<b><u>Manufacturer:</u></b>	<b><u>Ontario Canada 6747 Campobello Rd Mississauga, Ontario Canada L5N 2L7</u></b>
<b><u>Report:</u></b>	<b><u><a href="#">ES Report #ESR-1826</a></u></b>		

**Conditions of Use:**

This report is limited to the applications and products as stated in the [ES Report #ESR-1826](#) (attached). The ICC-ES Subcommittee on National Codes intends that the report be used by the Code Official to determine that it complies with the code requirements specifically addressed, provided that this product is installed in accordance with the following conditions:

1. The Icynene Spray Foam Insulation System shall be installed in accordance with this report, the manufacturers' installation instructions and the appropriate code.
2. The Icynene Spray Foam Insulation System shall be separated from the interior of the building by an approved 15 minute thermal barrier, except when installed in attics or crawl spaces as described in Section 4.3 of the [ESR-1826 report](#).
3. The Icynene Spray Foam Insulation System shall not exceed the thickness and density noted in Sections 3.0 and 4.2.2 of the [ESR-1826 report](#).
4. The Icynene Spray Foam Insulation System may have a maximum thickness of 10" per the revised [ESR-1826 report](#) provided the installation complies with Sections 4.4.2 – 4.4.2.5 of the [ESR-1826 report](#).

5. **The Icynene Spray Foam Insulation System shall be protected from the weather after application.**
6. **The Icynene Spray Foam Insulation System shall only be used in IRC dwellings and Type V-B IBC buildings.**
7. **The use of Icynene Spray Foam Insulation System shall be identified on the plans submitted to Plans Review for approval.**
8. **The use of Icynene Spray Foam Insulation System in attic assemblies under the IRC 2003 Code must submit a Code Modification request to comply with the IRC 2006 Section R806.4 un-vented conditioned attic assemblies at time of plans review.**
9. **The use of Icynene Spray Foam Insulation System shall be inspected by the project superintendent and identified on the County's Energy Envelope and Roof Covering Certification for residential projects and will be inspected by County Inspectors on commercial projects. Manufacturers' installation instructions and a copy of [ES Report No. ESR-1826](#) must be on site for either inspection.**

  
Eric M. Mays, P.E., C.B.O.  
Building Official

**Attachment**

**[ES Report No. ESR-1826](#)**

{[www.pwcgov.org/government/dept/development/bd/Documents/008765.pdf](http://www.pwcgov.org/government/dept/development/bd/Documents/008765.pdf)}

**Cc: Product Approval Folder  
Building Plan Review Branch  
Construction Inspections Branch**